FIRE STATION #31 REPLACEMENT FOR CITY OF PANAMA CITY BEACH BAY COUNTY, FLORIDA PCB 22-86 ITB



PANAMA CITY BEACH GOVERNMENT

CITY COUNCIL Mayor Ward 1 Councilman Ward 2 Councilman Ward 3 Councilman Ward 4 Councilman

CITY MANAGER ASST. CITY MANAGER CITY CLERK

Mark Sheldon Paul Casto Phil Chester Mary Coburn Michael Jarman

Drew R. Whitman Holly White Lynne Fasone



CIVIL

MCNEIL-CARROLL ENGINEERING 17800 Panama City Beach Pkwy Panama City Beach, FL 32413 Phone: 850.234.1730

STRUCTURAL

BTK ENGINEERING 1101 Brickyard Road Chipley, Florida 32428 Phone: 850.676.4140

BID DOCUMENTS JULY 01, 2022

MECHANICAL / PLUMBING / FP

WATFORD ENGINEERING 4452 Clinton Street Marianna, FL 32446 Phone: 850.526.3447

ELECTRICAL

HG ENGINEERS, INC. 621 N. Tyndall Pkwy, Unit C Panama City, FL 32404 Phone: 850.243.6723





2211 THOMAS DRIVE, STE. 100 PANAMA CITY BEACH, FL 32408 PHONE: (850) 236-9832

Commission Number: 21804



TELECOM / SECURITY / AV

LOGAN TECHNOLOGY GROUP 918 Highway 98 East Destin, FL 32541 Phone: 850.427.2140



::

BRDG - Bridging BRG - Bearing BRK - Brick BRKT - Bracket BSMT - Basement BS - Both Sides BTUN - Between BUR - Built-up Roof BVL - Bevel BW - Both Ways C - Channel CAD - Cadmium CAP - Capacity CARP - Carpet CAT - Catalog CB - Catch Basin C/C - Center to Center CLG - Ceiling CEM - Cement CF - Cubic Feet CFM - Cubic Feet Per Minute CHAM - Chamfer Cl - Cast Iron CIR - Circle CIP - Cast-in-place CJ - Control Joint CK - Caulk C/L - Chain Link (fence) CL - Centerline CLO - Closet CLR - Clearence, Clear CLS - Closure CMU - Concrete Masonary Unit

CNTR - Counter

DS - Downspout DTA - Dovetail Anchor DTL - Detail DTS - Dovetail Slot DWG - Drawing DUGS - Drawings DWL - Dowel E - East EA - Each EF - Each Face EFS - Exterior Finish System EIFS - Exterior Insulating Finish System EJ - Expansion Joint EL - Elevation ELECT - Electrical ELEV - Elevator, Elevation EMER - Emergency ENCL - Enclosure ENT - Entrance EQ - Equal EQUIP - Equipment EST - Estimated EW - Each Way EWC - Electric Water Cooler EXH - Exhaust EXIST - Existing EXP - Exposed EXPAN - Expansion EXP JT - Expansion Joint EXT - Exterior

GWB - Gypsum Wallboard GYP - Gypsum HC - Hollow Core HD - Heavy Duty, Head HDR - Header HDRL - Handrail HDW - Hardware HEX - Hexagonal HK - Hook HM - Hollow Metal HORIZ - Horizontal HR - Hour HS - High Strength HT - Height HTR - Heater HWS - Headed Welded Studs ID - Inside Diameter (Dim.) IF - Inside Face IN - Inches INCL - Include INSUL - Insulation INT - Interíor INTM - Intermediate ISOL - Isolation JAN - Janitor JB - Jamb JC - Janitor Closet JST - Joist JT - Joint

MISC - Miscellaneous MK - Mark ML - Match Line MM - Millimeter MO - Masonary Opening MRR - Men's Restroom MS - Machine Screw MTD - Mounted MTL - Metal MULL - Mullion N - North

NA - Not Applicable NIC - Not In Contract NO. - Number NOM - Nominal NS - Non Shrink NTS - Not To Scale

0A - Overall OC - On Center OD - Outside Diameter (Dim.) OF - Outside Face OH - Overhead OPNG - Opening OPP - Opposite OPPH - Opposite Hand OPS - Operations 0VS - Oversized OZ - Ounce

	Cape Cir	Quincy's Heating &		CTURAL MA	TERIALS		CTURAL SYMBOLS	_		
Advance Auto Parts Auto parts store	Gulf Winds			CONCRETE BLOCK (CMU)			WALL SECTION			
Bay Lock and Key	og Vapor Shop r store	Brown Fire Protection								
	Fast Food · S	T HOURS AND		BRICK	FINISHED WOOD		BUILDING SECTION			
13 Hub Lane	Breakfast / S	Texaco Panama City Beach		STEEL	BATT INSULATION					
	Panama City Beach Fire Station #31	Convenience store	SAND, MORTAR, CUT STONE, CAST STONE, GYPSUM				DETAIL / ENLARGED VIEW			
Pal Pal Pal Pal	anama Oty Beach Police Department	Panama City Beach		PLYWOOD	RIGID INSULATION					
Parkside C	Panama City Beach	nFlip Bitcoin ATM	CAST IN PLACE CONCRETE			2/A6.1	ELEV NUMBER/SHEET ELEVATION IS DRAWN ON			
	Panama City	eafood Market			I TYPES	(Δ)	COLUMN GRID MARK			
Firenzo Av	Brach, City Hall Panama City Beach Water Department	Pepsi Gulf Coast Jam					LETTER OR NUMBER			
arkside Cir	Firenzo Ave	Pavers Castile Ave		INSULATING CONCRETE FOR R FACE. SEE STRUCTURAL	DRM (ICF), AND 5/8" GWB ON L FOR ICF CORE SIZE.		ELEVATION MARK			
	PROJECT LOC	CATION		<u>OR WALL:</u> 4" SPLIT-FACE IT BOARD SIDING ABOVE IG SECTIONS), SERIES I INS XPOSED CONCRETE INTER	VENEER WITH AIR SPACE SEE ELEVATIONS AND BULATING CONCRETE FORM RIOR FACE, SEE STRUCTURAL		DOOR MARK			
	17121 PANAMA (Ty Map	CITY BEACH PKWY.		CORE SIZE.	FORM (ICF) WALL:		WINDOW MARK			
	ALE			R INSULATING CONCRETE I	FORM (ICF) WALL:	•	LOUVER MARK			
CODE	INFORMATION:			HEXPOSED CONCRETE ON URAL FOR ICF CORE SIZE.	N BOTH FACES, SEE	\bigcirc	EQUIPMENT MARK			
	CODES:	EDITION:		78 GUB EA, SIDE, EXTEND 7 ADJACENT CEILING, SEE 7 ND INSULATION REQUIREN	WALL TO MIN. 6" ABOVE E FINISH SCHEDULE REMARKS MENTS.		CONSTRUCTION KEYNOTE			
 FLORIDA BUILDING C FLORIDA BUILDING C FLORIDA BUILDING C 	CODE, BUILDING (FBC-B) CODE, ACCESSIBILITY CODE, MECHANICAL (FBC-M)	2 <i>0</i> 20 2 <i>0</i> 20 2 <i>0</i> 20		ATED INTERIOR PARTITION TH 5/8" TYPE 'X' GWB EA. S	(STD: U 419): 3 5/8" (U.N.O.) SIDE, EXTEND WALL TO DECK ABOVE & EIRESAEE					
 FLORIDA BUILDING C FLORIDA BUILDING C FLORIDA BUILDING C 	20DE, ENERGY CONSERVATION 20DE, FUEL GAS (FBC-FG) 20DE, FLUMBING (FBC-P)	2 <i>0</i> 20 2 <i>0</i> 20 2 <i>0</i> 20	ALL GA REMAR	KS FOR SOUND INSULATION	SEE FINISH SCHEDULE N REQUIREMENTS.					
 FLORIDA FIRE PREVE NATIONAL ELECTRICA 	ENTION CODE (FFPC) AL CODE (NEC)	2 <i>0</i> 20 2 <i>0</i> 20		INTERIOR PARTITION: 3 5/ <' GWB EA. SIDE. EXTEND ALL EDGES CEILING GRID KS FOR SOUND INGUI ATION	18" (UN.O.) GMS WITH 5/8" WALL 6" ABOVE CEILING 4 D. SEE FINISH SCHEDULE N REQUIREMENTS					
	BITED (FBC, CHAPTER 453.8.6):									
163, AS REVISED JULY MATERIALS <u>ANY</u> PUBLI CERTIFICATION OF SAM	IC EDUCATION CONSTRUCTION PROJECT AN ME BY THE ARCHITECT OF RECORD	STOS CONTAINING ND REQUIRES	SEE ELEVATIONS AND S CONSTRUCTION	ECTIONS FOR ADDITIONAL [DETAIL <i>o</i> f Wall					
	IL DI THE ARCHITECT OF RECORD.									
				INDEX	X OF DRAWING	GS				
PA - Public Address PC - Precast PCF - Pounds Per Cubic Foot	50G - Slab On Grade SPCR - Spacer SPEC - Specification			<u>STRUCTURAL</u>						
PED - Pedestal PEMB - Pre-Engineered Metal Building PK - Parking	SPM - Single Ply Membrane g SQ - Square SS - Stainless Steel	INDEX DRAWING INDEX & GEN 51 TOPOGRAPHIC SURVEY LS1.1 LIFE SAFETY PLAN	ERAL INFORMATION (THIS SHEET)	50.1 STRUCTURAL NO 50.2 WIND CRITERIA 511 FOUNDATION PL		EØ.I LEGEND AND EI.I SITE PLAN - E21 EL OOR PLAN	D NOTES ELECTRICAL			
PL - Plate PLAS - Plastic PLBG - Plumbing	SSL - Short Slotted STD - Standard STL - Steel	CIVIL CI.1 SITE DEMOLITION PLAN		S12 LINTEL/HEADER S13 ROOF FRAMING S14 ACCESSORY B	R PLAN PLAN BUILDING	E3.1 FLOOR PLAN E4.1 FLOOR PLAN E5.1 FLOOR PLAN	N - HVAC POWER N - MISC, SYSTEMS N - LIGHTING	NO. DESCRIPTION	DRAWN CHECKED	DATE
PLF - Pounds Per Lineal Foot PLYWD - Plywood PNL - Panel	STOR - Storage STRUCT - Structural SUPER - Supervision	CI2 SITE EROSION CONTROL F CI3 SITE LAYOUT PLAN CI.4 SITE GRADING & PAVING	PLAN PLAN	52.1 STRUCTURAL W, 52.2 STRUCTURAL W, 52.3 STRUCTURAL W,	ALL SECTIONS ALL SECTIONS ALL SECTIONS	E6.1 ACCESSORY E7.1 ELECTRICAL E7.2 ELECTRICAL	BUILDING FLOOR PLANS - ELECTRICAL DETAILS DETAILS			
PP - Panel Point PR - Pair PRC6T - Precast	SUSP - Suspended SVC - Service SY - Square Yard	CI.5 SITE DRAINAGE PLAN CI.6 SITE UTILITY PLAN C2.1 CONSTRUCTION DETAILS		62.4 STRUCTURAL WA 62.5 STRUCTURAL WA 63.1 STRUCTURAL FO	IALL SECTIONS IALL REINFORCEMENT ELEVATIONS OOTING DETAILS	E1.3 ELECTRICAL E1.4 GROUNDING I E1.5 LIGHTING CO	. DETAILS DETAILS NTROLS AND FIXTURE SCHEDULES			
PREFAB - Prefabricated PREP - Preparation PROJ - Projection	SYM – Symetrical SYS – System	C2.2 CONSTRUCTION DETAILS C2.3 CONSTRUCTION DETAILS C2.4 CONSTRUCTION DETAILS		63.2STRUCTURAL FR63.3STRUCTURAL DO63.4STAIR DETAILS	RAMING DETAILS DETAILS D	E7.6 LIGHTING CO E7.7 LIGHTING CO E7.8 LIGHTING CO	NTROL DETAILS NTROL DETAILS NTROL DETAILS			
PSF - Pounds Per Square Foot PSI - Pounds Per Square Inch PSTR - Prestressed	T – Tread T&B – Top & Bottom TC – Top Chord	C2.5 CONSTRUCTION DETAILS	IGATION	MECHANICAL MØ.I HVAC LEGENDS	S, SCHEDULES, AND NOTES	E7.9 LIGHTING CO E8.1 SINGLE LINE E8.2 SCHEDULES	NTROL DETAILS POWER RISER AND SCHEDULES	PHASE SCHEMATIC DESIGN	DRAWN CHECKED	DATE 11/Ø5/21
PT - Pressure Treated, Paint, Point PTD - Painted PTN - Partition	TEMP - Temporary, Temperature T&G - Tongue & Groove THK - Thick	LPI LANDSCAPE PLAN LP2 LANDSCAPE DETAILS IPI IPPIGATION PLAN		MØ.2 HVAC SCHEDUL MI.I HVAC FLOOR F MI.2 ACCESSORY B	LEG PLAN BUILDING HVAC FLOOR PLANG	E8.3 FIRE ALARM E8.4 ROLL-UP DC	RISER DOR CONTROL RISER	DESIGN DEVELOPMENT 60% DOCUMENTS		12/17/21 Ø2/11/22
PVC - Polyvinyl Chloride PVMT - Pavement	THRESH - Threshold TLT - Toilet TCC - Ton of Constants			M2.1 HVAC DETAILS M2.2 HVAC DETAILS M2.3 HVAC DETAILS		TELECOMM TØ.1 TELECOM LEI TØ2 TELECOM NO	GEND AND NOTES	90% CONSTRUCTION DOCUMENTS		Ø3/31/22 Ø5/16/22
QC - Quality Control QT - Quarry Tile	TOE - Top of Concrete TOF - Top of Footing TOL - Toleranace	AQ.1 ARCHITECTURAL SITE PLA AQ.2 SITE DETAILS	AN	M2.4 HVAC DETAILG)	TLØ TELECOM SIT TLI TELECOM SIT TLI TELECOM SIT	TE PLAN TE DETAILS	BID SET		Ø7/Ø1/22
R - Riser, Reaction, Radius R&D - Remove and Dispose	TPG - Topping TS - Structural Tube	AI.IA ARCHITECTURAL FLOOR F AI.IB FURNITURE & EQUIPMENT F AI.IC DIMENSIONED FLOOR PLA	PLAN PLAN AN	PØ.1 PLUMBING LEGI PØ2 PLUMBING DET	END, SCHEDULE, NOTES, AND DETAILS AILS	TI.3 ACCESSORY T2.1 TELECOM DE T2.2 TELECOM DE	BUILDING - TELECOM NEW WORK FLOOR PLANS ETAILS ETAILS		THOMAS DR., STE	E 100
RAC - Rent-a-car RAD - Radius RB - Racquetball	TYP - Typical	A12A ACCESSORY BUILDING FL A12B ACCESSORY BUILDING SE A2.1 ENLARGED PLANS AND T	OOR PLANG & ELEVATIONS ECTIONG & DETAILS OILET DETAILS	P0.3 PLUMBING DET P1.1 PLUMBING PLA P1.2 PLUMBING PLA	AILS N - SANITARY N - DOMESTIC WATER & NATURAL GAS	T2.3 TELECOM DE T2.4 SECURITY & F T2.5 TELECOM DE	ETAILS PAGING DETAILS ETAILS		ONE: (850) 236-98	332
RD - Roof Drain RECEPT - Reception REF - Reference	UN - Unless Noted UNF - Unfinished UNO - Unless Noted Otherwise	A3.1 REFLECTED CEILING PLAI A4.1 EXTERIOR ELEVATIONS A5.1 BUILDING SECTIONS	N	P3.1 PLUMBING SAN P3.2 PLUMBING DOM	IITARY RISER DIAGRAMS 1ESTIC WATER RISER DIAGRAM	T3.1TELECOM SINT3.2CATV & PAGET4.1ENLARGED F	NGLE LINE DIAGRAM ING SINGLE LINE DIAGRAMS FLOOR PLANS - MAIN TELECOM ROOM			
REINF - Reinforcea, Reinforcement REM - Remove REQ - Required	UR - Urinal	A6.1 WALL SECTIONS A6.2 WALL SECTIONS A6.3 WALL SECTIONS				15.1 TELECOM RA	ACK ELEVATIONS		A THE OF FLOR	
RET - Return, Retaining REV - Revision, Reverse RFG - Roofing	VB - Vapor Barrier VCT - Vinyl Composition Tile VEL - Velocity	A6.4 WALL SECTIONS A6.5 WALL SECTIONS A1.1 ROOF PLAN		FPU. FIRE PROTECTI	ION PLAN ION PLAN					
RH - Right Hand RM - Room RO - Rough Opening	VERT - Vertical VEST - Vestibule VFY - Verify	A8.1 CASEWORK ELEVATIONS A8.2 CASEWORK DETAILS							ERED ARCI	
5 - South, Standard Beam SAN - Sanitary	VOL – Volume W/ – With	A3.1 DOOR SCHEDULE AND FR A9.2 HEAD, JAMB AND SILL DE A9.3 HEAD, JAMB AND SILL DE	ETAILS ETAILS ETAILS					PROJECT:		5
SAS - Self Adhering Sheet SC - Solid Core SCHED - Schedule	W/C - Water Closet WD - Wood WDW - Window	AIØ.1 MISC. DETAILS						PANAMA CITY B	FACH	
SCWD - Solid Core Wood Door SECT - Section, Secretary SECUR - Security	WLD - Weld W/O - Without WP - Waterproof, Workina Point							FIRE STATION # 3	REPLACEM	1ENT
SERV - Service SEW - Sewer SE - Souare Feet	WPFG - Waterproofing WS - Waterstop, Welded Stud WT - Struct Tee Cut from III Section							BAY COUNTY, FLORIDA		
SGL - Single SHT - Sheet SHTH - Sheething	WWF - Welded Wire Fabric							SHEET TITLE:		
SIM - Similar SJ - Sawed Joint								DRAWING INDEX	- SYMBOLS	
SL - Steel Line										
SLV - Sleeve								LEGEND & ABBR	EVIATIONS	
SLV - Sleeve SLO - Short Leg Out SLNT - Sealant SLV - Short Leg Vertical								SHEET NUMBER:		





1804-PCB Replacement Fire Station 31\A1-1.dwg, 7/1/2022 8:48:52 AM, Shane Boullie, Adobe PDF, 1:

					<u>SYM</u>	BOL LEGEND)	
						EXIT LIGHT FIXTURE		
ELLANEOUS:						EMERGENCY LIGHT		
					(S)	SPEAKER		
DISTANCE RATINGS					S	SMOKE DETECTOR		
		B & C	NOT REQUIRED	THOUR	H	HEAT DETECTOR		
		R-2:	0.5 HR		E	MANUAL PULL STATION		
					I EK	FIRE ALARM HORN WITH I	FLASHING LIGHT	
R FINISHES:	A RATING							
ARMS: ERS SYSTEM:	MANUAL F Providei	IRE ALARM D	1		EAA	FIRE ALARM CONTROL F	ANEL	
INGUISHERS NS:	REQUIRED REQUIRED) / PROVID) / PROVID	ÞED ÞED			SPACE NAME	< panel	
NCY LIGHTING:	REQUIRED) / PROVID	ÞED		-	BLDG No SPACE No. SQUARE FOOTAGE		
					0. L.=ØØ	OCCUPANCY LOAD (WHE	RE APPLICABLE)
					[FEI]	FIRE EXTINGUISHER IN SE	MI-RECESSED C	ABINET.
					FE2	AFF FIRE EXTINGUISHER, BRA	CKET MOUNTED M	1AX 54" TO
						TOP OF EXTINGUISHER.		
						PRIMARY EGRESS		
						SECONDARY EGRESS		
						 P ATH <i>o</i> f th	RAVEL	
					<u>NOT</u>	<u> </u>		
					1. BUILDI SPRINK	NG IS EQUIPPED WITH AN . (LER SYSTEM IN ACCORD)	APPROVED AUTC ANCE WITH FBC 9	MATIC Ø3.3.1.1
					2. THIS L SEE PI	IFE SAFETY PLAN IS PROV _ANS & SPECIFICATIONS FO	VIDED FOR REVIE OR COMPLETE SC	WONLY. OPE
					AND R	EQUIREMENTS OF SYSTEMS	3 AND CONSTRUCT	TION.
					4. SEE M	EP & FP DOCUMENTS FOR	ADDITIONAL INFO	PLAN DRMATION
					ON ST	STEMS REQUIREMENTS AND) SCOPE.	
BUNK RM					RA	TED WALL		3_
					====	INTERIOR INGUL FORM (ICF) WA	<u>.ATING CONCRET</u> LL:	Ē
EGRESS					_	INTERIOR INGUL FORM (ICF) WA	<u>.ATING CONCRET</u> _ <u>L:</u>	<u>'E</u>
WIDTH 32.5"	\rightarrow	<u> </u>			=			<u>2N</u>
FE2								
		Ι			•••••	<u></u> <u>Smoke interic</u>	<u>DR PARTITION</u>	
					REVISIO	NS		
					NO. DESCRIF	TION		KED DATE
	\sum_{n}				PHASE		DRAWN CHEC	
╶┬═╕╾┙╴╏╢	\rightarrow		ΙĻ		SCHEMATIC	DESIGN		11/Ø5/21
			١٢		DESIGN DE	EVELOPMENT		12/17/21
•	\rightarrow	COVERE PATIO			60% DOCL	IMENTS		Ø2/11/22
		133			CONSTRUC	TION DOCUMENTS		Ø5/16/2
					BID SET			Ø7/Ø1/2
			}					
							MA CITY BEA	ACH, FL
			\				E: (850) 236	-9832
	╶┛┤───┞╸					TILECIS Commiss	ion Number: 218	<i>0</i> 4
			/					X
							THE OF FL	
			7				DAVID VINCE	NT B
			/				AR0014954	58
							EREDAR	cHIM
							- COURTER	
					PROJECT:			
						MA CITY BE		
					FIRE	STATION # 31	REPLAC	EMENT
								, - •
					BAT CO	OUNTY, FLORIDA		
					SHEET TITLE:			
							1	
					╏┍╖╾╤╶┊	JAFEII MLAN	4	
					SHEET NUMBE	R:		
							Ć	311
					•		//	



SITE DEMOLITION DRAWING NOTES:

- 1. SEE SYMBOL LEGEND ON THIS SHEET FOR SYMBOL INFORMATION AND REFERENCED DETAILS.
- 2. ALL DEMOLISHED MATERIALS (ie., SIGNS, CONCRETE, ASPHALT, ETC...) TO BE REMOVED
- UNDERGROUND UTILITIES PRIOR TO CONSTRUCTION. 4. THE DEVELOPER AND/OR CONTRACTOR IS RESPONSIBLE FOR FOLLOWING REQUIRED WASTE MANAGEMENT PRACTICES AS DEFINED IN THE BAY COUNTY MUNICIPAL CODE SECTION 22-91 "UNLAWFUL DISPOSAL OF WASTE, FAILURE TO DELIVER WASTE", WHICH MAKES IT
- OR OR PRIVATE PROPERTY. 5. IT IS THE CONTRACTORS RESPONSIBILITY TO CALL SUNSHINE ONE AT 811 FOR UTILITY LOCATES PRIOR TO CONSTRUCTION.
- 6. DEMOLITION SHALL BE COORDINATED WITH PROJECT PHASING NOTED ON SHEET A0.1 SYMBOL LEGEND
- N1 (SEE NOTE ie., #1 SEE NOTES ON THIS SHEET)
- **RJ** (REMOVE EXISTING MATERIALS TO NEAREST JOINT)
- **RM** (REMOVE EXISTING MATERIALS) SAW (SAW CUT AND REMOVE EXISTING MATERIALS)



DEMOLITION AREA



AND DISPOSED OF IN A LEGAL MANNER.
ALTHOUGH EVERY ATTEMPT TO LOCATE UNDERGROUND UTILITIES HAS BEEN MADE, THERE IS THE POSSIBILITY OF UNDERGROUND GAS, ELECTRICAL, WATER SEWER, ETC... THAT HAS NOT BEEN LOCATED. THE CONTRACTOR SHALL FIELD VERIFY THE LOCATION OF ALL UNDERGROUND UTILITIES PRIOR TO CONSTRUCTION.

UNLAWFUL FOR ANY PERSON TO DUMP, LEAVE OR BURY ANY SOLID WASTE ON PUBLIC





C1.1



SITE EROSION CONTROL DRAWING NOTES:

- 1. EROSION CONTROL SHALL BE MAINTAINED FOR THE DURATION FOR THE PROJECT. 2. ALL CONSTRUCTION OUTSIDE OF PROPERTY LINES IS SHOWN IN DETAIL ON PERMIT DRAWINGS. (SEE GENERAL NOTES.).
- 4. SEE SECTIONS IN CONSTRUCTION DETAILS. 5. SILT FENCE TO BE INSTALLED AT PERIMETER OF SITE DURING CONSTRUCTION. EROSION
- PROJECT TO RESTRICT ANY TURBID RUNOFF FROM LEAVING THE CONSTRUCTION SITE. 6. CONTROL OF SEDIMENT-LADEN RUNOFF SHALL BE PROVIDED WITH HAY BALES AND/OR CONSTRUCTED TO PREVENT SEDIMENT TRANSPORT. THE MEANS FOR RETAINING THE
- ARE COMPLETE. 7. THE CONTRACTOR IS RESPONSIBLE FOR TREATING ALL ONSITE STORMWATER DRAINAGE AS
- DISCHARGE. 8. ALL CATCH BASINS, INLETS AND ACCESSES TO UNDERGROUND STORMWATER SYSTEMS SHALL BE PROTECTED IN ACCORDANCE WITH THE ATTACHED DETAILS.
- DISTRICT, ETC.). 10. CONSTRUCTION DRIVES SHALL SLOPE AWAY FROM THE ROADWAY AT A MINIMUM SLOPE OF
- WARN APPROACHING DRIVERS AND PEDESTRIANS.
- 11. THE DEVELOPER AND/OR CONTRACTOR IS RESPONSIBLE FOR FOLLOWING REQUIRED WASTE PROPERTY.
- THE FDEP GENERIC PERMIT FOR STORMWATER DISCHARGE FROM LARGE AND SMALL
- CODE ENFORCEMENT ACTION AND FINES. (7) CALENDAR DAYS AND/OR WITHIN 24 HOURS OF THE END OF A STORM EVENT (RAINFALL) THAT IS A 1/2 INCH OR GREATER: A. POINTS OF DISCHARGE TO WATERS OF THE UNITED STATES. STRUCTURAL CONTROLS.
- F. LOCATIONS WHERE VEHICLES ENTER OR EXIT THE SITE. 14. THE CONTRACTOR SHALL INITIATE REPAIRS WITHIN 24 HOURS OF INSPECTION THAT INDICATE AND MAINTAIN RAIN GAGES AND DAILY RAINFALL RECORDS. WHERE SITES HAVE BEEN PERMANENTLY STABILIZED, INSPECTIONS SHALL BE CONDUCTED AT LEAST ONCE EVERY THE FIELD AGREE WITH THE LATEST STORMWATER POLLUTION PREVENTION PLAN.
- MONTH. AS NEEDED.
- 16. RECORDS OF THE INSPECTIONS AND THE CONSTRUCTION PERMIT MUST BE MAINTAINED AT THE CONSTRUCTION SITE AND BE READILY AVAILABLE FOR INSPECTION 17. ALL STORMWATER MANAGEMENT FACILITIES AND EROSION CONTROL MEASURES SHALL BE INSTALLED PRIOR TO COMMENCEMENT OF ANY CONSTRUCTION, DEMOLITION OR OTHER DISTURBANCE TO THE SUBJECT SITE.

CONSTRUCTION SEQUENCE AND BMP'S NWFWMD

- 18. THE INITIAL PART OF THE CONSTRUCTION PROCESS SHALL BE THE INSTALLATION OF SILT SECOND STEP SHALL BE THE INSTALLATION OF THE CONSTRUCTION ENTRANCE AND CREATED TO CAPTURE ANY OVERLAND FLOW AND ACT AS A SEDIMENT TRAP. IT IS GRADING OF THE STORMWATER BASIN.
- 19. TYPICALLY, THE SANITARY SEWER, STORM SEWER, AND WATER MAINS ARE INSTALLED RESPECTIVELY. UPON INSTALLATION OF THE STORM SEWER, HAY BALES AND FILTER FABRICS FROM LEAVING THE SITE (SEE EROSION CONTROL PLAN).
- SHALL BE USED WHEN FINAL GRADES ARE ESTABLISHED.
- OF THIS PROJECT AND BE MANAGED IN ACCORDANCE THE THE STATE NPDES PROGRAM.
- 22.THE DESIGN OF THE STORMWATER MANAGEMENT SYSTEM FOR THIS PROJECT COMPLIES WITH THE REQUIREMENTS OF THE FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION AND THE NORTHWEST FLORIDA WATER MANAGEMENT DISTRICT.
- 23.THE ENGINEER OF RECORD IS RESPONSIBLE FOR MONITORING CONSTRUCTION OF THE STORMWATER MANAGEMENT FACILITY AND SUBMITTING TO THE APPROPRIATE AGENCY NOTICE OF COMMENCEMENT AND AS-BUILT CERTIFICATIONS FOR THE PROJECT WHEN COMPLETED.

SYMBOL LEGEND

- \implies (stormwater surface flow) **ISB** (INLET SEDIMENT BARRIER – SEE CONSTRUCTION DETAILS)
- **SILT** (SILT FENCE SEE CONSTRUCTION DETAILS)

PVG (24' WIDE x 50' DEEP FDOT #1 OR #2 GRAVEL CONSTRUCTION ENTRANCE 6" THICK) SA (SEE ARCH. PLANS)



3. SEE SYMBOL LEGEND ON THIS SHEET FOR SYMBOL INFORMATION AND REFERENCED DETAILS.

CONTROL MEASURES WILL BE UTILIZED THROUGHOUT THE CONSTRUCTION PHASE OF THIS GEOTECH STYLE FABRICS. ALL CONTROL MEASURES SHALL BE PROPERLY LOCATED AND SEDIMENTS WILL BE MAINTAINED BY THE CONTRACTOR UNTIL PERMANENT IMPROVEMENTS

REQUIRED TO MEET THE CRITERIA OF 62-3 FLORIDA ADMINISTRATIVE CODE, F.A.C. PRIOR TO

9. THE CONTRACTOR IS RESPONSIBLE FOR COMPLYING WITH THE TERMS AND CONDITIONS OF ANY STORMWATER PERMITS THAT MAY APPLY (FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION, FLORIDA DEPARTMENT OF TRANSPORTATION, BAY COUNTY, WATER MANAGEMENT

2.00% TO DISTANCE OF NOT LESS THAN 15 FEET FROM THE EDGE OF PAVEMENT. THE MAXIMUM WIDTH OF THE DRIVE SHALL BE 30 FEET WITH #57 GRAVEL SURFACE 6 INCHES THICK. SIGNS SHALL BE PLACED (IN ACCORDANCE WITH CITY AND STATE REQUIREMENTS) TO

MANAGEMENT PRACTICES AS DEFINED IN THE BAY COUNTY MUNICIPAL CODE SECTION 22-91 "UNLAWFUL DISPOSAL OF WASTE, FAILURE TO DELIVER WASTE", WHICH MAKES IT UNLAWFUL FOR ANY PERSON TO DUMP, LEAVE OR BURY ANY SOLID WASTE ON PUBLIC OR OR PRIVATE

12. THE DEVELOPER AND/OR CONTRACTOR IS RESPONSIBLE FOR OBTAINING COVERAGE UNDER CONSTRUCTION ACTIVITIES PRIOR TO START OF CONSTRUCTION OR ANY DISTURBANCE OF LAND GREATER THAN 1 ACRE. THE DEVELOPER/CONTRACTOR WILL FORWARD A COPY OF THE PERMIT AND WILL PROVIDE 48 HOUR NOTIFICATION TO THE APPROPRIATE AGENCIES PRIOR TO COMMENCEMENT OF CONSTRUCTION. ALL REQUIRED ELEMENTS OF THE SWPP MUST BE IN PLACE PRIOR TO COMMENCEMENT OF CONSTRUCTION. FAILURE TO COMPLY COULD RESULT IN 13. QUALIFIED PERSONNEL SHALL INSPECT THE FOLLOWING ITEMS AT LEAST ONCE EVERY SEVEN

> B. POINTS OF DISCHARGE TO MUNICIPAL SEPARATE STORM WATER SYSTEMS. C. DISTURBED AREAS OF THE SITE THAT HAVE NOT BEEN FINALLY STABILIZED. AREAS USED FOR STORAGE OF MATERIALS THAT ARE EXPOSED TO PRECIPITATION.

ITEMS ARE NOT IN GOOD WORKING ORDER. TO COMPLY, THE CONTRACTOR SHALL INSTALL MONTH. THE CONTRACTOR SHALL ALSO INSPECT AND CERTIFY THAT CONTROLS INSTALLED IN 15. IF INSPECTIONS INDICATE THAT THE INSTALLED STABILIZATION AND STRUCTURAL PRACTICES ARE NOT SUFFICIENT TO MINIMIZE EROSION, RETAIN SEDIMENT, AND PREVENT DISCHARGING POLLUTANTS, THE CONTRACTOR SHALL PROVIDE ADDITIONAL MEASURES, WHERE SITES HAVE BEEN PERMANENTLY STABILIZED, INSPECTIONS SHALL BE CONDUCTED AT LEAST ONCE EVERY

FENCE AROUND THE PERIMETER OF THE AREA THAT IS TO BE DISTURBED TO ENSURE NO TURBID RUNOFF LEAVES THE CONSTRUCTION SITE. THE SILT FENCE SHALL BE INSTALLED PER THE CONSTRUCTION DETAILS. IF THERE IS A POSSIBILITY OF RUNOFF TO A WATER BODY, TURBIDITY CURTAIN SHALL BE INSTALLED PER THE CONSTRUCTION DETAILS. THE DEMOLITION OF ANY EXISTING IMPROVEMENTS AS NEEDED (SEE DEMOLITION PLAN). THE THIRD STEP SHALL BE TO CLEAR AND GRUB AREAS WHERE IMPROVEMENTS ARE TO BE INSTALLED. AS FILL IS BROUGHT INTO THE SITE, THE STORMWATER BASIN SHOULD BE RECOMMENDED THAT THE BASIN BE CONSTRUCTED APPROXIMATELY 1/2' HIGHER THAN DESIGN AT THIS POINT TO ENSURE ALL SILTS AND FINES ARE REMOVED AT THE TIME OF FINAL

SHALL BE USED AT ALL INLET OPENINGS PER THE CONSTRUCTION DETAILS TO THE KEEP THE SYSTEM FREE OF SEDIMENTS DURING THE CONSTRUCTION PHASE. DEPENDING ON SITE CONDITIONS AND SIZE, SEDIMENT TRAPS SHALL BE UTILIZED TO PREVENT TURBID RUNOFF

20.SITE STABILIZATION SHALL BE PROVIDED AS SOON AS THE GRADING WILL ALLOW IN ORDER TO STOP EROSION AND REDUCE TURBID RUNOFF. SEEDING, SODDING, OR HYDROSEEDING

21.EROSION CONTROL MEASURES SHALL BE UTILIZED THROUGHOUT THE CONSTRUCTION PHASE



REVISIONS:

DRAWN CHECKED DATE DESCRIPTION PHASE: DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22 2211 THOMAS DRIVE, SUITE 100 PANAMA CITY BEACH, FL



M^CNEIL⁻ -CARROLL ENGINEERING, INC.

17800 Panama City Beach Parkway Panama City Beach, Florida 32413 Phone: 850-234-1730 Fax: 850-234-1731

Professional Engineering Consultants STATE OF FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER: 7288

PHONE: (850) 236-9832

PROJECT:

PANAMA CITY BEACH **REPLACEMENT FIRE STATION # 31**

PANAMA CITY BEACH, FLORIDA SHEET TITLE:

SITE EROSION CONTROL PLAN



SITE LAYOUT DRAWING NOTES:

- ALL RADII AT FACE OF CURB ARE 5' UNLESS OTHERWISE SHOWN.
 CONTRACTOR SHALL PROVIDE MCNEIL CARROLL ENGINEERING, INC. FIVE (5) SETS OF AS-BUILT DRAWINGS AND ONE (1) DIGITAL COPY (AUTOCAD FORMAT) OF THE COMPLETED PROJECT. DRAWINGS SHALL BE PREPARED AND SIGNED & SEALED BY A FLORIDA

SYMBOL LEGEND

(DENOTES NEW "STOP" SK	GN)		
(DENOTES NEW "HANDICAP	PARKING" SIGN)		
(DENOTES NEW "DO NOT I	ENTER" SIGN)		
lpha (denotes critical dimension)	SION TO OUTSIDE FACE OF BUILDING)		
BIKE (BIKE PARKING FOR 6 BIC	CYCLES)		
CSW (CONCRETE SIDEWALK - S	SEE CONSTRUCTION DETAILS)		
DS (DRAINAGE STRUCTURE -	SEE GRADING & DRAINAGE PLAN)		
	SEE CONSTRUCTION DETAILS)		
	DEDNIT)		
FDOT (SEE F.D.O.T. CONNECTION	NOTES ON THIS SUFET)		
NI (SEE NOIE ie., #1 - SEE	NOTES ON THIS SHEET)		
(RAMP - SEE GRADING &	DRAINAGE PLAN)		
SA (SEE ARCH. PLANS)			
SS (SEWER STRUCTURE - SE	E UTILITY PLAN)		
SWMF (STORM WATER MANAGEME	NT FACILITY)		
WF (WATER FIXTURE – SEE U	ITILITY PLAN)		
	SITE DATA TABLE		
PARCEL ID:			
GOVERNING ENTITY – PANAMA CIT	TY BEACH		
ZONING - PUBLIC FACILITY			
TOTAL AREA OF SITE: 415,905	D SQUARE FEET - 9.55 ACRES		
TUTAL BUILDING AREA: (EX. 59,99	$\frac{19}{5}$ SF - 1.38 AURES)+(PRU: 12,680	SF - 0.29 ACRES)=101AL: 72,679 SF - 1.67 ACRES	
THE PLOOD ZONES ON FROFERIT .		PROPOSED / FXISTING	
TOTAL IMPERVIOUS AREA	291134 SQUARE FEET - 6.69 AC	231.956 SQUARE FEET - 5.32 AC	
IMPERVIOUS SURFACE RATIO	0.70	0.56	
FLOOR AREA RATIO	N/A	0.17	
DENSITY	N/A UNITS PER ACRE	N/A UNITS PER ACRE	
OPEN SPACE AREA	124,771 SQUARE FEET – 2.86 AC	183,949 SQUARE FEET – 4.22 AC	
OPEN SPACE RATIO	0.30 MIN	0.44	
FRONT YARD SETBACK	20 FEET	25 FEET	
SIDE YARD SETBACK	8-20 FEET	10 FEET	
REAR YARD SETBACK	N/A	N/A	

	OPEN SPA	ACE AREA		1	24,771	SQUARE	FEET -
OPEN SPACE RATIO					30 MIN	١	
FRONT YARD SETBACK				2	D FEET		
	SIDE YARD) SETBAC	κ	8	-20 FE	EET	
	REAR YAR	D SETBA	СК	N	/Α		
			PAR	KING SE	ACE S	CHEDULE	

NO. ANGLE WIDTH DEPTH NOTES: ALL PARKING STALLS SHALL BE 4" WHITE STRIPING ON ASP YELLOW ON CONCRETE. HANDICAP SIGNAGE AND STRIPING S STATE AND CITY CODE. LANE SEPARATION LINES SHALL BE 6

REQUIRED PARKING CALCULATION				
PROPOSED USE	PARKING REQUIREMENT	SQUARE FOOTAGE/UNITS	SPACES REQUIRED	
OFFICE/(POLICE STATION)	3.33 PER 1000 SQ. FT	18,246 SQUARE FEET	61	
OFFICE/(PUBLIC WORKS)	3.33 PER 1000 SQ. FT	23,828 SQUARE FEET	79	
OFFICE/(FIRE STATION)	3.33 PER 1000 SQ. FT	7,445 SQUARE FEET	25	
ASSEMBLY/CITY HALL, TDC)	1 PER 5 SEATS	275 SEATS	55	
		TOTAL PARKIN	IG REQUIRED = 220	
		TOTAL PARKIN	IG PROVIDED = 274	



PROJECT. DRAWINGS SHALL BE PREPARED AND SIGNED & SEALED BT A FLORIDA REGISTERED SURVEYOR.
3. ALL DIMENSIONS AT CURB ARE FROM FACE OF CURB.
4. ALL DISTURBED AREAS SHALL BE RESTORED TO ORIGINAL CONDITION AND SODDED PER FDOT INDEX 105.
5. A COPY OF ALL REGULATORY PERMITS SHALL BE KEPT ON SITE.
6. THE CONTRACTOR SHALL REVIEW THE COMPLETE NWFWMD PERMIT PRIOR TO CONSTRUCTION. COMMENCEMENT.

THE CONTRACTOR SHALL REVIEW THE COMPLETE NWFWMD PERMIT PRIOR TO CONSTRUCTION COMMENCEMENT.
 AN 8 1/2 x 11 NWFWMD WEATHER RESISTANT SIGN, INCLUDING THE PERMIT NUMBER SHALL BE PLACED ON THE PROPERTY FACING THE ROAD.
 ALL PROPOSED UTILITIES TO BE PLACED UNDERGROUND.
 ALL ABOVE GROUND UTILITIES TO BE SCREENED BY LANDSCAPING.

5' WIDE AISLE	
WIDE AISLE	
PHALT AND 4" SHALL BE TO 6" WIDF	



C1.3



SITE GRADING AND PAVING DRAWING NOTES:

- OF IN A LEGAL MANNER.
- 3. SEE SECTIONS IN CONSTRUCTION DETAILS.
- TO CONSTRUCTION.
- 105.

SYMBOL LEGEND

- 34.60 (EXISTING SPOT ELEVATION) +12.50 (PROPOSED FINISHED GRADE) \implies (stormwater surface flow)
- CSW (CONCRETE SIDEWALK- SEE CONSTRUCTION DETAILS) CUIF (F.D.O.T. CURB ie., TYPE F - SEE CONSTRUCTION DETAILS)
- HR (5' WIDE HANDICAP RAMP ie.,12:1 SLOPE)
- **PVA** (ASPHALT PAVEMENT SEE CONSTRUCTION DETAILS) (CONCRETE PAVEMENT - SEE CONSTRUCTION DETAILS)
- **PVHC** (HEAVY DUTY CONCRETE PAVEMENT SEE CONSTRUCTION DETAILS)
- (ASPHALT PAVEMENT OVERLAY SEE CONSTRUCTION DETAILS) MAT (MATCH PROPOSED FLUSH WITH EXISTING SURFACE) N 1 (SEE NOTE ie.,#1 - SEE NOTES THIS SHEET) SA (SEE ARCHITECTURAL PLANS)
- TRANS (TRANSITION CURB 3')



1. SEE SYMBOL LEGEND ON THIS SHEET FOR SYMBOL INFORMATION AND REFERENCED DETAILS. 2. ALL DEMOLISHED MATERIALS (ie., SIGNS, CONCRETE, ASPHALT, ETC...) TO BE REMOVED AND DISPOSED

4. CONTRACTOR SHALL PROVIDE MCNEIL CARROLL ENGINEERING, INC. FIVE (5) SETS AND ONE (1) DIGITAL COPY (AUTOCAD FORMAT) OF AS-BUILT DRAWINGS OF THE COMPLETED PROJECT. DRAWINGS SHALL BE PREPARED AND SIGNED & SEALED BY A FLORIDA REGISTERED SURVEYOR. 5. IT IS THE CONTRACTORS RESPONSIBILITY TO CALL SUNSHINE ONE AT 811 FOR UTILITY LOCATES PRIOR 6. ALL DISTURBED AREAS SHALL BE RESTORED TO ORIGINAL CONDITION AND SODDED PER FDOT INDEX





C1.4



SITE DRAINAGE DRAWING NOTES:

- 1. SEE SYMBOL LEGEND ON THIS SHEET FOR SYMBOL INFORMATION AND REFERENCED DETAILS.
- OF IN A LEGAL MANNER.
- BY THE CITY.
- PREPARED AND SIGNED & SEALED BY A FLORIDA REGISTERED SURVEYOR.
- TO CONSTRUCTION. 105
- TIMES MUST BE APPROVED BY CITY.

SYMBOL LEGEND

DP16 (SEE DRAINAGE PIPE SCHEDULE THIS SHEET ie.,#16)

- DS12 (SEE DRAINAGE STRUCTURE SCHEDULE THIS SHEET ie.,#12) N 1 (SEE NOTE ie.,#1 - SEE NOTES THIS SHEET)
- RD[6] (6" ROOF DRAIN CONNECTION SEE CONSTRUCTION DETAILS)
- RD8 (8" ROOF DRAIN CONNECTION SEE CONSTRUCTION DETAILS) SA (SEE ARCHITECTURAL PLANS)

SWMF 1 (SEE STORM WATER MANAGEMENT FACILITY SCHEDULE THIS SHEET)

	DRAINAGE PIPE SCHEDULE					
NO.	SIZE	LF	TYPE	SLOPE		
DP1	15"	92	ADS	0.50%		
DP2	15"	96	ADS	0.50%		
DP3	15"	50	ADS	0.50%		
DP4	15"	45	ADS	0.50%		
DP5	15"	95	ADS	0.50%		
DP6	10"	75	ADS	0.50%		
DP7	18"	42	ADS	0.50%		
DP8	10"	17	ADS	0.50%		
DP9	24"	99	ADS	0.50%		
DP10	24"	170	ADS	0.50%		
DP11	24"	142	ADS	0.50%		
DP12	24"	84	ADS	0.50%		
DP13	24"x8"		INSERTA TEE	0.50%		
DP14	8"	53	ADS	0.50%		
DP15	8"	52	ADS	0.50%		
ALL AD	ALL ADS PIPE SHALL BE AS SHOWN OR EQUAL					

ALL PERFORATED PIPE SHALL HAVE A GRAVEL PACK ALL ADS PIPE SHALL BE RATED N-12 SEE CONSTRUCTION DETAILS.

DRAINAGE	STRUCTURE	SCHEDUL

IPE INV
00
59
11
36
53
00
53
15
94
14
55
13
14 W,E;
50
29

2' SUMP UNLESS OTHERWISE NOTED.

SEE CONSTRUCTION DETAILS.

STORMWATER OPERATION AND MAINTENANCE SCHEDULE (A) STORMWATER MANAGEMENT SYSTEM SHALL BE OPERATED AND MAINTAINED IN ACCORDANCE WITH THE APPROVED DESIGN, PLANS AND CALCULATIONS. (B) THE OPERATION AND MAINTENANCE ENTITY SHALL PROVIDE FOR THE INSPECTION OF THE STORMWATER MANAGEMENT SYSTEM IN ACCORDANCE WITH SUBSECTION 62-346.095(6), F.A.C. DURING THE INSPECTION, SPECIAL ATTENTION SHOULD BE MADE TO INSURE THAT: 1. ALL EROSION IS CONTROLLED AND SOIL IS STABILIZED TO PREVENT SEDIMENT DISCHARGE

- TO WATERS IN THE STATE. 2. OILS AND GREASES, AND OTHER REFUSE. 3.
- AT A SANITARY LANDFILL OR BY OTHER LAWFUL MEANS. 4. ALL STRUCTURES WITHIN STORMWATER MANAGEMENT SYSTEMS HAVE NOT BECOME
- TO RENDER THEM INOPERABLE. (C) INSPECTIONS OF THE PERMITTED SYSTEM SHOULD BE CONDUCTED AT LEAST ONCE EVERY THIRD YEAR AFTER CONVERSION OF A PERMIT TO THE OPERATION PHASE.

2. ALL DEMOLISHED MATERIALS (ie., SIGNS, CONCRETE, ASPHALT, ETC...) TO BE REMOVED AND DISPOSED 3. ALL DRAINAGE PIPES TO BE DEDICATED TO THE CITY OF PANAMA CITY BEACH SHALL BE VIDEO RECORDED AND PLACED ON A DIGITAL MEDIA (NO TAPES). VIDEO MUST BE REVIEWED AND APPROVED 4. CONTRACTOR SHALL PROVIDE MCNEIL CARROLL ENGINEERING, INC. FIVE (5) SETS AND ONE (1) DIGITAL COPY (AUTOCAD FORMAT) OF AS-BUILT DRAWINGS OF THE COMPLETED PROJECT. DRAWINGS SHALL BE 5. IT IS THE CONTRACTORS RESPONSIBILITY TO CALL SUNSHINE ONE AT 811 FOR UTILITY LOCATES PRIOR 6. ALL DISTURBED AREAS SHALL BE RESTORED TO ORIGINAL CONDITION AND SODDED PER FDOT INDEX 7. POLICE IMPOUND YARD HAS LIMITED/CONTROLLED ACCESS. CONTRACTOR TO COORDINATE ACTIVITIES WITHIN FENCE LINE WITH CITY TO MINIMIZE IMPACTS ON POLICE DEPARTMENT OPERATIONS. ACCESS

FRT ; 32.24 N

THE SURFACE WATER MANAGEMENT SYSTEM IS KEPT FREE OF DEBRIS, TRASH, GARBAGE, ENGINEERED STORMWATER MANAGEMENT SYSTEM THAT INCLUDE OIL AND GREASE SEPARATORS, SKIMMERS, OR COLLECTION DEVICES ARE WORKING PROPERLY AND DO NOT ALLOW THE DISCHARGE OF OIL OR GREASES. OILS AND GREASES OR OTHER MATERIALS REMOVED FROM SUCH A DEVICE DURING ROUTINE MAINTENANCE SHALL BE DISPOSED OF

CLOGGED OR CHOKED WITH VEGETATIVE OR AQUATIC GROWTH TO SUCH AN EXTENT AS





SITE UTILITY DRAWING NOTES:

- 1. SEE SYMBOL LEGEND ON THIS SHEET FOR SYMBOL INFORMATION AND REFERENCED DETAILS.
- 2. SEE SECTION AND DETAILS IN CONSTRUCTION DETAILS.
- 3. ALL PROPOSED UTILITIES SHALL BE PLACED UNDERGROUND. 4. ALL SEWER LINES TO BE DEDICATED TO THE CITY OF PANAMA CITY BEACH SHALL BE VIDEO RECORDED AND PLACED ON A DIGITAL MEDIA (NO TAPES). VIDEO MUST BE REVIEWED AND APPROVED BY THE CITY.
- 5. CONTRACTOR SHALL PROVIDE MCNEIL CARROLL ENGINEERING, INC. FIVE (5)
- 6. IT IS THE CONTRACTORS RESPONSIBILITY TO CALL SUNSHINE ONE AT 811
- FOR UTILITY LOCATES PRIOR TO CONSTRUCTION. 7. ALL DISTURBED AREAS SHALL BE RESTORED TO ORIGINAL CONDITION AND
- SODDED PER FDOT INDEX 105. 8. CONNECT TO EXISTING 2" WATER SERVICE.
- 9. REMOVE PLUG/CAP AND CONNECT TO EXISTING 12" REUSE MAIN.

SYMBOL LEGEND

- CO (4" CLEANOUT SEE CONSTRUCTION DETAILS)
- FDC (FIRE DEPARTMENT CONNECTION)
- LAT (4" SANITARY SEWER LATERAL @1.00% SLOPE MAX SEE CONSTRUCTION DETAILS)
- (SEE NOTE ie., #1 SEE NOTES THIS SHEET)
- RF12 (SEE REUSE WATER FIXTURE SCHEDULE THIS SHEET ie.,#12 SEE CONSTRUCTION DETAILS)
- **RP10** (SEE REUSE WATER PIPE SCHEDULE THIS SHEET ie.,#10 SEE CONSTRUCTION DETAILS)
- SA (SEE ARCHITECTURAL PLANS) WF14 (SEE WATER FIXTURE SCHEDULE THIS SHEET ie.,#14 SEE CONSTRUCTION DETAILS) WP10 (SEE WATER PIPE SCHEDULE THIS SHEET ie., #10 SEE CONSTRUCTION DETAILS)

	WATEF	R MAIN P	IPE SCHEDULE	
NO.	SIZE	LF	TYPE	N
WP1	2"	28	PVC	WE
WP2	6"	30	FIRE LINE	WF
WP3	6"	118	PVC	WF
WP4	6"	38	PVC	WF
WP5	8"X4"		TAPPING SLEEVE W/ VALVE	WF
WP6	4"	68	FPVC (BORED)	WF
WP7	4"	39	PVC	WF
WP8	4"		90° BEND	WF
WP9	4"X1"		TEE	SEE
WP10	1"	58	PVC	
LESS T	HAN 4'	' WATER	MAIN - ASTM D2241 SDR-2	
/ _ h	WATER			

4"-6" WATER MAIN - AWWA C900 DR18 8"-12" WATER MAIN - AWWA C900 DR25 ALL LINES SHALL BE THE COLOR BLUE.

RE	USE W	ATER MAII	N PIPE SCHEDULE
NO.	SIZE	LF	TYPE
RP1	12"		90° BEND
RP2	12"	220	PVC
RP3	12"		TEE
RP4	12"		GATE VALVE ASSEMBLY
RP5	12"		45° BEND
RP6	12"	117	PVC
DD7		6	

RP72"6PVCRP812"--GATE VALVE ASSEMBLY W/ CAPUP TO 4" WATER MAIN-CLASS 2004-12" WATER MAIN-C900 DR18ALL LINES SHALL BE THE COLOR PURPLE.



SETS AND ONE (1) DIGITAL COPY (AUTOCAD FORMAT) OF AS-BUILT DRAWINGS OF THE COMPLETED PROJECT. DRAWINGS SHALL BE PREPARED AND SIGNED & SEALED BY A FLORIDA REGISTERED SURVEYOR.

	,
	WATER FIXTURE SCHEDULE
	TYPE
	O" DOTADLE WATED METED ACCEMPLY
	2" BACKFLOW PREVENTOR ASSEMBLY
	6" DOUBLE DETECTOR CHECK VALVE ASSEMBLY
	FIRE HYDRANT ASSEMBLY
	16"X6" TAPPING SLEEVE W/ VALVE
	4" DOUBLE DETECTOR CHECK VALVE ASSEMBLY
	1" WATER METER
	1" BACKFLOW PREVENTOR ASSEMBLY
1	ONSTRUCTION DETAILS

L CONSTRUCTION DETAILS. LINES SHALL BE THE COLOR BLUE

	REUSE WATER FIXTURE SCHEDULE
NO.	TYPE
RF1	2" RE-USE WATER METER ASSEMBLY
SEE C	ONSTRUCTION DETAILS.

ALL LINES SHALL BE THE COLOR PURPLE





WORK IN RIGHTS-OF-WAYS

ALL WORK WITHIN RIGHTS-OF-WAYS SHALL BE IN STRICT ACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF THE RESPECTIVE AGENCIES.

THE CONTRACTOR SHALL COOPERATE WITH THE GOVERNING STATE AND LOCAL AGENCIES IN ALL PROCEDURES, MATERIALS AND METHODS OF CONSTRUCTION.

- ALL OFF-SITE WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: CONSTRUCTION OF DRIVEWAY CONNECTIONS TO EXISTING MUNICIPAL ROADWAYS AS SHOWN ON PLANS.
- PLACEMENT OF ABOVE OR BELOW GROUND UTILITIES AND CONNECTION TO EXISTING UTILITIES AS SHOWN ON PLANS.

SITE CLEARING AND DEMOLITION

ANY WORK WITHIN STREET OR HIGHWAY RIGHT-OF-WAY SHALL BE DONE IN ACCORDANCE WITH THE REQUIREMENTS OF THE GOVERNMENTAL AGENCIES HAVING JURISDICTION AND SHALL NOT BEGIN UNTIL THESE GOVERNING AUTHORITIES HAVE BEEN NOTIFIED AND PROPER PERMITS OBTAINED. KEEP ALL AREAS WITHIN THE CONSTRUCTION AREA SUFFICIENTLY DAMPENED TO PREVENT DUST FROM RISING DUE TO CONSTRUCTION. COMPLY WITH ALL ANTI-POLLUTION

THIS SUBCONTRACTOR SHALL SEE TO IT THAT TRUCKS LEAVING THE SITE SHALL DO SO IN SUCH A MANNER THAT MUD AND EARTH WILL NOT BE DEPOSITED ON ADJACENT STREET PAVEMENTS. ANY MUD OR EARTH DEPOSITED ON STREET PAVEMENTS SHALL BE PROMPTLY REMOVED BY THIS SUBCONTRACTOR.

ALL CLEARING SHALL BE PERFORMED IN A MANNER SUCH AS TO PREVENT ANY ALL CLEARING SHALL BE PERFORMED IN A MANNER SUCH AS TO PREVENT ANY WASH-OFF OF SOILS FROM THE SITE INTO STREAMS AND/OR STORM DRAINAGE SYSTEMS. APPROPRIATE SEDIMENTATION PONDS, DIKES, COLLARS, AND FILTER MEDIA SHALL BE EMPLOYED TO INSURE COMPLIANCE WITH THESE REQUIREMENTS. WHERE A SPECIFIC STATUTE GOVERNS THESE PROCEDURES, SUCH STATUTE SHALL BE COMPLIED WITH IN IT'S ENTIRETY.

TOPSOIL IS DEFINED AS FRIABLE CLAY LOAM SURFACE SOIL FOUND IN A DEPTH OF NOT LESS THAN 4". SATISFACTORY TOPSOIL IS REASONABLY FREE OF SUBSOIL, CLAY LUMPS, STONES, AND OTHER OBJECTS OVER 2" IN DIAMETER, AND WITHOUT WEEDS, ROOTS, AND OTHER OBJECTIONABLE MATERIAL.

STRIP TOPSOIL TO WHATEVER DEPTHS ENCOUNTERED IN A MANNER TO PREVENT INTERMINGLING WITH UNDERLYING SUBSOIL OTHER OBJECTIONABLE MATERIAL. REMOVE HEAVY GROWTHS OF GRASS FROM AREAS BEFORE STRIPPING. WHERE TREES ARE INDICATED TO BE LEFT STANDING, STOP TOPSOIL STRIPING A SUFFICIENT DISTANCE TO PREVENT DAMAGE TO MAIN ROOT SYSTEM. DISPOSE OF UNSUITABLE OR EXCESS TOPSOIL SAME AS WASTE MATERIAL, HEREIN SPECIFIED. BURNING WILL NOT BE PERMITTED ON PROJECT SITE.

ALL EXISTING STRUCTURES, UTILITIES AND OTHER OBSTACLES IN CONFLICT WITH THE PROPOSED FACILITY SHALL BE REMOVED AND DISPOSED OF IN A LEGAL MANNER. SEE OTHER UTILITY AND MISCELLANEOUS NOTES CONCERNING REMOVAL. ALLOW TESTING SERVICES TO INSPECT AND APPROVE SUBGRADE AND FILL LAYERS BEFORE FURTHER CONSTRUCTION WORK IS PERFORMED.

ATTENTION IS CALLED TO THE FACT THAT THE CONTRACTOR IS RESPONSIBLE FOR CONTACTING ALL UTILITY COMPANIES TO OBTAIN LOCATIONS OF ALL EXISTING UTILITIES OR OBSTRUCTIONS WHICH HE MAY ENCOUNTER DURING CONSTRUCTION. AFTER LOCATION OF UTILITIES BY THE APPROPRIATE UTILITY COMPANY, IT IS THE CONTRACTOR'S LIABILITY TO PROTECT ALL SUCH UTILITY LINES, INCLUDING SERVICE LINES AND APPURTENANCES, AND TO REPLACE AT HIS OWN EXPENSE ANY WHICH MAY BE DAMAGED BY THE CONTRACTOR'S EQUIPMENT OR FORCES DURING CONSTRUCTION.

TO PROTECT PERSON FROM INJURY AND TO AVOID PROPERTY DAMAGE, ADEQUATE BARRICADES, CONSTRUCTION SIGNS, TORCHES, RED LANTERNS AND GUARDS AS REQUIRED SHALL BE PLACED AND MAINTAINED DURING THE PROGRESS OF THE CONSTRUCTION WORK.

ADEQUATE PROVISION SHALL BE MADE FOR THE FLOW OF SEWERS, DRAINS, AND WATER COURSES ENCOUNTERED DURING CONSTRUCTION, AND THE STRUCTURES WHICH MAY HAVE BEEN DISTURBED SHALL BE SATISFACTORILY RESTORED BY THE CONTRACTOR.

EXCAVATING, FILLING AND GRADING

ALL ON AND OFF-SITE WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: ALL ON AND OFF-SITE PREPARATION WORK FOR EXCAVATION, PIPE BED PREPARATION AND BACKFILL FOR UNDERGROUND UTILITIES.

COMPACTION OF BACKFILL REMOVAL OF ALL EXCESS OR UNUSABLE MATERIAL.

APPROVAL REQUIRED: ALL FILL MATERIAL SHALL BE SUBJECT TO APPROVAL OF THE GEO-TECHNICAL ENGINEER. ALL ON-SITE FILL MATERIAL SHALL BE SOIL-ROCK MIXTURE WHICH IS FREE FROM

ORGANIC MATTER (LESS THAN 3% BY IGNITION), AND OTHER DELETERIOUS SUBSTANCE. IT SHALL CONTAIN NO ROCKS OR LUMPS OVER SIX (6) INCHES IN GREATEST DIMENSION AND NOT MORE THAN 15% OF THE ROCKS OR LUMPS BY DRY WEIGHT, SHALL BE LARGER THAN 2 AND 1/2 INCHES IN GREATEST DIMENSION.

ALL IMPORTED FILL MATERIAL SHALL MEET THE REQUIREMENTS OF ON-SITE FILL MATERIAL AND SHALL IN ADDITION, BE PREDOMINANTLY GRANULAR WITH A MAXIMUM PARTICLE SIZE OF TWO (2) INCHES AND A PLASTICITY INDEX OF 12 OR LESS. ALL ON-SITE FILL MATERIAL USED FOR TRENCH AND STRUCTURAL BACKFILL SHALL MEET THE REQUIREMENTS OF ARTICLE ABOVE.

ALL IMPORTED COHESIONLESS MATERIAL USED FOR TRENCH AND STRUCTURAL BACKFILL SHALL BE FREE FROM ORGANIC SUBSTANCE (LESS THAN 3% BY IGNITION) AND OTHER DELETERIOUS MATTER, SHALL BE SUBJECT TO THE APPROVAL OF THE ENGINEER. PRIOR TO ALL WORK OF THIS SECTION, CONTRACTOR IS TO BECOME THOROUGHLY FAMILIAR WITH THE SITE, THE SITE CONDITIONS, AND ALL PORTIONS OF THE WORK, FALLING WITHIN THIS SECTION.

DO NOT ALLOW OR CAUSE ANY OF THE WORK PERFORMED OR INSTALLED TO BE COVERED UP OR ENCLOSED BY WORK OF THIS SECTION PRIOR TO ALL REQUIRED INSPECTIONS, TESTS AND APPROVALS.

AFTER THE WORK HAS BEEN COMPLETELY TESTED, INSPECTED AND APPROVED, MAKE ALL REPAIRS AND REPLACEMENTS NECESSARY TO RESTORE THE WORK TO THE CONDITION IN WHICH IT WAS FOUND AT THE TIME OF UNCOVERING, ALL AT NO ADDITIONAL COST TO

FOR SETTING AND ESTABLISHING FINISH ELEVATIONS AND LINES, SECURE THE SERVICES OF A REGISTERED CIVIL ENGINEER OR LAND SURVEYOR ACCEPTABLE TO THE OWNER, CAREFULLY PRESERVE ALL DATA AND ALL MONUMENTS SET BY THE CIVIL ENGINEER OR LAND SURVEYOR, AND IF DISPLACED OR LOST, IMMEDIATELY REPLACE TO THE APPROVAL OF THE OWNER AND AT NO ADDITIONAL COST TO THE OWNER.

PROVIDE ALL LABOR, MATERIALS, EQUIPMENT, SERVICES, ETC. NECESSARY AND INCIDENTAL TO THE COMPLETION OF ALL EARTHWORK AS SHOWN ON THE DRAWINGS AND SPECIFICATIONS. ALL OFF-SITE WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: THIS WORK CONSISTS OF GRADING IN ORDER TO ACHIEVE FINISHED ELEVATIONS SHOWN ON THE CONSTRUCTION PLANS.

ALL GRADED SURFACES SHALL BE SMOOTH AND UNIFORM, WITHOUT ABRUPT CHANGES IN SLOPE OR GRADE. AREAS TO BE COVERED WITH PAVING SHALL BE FINE GRADED TO THE REQUIRED ELEVATIONS AND SLOPES. FINISHED SURFACES IN ALL OTHER AREAS MAY VARY UP TO 0.1 FEET FROM THE REQUIRED ELEVATIONS.

PERFORM EXCAVATION WORK IN COMPLIANCE WITH APPLICABLE REQUIREMENTS OF GOVERNING AUTHORITIES HAVING JURISDICTION. ALL MATLERIALS AND CONSTRUCTION METHODS SHALL BE IN ACCORDANCE WITH SECTION 120 OF THE STANDARD SPECIFICATIONS FOR ROADS AND BRIDGES, STATE OF FLORIDA, DEPARTMENT OF TRANSPORTATION, LATEST EDITION.

EMPLOY, AT CONTRACTOR'S EXPENSE, DESIGN LABORATORY TO PERFORM SOIL TESTING AND INSPECTION SERVICE FOR QUALITY CONTROL TESTING DURING EARTHWORK OPERATIONS. SUBMIT FOLLOWING REPORTS DIRECTLY TO ENGINEER AND COPIES TO CITY ENGINEERING DEPARTMENT FROM THE TESTING SERVICES, WITH COPY TO THE CONTRACTOR

TEST REPORTS ON BORROW MATERIAL. FIELD DENSITY TEST REPORTS.

CONTRACTOR.

ONE OPTIMUM MOISTURE-MAXIMUM DENSITY CURVE FOR EACH TYPE OF SOIL ENCOUNTERED.

WHERE REQUIRED, THE SITE SHALL BE EXCAVATED TO THE GRADES COURSE, EXCAVATED MATERIAL THAT IS SUITABLE SHALL BE USED IN THE FILL SECTIONS OF THE SITE. NO SUITABLE MATERIAL SHALL BE REMOVED FROM THE SITE. ANY EXCESS SUITABLE MATERIAL SHALL BE PLACED AT THE DIRECTION OF THE ENGINEER. EXCAVATION FOR MANHOLES, CATCH BASINS, AND OTHER ACCESSORIES SHALL BE SUFFICIENT TO LEAVE AT LEAST 12 INCHES IN THE CLEAR BETWEEN THEIR OUTER SURFACES AND THE EMBANKMENT OF TIMBER THAT MAY BE USED TO PROTECT THEM.



THIS WORK CONSISTS OF SODDING AREAS CLEARED DURING CONSTRUCTION AND NOT PAVED, OR AS OTHERWISE SHOWN ON THE CONSTRUCTION PLANS. ALL MATERIAL AND CONSTRUCTION METHODS SHALL BE IN ACCORDANCE WITH SECTION 570, 571, 573, OR 575 OF THE FLORIDA DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS, LATEST REVISION LATEST REVISION. USE ST. AUGUSTINE GRASS (FLORATAM) SOD. THE SOD SHALL BE LIVE, FRESH AND UNINJURED AT THE TIME OF PLANTING AND SHALL HAVE A THICK MAT OF ROOTS WITH ENOUGH ADHERING SOIL TO ASSURE GROWTH. APPLY SOD WITHIN 72 HOURS OF CUTTING OR STACKING TO KEEP MOIST. PREPARE THE GROUND BY LOOSENING THE SOIL. PLACE SOD ON THE PREPARED SOIL WITH EDGES IN CLOSE CONTACT. STAGGER THE SOD PIECES SO AS TO AVOID A CONTINUOUS DOWNHILL SEAM. TAMP THE OUTER EDGES OF THE SODDED AREA TO PRODUCE A SMOOTH CONTOUR. KEEP SOD CONTINUOUSLY MOIST TO A DEPTH BELOW THE ROOT ZONE FOR THREE WEEKS AFTER PLACEMENT.

SODDING DETAIL NOT TO SCALE



PROFILE VIEW NOTE: 1. GRAVEL CONSTRUCTION ENTRANCE SHALL BE 24' WIDE AND 50' LONG.

2. CONSTRUCTION ENTRANCE SHALL BE 6" OF #57 STONE OVERLAYING FILTER FABRIC.

3. ALGEBRAIC DIFFERENCE OF SLOPE FROM EXISTING ROAD AND SLOPE FROM EDGE OF PAVEMENT TO GRADE BREAK SHALL NOT EXCEED

5. WHEN NECESSARY, WHEELS SHALL BE CLEANED PRIOR TO ENTRANCE ONTO PUBLIC RIGHT-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE THAT DRAINS INTO AN APPROVED SEDIMENT TRAP OR BASIN.

CONSTRUCTION ENTRANCE DETAIL

NOT TO SCALE

CONSTRUCTION ENTRANCE SHALL BE MAINTAINED IN A CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHT-OF-WAYS.

REVISIONS: ND. DESCRIPTION DRAWN CHECKED DATE 1 _ PHASE: DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22 2211 THOMAS DRIVE, SUITE 100 PANAMA CITY BEACH, FI PHONE: (850) 236-9832 PANAMA CITY BEACH, FL ARCHITECTS COMMISSION NUMBER 21804 CONSULTANTS: M^CNEIL----17800 Panama City Beach Parkway Panama City Beach, Florida 32413 -CARROLL Phone: 850-234-1730 Fax: 850-234-1731 ENGINEERING, INC. Professional Engineering Consultants STATE OF FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER: 7288 PROJECT:

PANAMA CITY BEACH **REPLACEMENT FIRE STATION # 31**

PANAMA CITY BEACH, FLORIDA SHEET TITLE:

CONSTRUCTION DETAILS



SITE DRAINAGE

ALL OFF-SITE AND ON-SITE WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: EXCAVATION, BEDDING, FILTER MATERIAL AND BACKFILL FOR ALL STORM SEWER, SUBSURFACE DRAINS AND DRAINAGE STRUCTURES. COMPLETE INSTALLATION OF ALL STORM SEWER, SUBSURFACE DRAINS, CATCH BASINS, JUNCTION BOXES, MANHOLES, ETC., INCLUDING ALL RELATED FITTINGS, JOINTS COVERS, GRATES, FRAMES, RUNGS, ETC.

ANY WORK WITHIN STREET OR HIGHWAY RIGHT-OF-WAY SHALL BE DONE IN ACCORDANCE WITH THE REQUIREMENTS OF THE GOVERNMENTAL AGENCIES HAVING JURISDICTION AND SHALL NOT BEGIN UNTIL ALL OF THESE GOVERNING AUTHORITIES HAVE BEEN NOTIFIED. POLYVINYL CHLORIDE (PVC), FOR PIPE UP TO AND INCLUDING TEN INCHES (10") IN DIAMETER, SHALL CONFORM TO ASTM D3034 SDR 35 WITH ELASTOMERIC GASKET JOINTS

CONFORMING TO ASTM D3212. REINFORCED CONCRETE PIPE, FOR PIPE TWELVE INCHES (12") IN DIAMETER AND UP, SHALL CONFORM TO ASTM C-76, CLASS IV OR AASHTO M-170 WITH BELL AND SPIGOT OR TONGUE AND GROOVE COMPRESSION JOINT CONFORMING TO ASTM C-443.

MANHOLES, CATCH BASINS, ETC. SHALL BE SIZE AND TYPE INDICATED ON THE DRAWINGS AND SHALL BE CONSTRUCTED OF THE FOLLOWING: REINFORCED PRECAST CONCRETE MANHOLE SECTIONS INCLUDING CONCENTRIC OR ECCENTRIC CONES AND GRADE RINGS SHALL BE 4000 PSI CONCRETE AND CONFORM TO ASTM C478 OR AASHTO M-199. SECTIONS SHALL BE COMPLETE WITH $3/4"\ \mbox{ROUND}\ \mbox{CAST}\ \mbox{IN}\ \mbox{PLACE}\ \mbox{WROUGHT}\ \mbox{IRON}\ \mbox{STEPS}.$

BRICK SHALL BE SOUND, HARD BURNED THROUGHOUT AND OF UNIFORM SIZE AND QUALITY AND SHALL BE IN ACCORDANCE WITH ASTM C-32, GRADE MS OR MM. CONCRETE MASONRY SHALL BE SOLID PRECAST SEGMENTAL CONCRETE MASONRY UNITS CONFORMING TO ASTM C-139.

IRON CASTINGS SHALL CONFORM TO ASTM A-48, CLASS 30. BEARING SURFACES BETWEEN CAST IRON FRAMES, COVERS AND GRATES SHALL BE MACHINED, FITTED TOGETHER AND MATCH MARKED TO PREVENT ROCKING. SYSTEM IDENTIFYING LETTER 2" HIGH SHALL BE STAMPED OR CAST INTO ALL COVERS SO THAT THE MAY BE PLAINLY VISIBLE.

CASTINGS SHALL BE MANUFACTURED BY EAST JORDAN IRON WORKS, INC. NEENAH FOUNDRY COMPANY, VULCAN FOUNDRY COMPANY OR EQUAL. MANHOLE STEPS FOR BRICK OR CONCRETE MASONRY STRUCTURES SHALL BE CAST IRON ASPHALT COATED, NEENAH FOUNDRY COMPANY "R-1980-E" OR EQUAL.

CONCRETE AND MASONRY MATERIALS FOR CONSTRUCTION OF STORM DRAINAGE STRUCTURES SHALL CONSIST OF THE FOLLOWING: PORTLAND CEMENT SHALL BE STANDARD BRAND OF PORTLAND CEMENT CONFORMING TO ASTM C-150, TYPE I OR II.

FINE AND COARSE AGGREGATES FOR CONCRETE SHALL BE PER ASTM C-33. AGGREGATES SHALL BE WELL GRADED FROM FINE TO COARSE WITHIN LIMITS SPECIFIED IN ASTM C-33. MAXIMUM SIZE OF COARSE AGGREGATE SHALL BE 3/4". AGGREGATE FOR CEMENT MORTAR SHALL BE CLEAN, SHARP SAND CONFORMING TO ASTM C-144. GRADE SAND FROM COARSE TO FINE WITH 100% PASSING NO. 8 SIEVE, AND NOT OVER 10 TO 30% PASSING NO. 50 SIEVE. HYDRATED LIME SHALL COMPLY WITH ASTM C-207, TYPE S. WATER SHALL BE CLEAN AND FREE FROM DELETERIOUS MATERIALS. ALL MATERIAL USED FOR CONCRETE AND THE DESIGN OF ALL CONCRETE MIXES SHAL

CONFORM WITH THE RECOMMENDATIONS OF THE AMERICAN CONCRETE INSTITUTE (ACI 211.1–81). ALL CONCRETE, UNLESS NOTED OTHERWISE, SHALL DEVELOP A 28-DAY COMPRESSIVE STRENGTH OF 3000 PSI.

JOINT SEALANT SHALL BE HOT LAID BITUMINOUS SEALER. RIP RAP SHALL BE SOUND, TOUGH DURABLE ROCK OR BROKEN CONCRETE AS APPROVED BY THE GEOTECHNICAL ENGINEER. RIP RAP SHALL BE AT LEAST EIGHT INCH (8") IN ONE DIMENSION AN SHALL HAVE A VOLUME OF NOT LESS THAN J1/3 CUBIC FOOT. SMALLER PIECES PERMITTED FOR FILLING VOIDS

REINFORCING STEEL FOR CONCRETE SHALL BE INTERMEDIATE GRADE NEW BILLET STEEL CONFORMING TO ASTM A-615, GRADE 40. WELDED WIRE MESH SHALL CONFORM TO ASTM DESIGNATION A185 FOR SMOOTH WIRE AND ASTM A497 FOR DEFORMED WIRE.

FORMS FOR FOUNDATIONS AND OTHER CONCRETE WORK SHALL BE WOOD. FORMS SHALL BE OF SUFFICIENT STRENGTH TO PREVENT DEFORMATION UNDER LOAD AND TIGHT ENOUGH TO PREVENT LEAKAGE. FOUNDATIONS MAY BE POURED AGAINST EARTH WHERE CONDITIONS PERMIT.

ALL REINFORCEMENT SHALL BE FABRICATED AND PLACED IN ACCORDANCE WITH ACI 318-77. WELDED WIRE MESH SHALL BE LAPPED 6-INCHES AT ALL EDGES. THE MIXING, PLACING, CURING AND FINISHING OF CONCRETE SHALL COMPLY WITH ACI 304 AND ACI 318. ALL EXPOSED SURFACES SHALL BE GIVEN A HARD STEEL TROWEL FINISH WITH NO TROWEL MARKS REMAINING. NO CEMENT SHALL BE DUSTED ON THE SURFACE. ALL CONCRETE SHALL BE CURED BY COATING WITH A CLEAR CURING NO CEMENT CONFORMING TO ASTM C-304, OR BY KEEPING IT WET FOR AT LEAST SIX DAYS AFTER POUNTED AC MEEPER FORMS ARE STRIPPED, ALL EXPOSED CONCRETE SURFACES SHALL BE POINTED AS NEEDED AND RUBBED TO A UNIFORM FINISH.

CONCRETE, UNLESS OTHERWISE NOTED, SHALL HAVE COMPRESSIVE STRENGTH AFTER 28 DAYS OF 3000 PSI MINIMUM. MIX SHALL BE SO PROPORTIONED TO PROVIDE A MINIMUM OF 517 POUNDS OF CEMENT PER CUBIC YARD. CONCRETE FILL BELOW GRADE FOR PIPE CRADLES ETC. MAY BE 2500 PSI AT 28 DAYS. CONCRETE, WHERE EXPOSED TO THE WEATHER, SHALL BE AIR ENTRAINED. AIR ENTRAINMENT SHALL BE ACCOMPLISHED BY THE USE OF ADDITIVES CONFORMING TO ASTM C-260. AIR CONTENT SHALL BE 6% + 1%. ADDITIVE SHALL BE USED STRICTLY IN ACCORDANCE WITH

MANUFACTURER'S PRINTED DIRECTIONS. READY-MIX CONCRETE SHALL CONFORM TO THE REQUIREMENTS OF ASTM C-94.

CEMENT MORTAR SHALL BE AS SPECIFIED HEREINAFTER. USE METHODS OF MIXING MORTAR MATERIALS CAN BE CONTROLLED AND ACCURATELY MAINTAINED DURING WORK PROGRESS. MORTAR SHALL NOT BE MIXED IN GREATER QUANTITIES THAN SATISFACTORY WORKABILITY. RETEMPERING OF MORTAR IS NOT PERMITTED.

MORTAR FOR LAYING BRICK OR CONCRETE MASONRY UNITS SHALL CONFORM TO ASTM C-270, TYPE M, AVERAGE COMPRESSIVE STRENGTH 2500 AT 28 DAYS. MORTAR MIX SHALL BE PROPORTIONED BY VOLUME. MORTAR FOR PARGING SHALL CONSISTS OF ONE PART PORTLAND CEMENT AND TWO PARTS SAND. MORTAR FOR GROUTING OF RIP RAP SHALL CONSIST OF ONE PART PORTLAND CEMENT AND THREE PARTS SAND.

STORM WATER SEWERS: STORM SEWERS SHALL BE INSTALLED IN LOCATIONS AND OF SIZES INDICATED ON DRAWING.

LAY PIPE, EMBED IT FIRMLY TO REQUIRED LINE AND GRADE WITH BELLS OF GROOVE END UP-GRADE. FIT ENDS TOGETHER, EXCAVATE BELL HOLES SO THAT SEWER WILL HAVE SMOOTH AND UNIFORM INVERT THROUGHOUT ITS LENGTH. CORRUGATED METAL PIPE SHALL BE PLACED ON A FLAT BOTTOM TRENCH WITH HAUNCHES SOLIDLY SUPPORTED BY TAMPED BEDDING MATERIAL.

WHERE GROUND IS FOUND UNSUITABLE TO SUPPORT PIPE, PROVIDE CONCRETE CRADLES. DEPOSIT CONCRETE FULL WIDTH OF TRENCH 4" DEEP MINIMUM TO BOTTOM OF PIPE, REINFORCE CONTINUOUSLY WITH TWO (2) NO. 4 REINFORCING BARS. BEFORE CONCRETE IS SET, EMBED PIPE EVENLY, DEPOSIT REMAINDER OF CONCRETE TO CENTERLINE OF PIPE AND TAMP IN A MANNER TO AVOID DISTURBING PIPE.

WHERE STORM SEWER CROSSES A SANITARY SEWER OR WATER LINE AND THE STORM SEWER IS WITHIN ONE AND A HALF (1-1/2) FEET OF THE SANITARY SEWER PIPE OR WATER LINE, THE INTERSECTION OF THE PIPE OR LINE SHALL BE EMBEDDED IN CONCRETE FOR A DISTANCE OF FIVE FEET (5') EACH WAY FROM CENTERLINE OF INTERSECTION. PROVIDE POURED CONCRETE FOUNDATIONS FOR DRAINAGE STRUCTURES.

PRECAST CONCRETE BASE MAY BE USED WHERE APPROVED BY THE GEO-TECHNICAL ENGINEER, PRECAST CONCRETE BASE MUST BE SET LEVEL ON SAND CUSHION OF NOT LESS THAN 2" NOR MORE THAN 4".

MANHOLES AND CATCH BASINS SHALL BE CONSTRUCTED OF BRICK, CONCRETE MASONRY OR PRECAST CONCRETE WITH CAST IRON FRAMES, COVERS AND MANHOLE STEPS, AS INDICATED ON DRAWINGS AND SPECIFIED HEREIN. RIP RAP SHALL BE LAID OVER FILTER FABRIC FROM THE BOTTOM UPWARD, STONES SHALL BE

LAID BY HAND WITH EIGHT (8") INCH MINIMUM DIMENSION PERPENDICULAR TO GRADE WITH WELL BROKEN JOINTS, COMPACTED AS IT GOES, TRUE TO LINE. ALL JOINTS SHALL BE FILLED WITH CEMENT MORTAR SURFACE OF STONE TO BE EXPOSED. CLEAN JOINTS WITH SIRE

BEFORE BACKFILLING AROUND DRAINAGE STRUCTURES, ALL FORMS, TRASH AND DEBRIS SHALL BE REMOVED AND CLEARED AWAY. SELECTED EXCAVATED MATERIAL SHALL BE PLACED SYMMETRICALLY ON ALL SIDES IN EIGHT INCH (8") MAXIMUM LAYERS; EACH LAYER SHALL BE MOISTENED AND COMPACTED WITH MECHANICAL OR HAND TAMPERS. INFILTRATION OF THE STORM DRAINAGE SYSTEM SHALL NOT EXCEED 0.60 GALLONS PER INCH OF INTERNAL PIPE DIAMETER PER ONE HUNDRED FEET (100') OF PIPELINE PER HOUR WITH A MAXIMUM HYDROSTATIC HEAD AT THE CENTER LINE OF THE PIPE OF TWENTY FIVE

FEET (25'), OR AS REQUIRED BY GOVERNING CODE AUTHORITIES. CATCH BASIN FRAMES AND GRATINGS: ASPHALT COATED GRAY CAST IRON, ANSI/ASTM A 48, CLASS 30 B.

IT IS THE CONTRACTOR'S RESPONSIBILITY TO SUPPLY ALL MATERIALS NECESSARY TO COMPLETE DRAINAGE.



COST OF FILTER FABRIC JACKET TO BE INCLUDED IN COST OF PIPE CULVERTS. FOR ALL PIPE TYPES - CONCRETE PIPE SHOWN

FILTER FABRIC JACKET DETAIL NOT TO SCALE



1. THESE INLETS ARE SUITABLE FOR BICYCLE AND PEDESTRIAN AREAS AND ARE TO BE USED IN DITCHES, MEDIANS AND OTHER AREAS SUBJECT TO INFREQUENT TRAFFIC LOADINGS BUT ARE NOT TO BE PLACED IN AREAS SUBJECT TO ANY HEAVY WHEEL LOADS. 2. INLETS SUBJECT TO MINIMAL DEBRIS SHOULD BE CONSTRUCTED WITHOUT SLOTS. WHERE DEBRIS IS A PROBLEM INLETS SHOULD BE CONSTRUCTED WITH SLOTS. SLOTTED INLETS LOCATED WITHIN ROADWAY CLEAR ZONES AND IN AREAS ACCESSIBLE TO PEDESTRIANS SHALL HAVE TRAVERSABLE SLOTS. THE TRAVERSABLE SLOT MODIFICATION IS NOT ADAPTABLE TO INLET TYPE H. SLOTS MAY BE CONSTRUCTED AT EITHER OR BOTH ENDS AS SHOWN ON PLANS.

3. STEEL GRATES ARE TO BE USED ON ALL INLETS WHERE BICYCLE TRAFFIC IS ANTICIPATED. STEEL GRATES ARE TO BE USED ON ALL INLETS WITH TRAVERSABLE SLOTS. EITHER CAST IRON OR STEEL GRATES MAY BE USED ON INLETS WITHOUT SLOTS WHERE BICYCLE TRAFFIC IS NOT ANTICIPATED. EITHER CAST IRON OR STEEL GRATES MAY BE USED ON ALL INLETS WITH NON-TRAVERSABLE SLOTS. SUBJECT TO THE SELECTION DESCRIBED ABOVE, WHEN ALTERNATE G GRATE IS SPECIFIED IN THE PLANS, EITHER THE STEEL GRATE, HOT DIPPED GALVANIZED AFTER FABRICATION, OR THE CAST IRON GRATE MAY BE USED, UNLESS THE PLANS STIPULATE THE PARTICULAR TYPE. 4. RECOMMENDED MAXIMUM PIPE SIZES SHOWN ARE FOR CONCRETE PIPE. PIPE SIZES LARGER THAN THOSE RECOMMENDED MUST BE CHECKED FOR FIT.

5. ALL EXPOSED CORNERS AND EDGES OF CONCRETE ARE TO CHAMFERED 3/4". 6. PAVEMENT TO BE USED ON INLETS WITHOUT SLOTS AND INLETS WITH NON-TRAVERSABLE SLOTS ONLY WHEN CALLED FOR IN THE PLANS; BUT REQUIRED ON ALL TRAVERSABLE SLOT INLETS. COST TO BE INCLUDED IN CONTRACT UNIT PRICE FOR INLETS. QUANTITIES SHOWN ARE FOR INFORMATION

7. TRAVERSABLE SLOTS CONSTRUCTED IN EXISTING INLETS SHALL BE PAID FOR AS INLETS PARTIAL, AND SHALL INCLUDE THE COST FOR SLOT OPENINGS, PAVING AND ANY REQUIRED REPLACEMENT 8. SODDING TO BE USED ON ALL INLETS NOT LOCATED IN PAVED AREAS AND PAID FOR UNDER CONTRACT UNIT PRICE FOR SODDING, SY.

9. FOR SUPPLEMENTARY DETAILS SEE INDEX NO. 201.

FDOT TYPE "C" INLET DETAIL



TRENCH DRAIN DETAIL



NOTE: ALL PIPE ADS N-12 OR EQUAL

DOWNSPOUT DETAIL NOT TO SCALE





UNDISTURBED EARTH — (SEE NOTE 3)

- 1. PIPE BEDDING: SELECT COMMON FILL COMPACTED TO 95% OF THE MAXIMUM DENSITY AS PER AASHTO T-180.
- TRENCH BACKFILL: COMMON FILL COMPACTED TO 95% (6" LIFTS) OF THE MAXIMUM DENSITY AS PER AASHTO T-180. PIPE BEDDING UTILIZING SELECT COMMON FILL OR BEDDING ROCK IN ACCORDANCE WITH TYPE A BEDDING AND TRENCHING DETAIL MAY BE REQUIRED AS DIRECTED BY THE CITY.
- (*): 15" MAX. FOR PIPE DIAMETER LESS THAN 24", AND 24" MAX. FOR PIPE DIAMETER 24" AND LARGER.
- 5. WATER SHALL NOT BE PERMITTED IN THE TRENCH DURING CONSTRUCTION. 6. ALL PIPE TO BE INSTALLED WITH BELL FACING UPSTREAM TO THE DIRECTION OF THE FLOW
- 7. REFER TO SECTION 32.5 OF THE MANUAL FOR SHEETING AND BRACING IN EXCAVATIONS.
- 8. FINAL RESTORATION IN IMPROVED AREAS SHALL BE IN COMPLIANCE WITH ALL APPLICABLE REGULATIONS OF GOVERNING AGENCIES. SURFACE RESTORATION WITHIN CITY RIGHT-OF-WAY SHALL COMPLY WITH REQUIREMENTS OF RIGHT-OF-WAY UTILIZATION REGULATIONS AND ROAD CONSTRUCTION SPECIFICATIONS.

TRENCHES AND EXCAVATION PITS SHALL NOT BE BACKFILLED UNTIL ALL TESTS AND INSPECTIONS COVERING THE INSTALLATION OF THE STORM DRAINAGE SYSTEM HAVE BEEN PERFORMED AND APPROVED. ALL TIMBER SHEETING BELOW A PLANE ONE FOOT ABOVE TOP OF PIPE SHALL REMAIN IN PLACE IN ORDER NOT TO DISTURB PIPE GRADING. BEFORE BACKFILLING, REMOVE ALL OTHER SHEETING, BRACING AND SHORING. PIPE TO BE CAREFULLY COMPACTED TO NINETY FIVE PERCENT (95%) OF MAXIMUM DENSITY AS PER ASTM D-1557 UNTIL ONE FOOT (1') OF COVER EXISTS OVER PIPE.

IN STREETS, DRIVES, PARKING LOTS AND OTHER AREAS TO HAVE OR HAVING IMPROVED HARD SURFACES, BACKFILL SHALL BE MATERIAL SPECIFIED AS FOR PIPE BEDDING AND SHALL BE DEPOSITED IN SIX INCH (6"O LOOSE LAYERS AS OPTIMUM MOISTURE CONTENT (+ 2%) AND COMPACTED TO 95% OF MAXIMUM DENSITY AS DETERMINED BY ASTM D-1557 WHERE SERVICES OR UTILITY LINES CROSS STREET, BEDDING SHALL BE CARRIED TO FIVE FEET (5') BEHIND THE CURB, OR WHERE SIDEWALKS EXISTS, TO THE SIDE OF SIDEWALK FARTHEST AWAY FROM THE STREET.

MATERIAL USED FOR BEDDING SHALL MEET CURRENT RECOMMENDATIONS OF THE PIPE MANUFACTURER AND SHALL BE APPROVED BY THE ENGINEER. THE SPECIFIED COHESIONLESS MATERIAL SHALL BE PLACED IN THE TRENCH SIMULTANEOUSLY ON EACH SIDE OF THE PIPE TO THE FULL WIDTH OF THE TRENCH. MATERIAL WILL BE PLACED IN A MAXIMUM LIFT OF SIX (6) INCHES (COMPACTED DEPTH) TO A MINIMUM DEPTH OF ONE (1) FOOT ABOVE THE CROWN OF THE PIPE.

PERFORM ALL TRENCHING REQUIRED FOR THE INSTALLATION OF UTILITIES AS SHOWN ON PLANS AND SPECIFIED HEREIN. MAKE ALL TRENCHES OPEN VERTICAL CONSTRUCTION WITH SUFFICIENT WIDTH TO PROVIDE FREE WORKING SPACE AT BOTH SIDE OF THE TRENCH AND AROUND THE INSTALLED ITEMS AS REQUIRED FOR CAULKING, JOINING, BACKFILLING AND COMPACTING. PROPERLY SUPPORT ALL TRENCHES IN STRICT ACCORDANCE WITH ALL PERTINENT RULES AND REGULATIONS.

GRADE THE TRENCH BOTTOM TO PROVIDE A SMOOTH, FIRM AND STABLE FOUNDATION FREE OF ROCK POINTS THROUGHOUT THE LENGTH OF THE PIPE. IN AREAS WHERE SOFT, UNSTABLE MATERIALS ARE ENCOUNTERED AT THE SURFACE UPON WHICH COHESIONLESS MATERIAL IS TO BE PLACED, REMOVE THE UNSTABLE MATERIAL AND REPLACE IT WITH MATERIAL APPROVED BY THE ENGINEER, MAKE SUFFICIENT DEPTH TO DEVELOP A FIRM FOUNDATION FOR THE ITEM BEING INSTALLED.

AT EACH JOINT IN PIPE, RECESS THE BOTTOM OF THE TRENCH AS REQUIRED INTO THE FIRM FOUNDATION IN SUCH A MANNER AS TO RELIEVE THE BELL OF THE PIPE OF ALL LOAD AND TO ENSURE CONTINUOUS BEARING OF THE PIPE BARREL ON THE FIRM FOUNDATION. ACCURATELY SHAPE ALL PIPE SUBGRADE AND FIT THE BOTTOM OF THE TRENCH TO THE PIPE SHAPE; USE A DRAG TEMPLATE SHAPED TO CONFORM TO THE OUTER SURFACE OF THE PIPE IF OTHER METHODS DO NOT PRODUCE SATISFACTORY RESULTS. SHAPING WILL CONFORM TO THE OUTSIDE OF THE PIPE FOR A DEPTH OF NOT LESS THAN 10% OF THE TOTAL HEIGHT (OUTSIDE DIMENSION) OF THE PIPE.

PIPE TRENCHES SHALL BE EXCAVATED TO A DEPTH THAT WILL INSURE A MINIMUM OF THIRTY INCHES OF COVER LESS OTHERWISE SHOWN ON THE DRAWINGS OR DIRECTED.

BACKFILL OF EARTH AROUND MANHOLES SHALL BE FILLED WITH THOROUGHLY COMPACTED SAND OR GRAVEL AT THE EXPENSE OF THE CONTRACTOR. TRENCHES SHALL BE BACKFILLED WITH EXCAVATED MATERIALS, FREE FROM LARGE CLODS OR STONES. BACKFILL SHALL BE DEPOSITED IN LAYERS NOT TO EXCEED 6-INCHES (6") IN THICKNESS, MOISTENED, AND COMPACTED TO DENSITY EQUAL TO OR GREATER THAN 95% OF THE MAXIMUM DENSITY OF AASHTO STANDARD METHOD T-99, TO A MINIMUM DEPTH OF 12-INCHES OVER THE PIPE. THE REMAINDER OF THE BACKFILL SHALL BE PLACED IN 8-INCH LAYERS COMPACTED TO 95% MAXIMUM DENSITY UNLESS THE BACKFILL IS BENEATH PAVED OR BUILDING AREAS IN WHICH CASE IT SHALL BE COMPACTED TO 95% A MODIFIED PROCTOR.

EXCAVATIONS FOR PIPE LAYING OPERATIONS SHALL BE CONSTRUCTED IN A MANNER TO CAUSE THE LEAST INTERRUPTION TO TRAFFIC. WHEN TRAFFIC MUST CROSS OPEN TRENCHES THE CONTRACTOR SHALL PROVIDE SUITABLE BRIDGES.

TYPE B BEDDING AND TRENCHING DETAIL NOT TO SCALE

5% OF A MODIFIED PROCTOR.



CONSTRUCTION DETAILS

BACKFILL, UNLESS OTHERWISE NOTED, SHALL BE COARSE SAND, FINE GRAVEL OR EARTH HAVING A LOW PLASTICITY INDEX, FREE OF ROCKS, DEBRIS AND OTHER FOREIGN MATERIALS AND DEFINED AS ALL PASSING THROUGH A 3/8" SIEVE AND NOT MORE THAN TEN PERCENT (10%) BY VOLUME PASSING THROUGH A 200 MESH SIEVE. UTILITY PIPING AND FITTINGS SHALL BE SIZE AND TYPE INDICATED ON THE DRAWINGS AND SHALL CONFORM TO THE FOLLOWING: MANHOLES STRUCTURES SHALL BE SIZE AND TYPE INDICATED ON THE DRAWINGS AND SHALL BE CONSTRUCTED OF THE FOLLOWING:

LEAKAGE TESTS FOR GRAVITY SEWER

FOR PIPE SIZE GREATER THAN 30IN DIA.

25.852L 4 30.768L 5

1. MUST IDENTIFY THE RESPONSIBLE SURVEYOR AND MAPPER.

SHALL STATE THE TYPE OF SURVEY IT DEPICTS AND THE THE SURVEY.

MINIMUM TECHNICAL STANDARDS CHECKLIST FOR UTILITY AS-BUILTS

3. MUST BEAR THE NAME, CERTIFICATE OF AUTHORIZATION NUMBER, AND STREET AND MAILING ADDRESS OF THE BUSINESS ENTITY ISSUING THE AS-BUILT SURVEY, ALONG WITH THE NAME AND LICENSE NUMBER OF THE SURVEYOR IN RESPONSIBLE CHARGE.

4. MUST REFLECT A SURVEY DATE, WHICH IS THE DATE OF ACQUISITION. WHEN THE GRAPHICS OF THE AS-BUILT SURVEY ARE REVISED, BUT THE SURVEY DATE STAYS THE SAME, THE AS-BUILT SURVEY MUST LIST DATES FOR ALL REVISIONS.

6. A DESIGNATED "NORTH ARROW" AND EITHER A STATED SCALE OR GRAPHIC SCALE SHALL BE

7. APPROPRIATE LINE TYPES, LINE WEIGHTS, AND LINE WIDTHS SHALL BE USED ON THE AS-BUILT DRAWING TO DIFFERENTIATE EXISTING FROM PROPOSED AND WATER FROM SEWER, RECLAIM, AND STORM. ALL PHYSICAL ITEMS (I.E. PIPES, VALVES, ETC.), SURVEYED BOUNDARIES, AND EASEMENTS SHOULD BE CLEARLY MARKED, AND DIMENSIONED, AND IDENTIFIED BY SIZE AND MATERIAL.

8. ALL UTILITIES IN THE PUBLIC RIGHT OF WAY AND WITHIN EASEMENTS OR TO THE END OF

9. ALL PROPOSED UTILITY/INGRESS/EGRESS EASEMENTS MUST BE SHOWN ON THE DRAWING AND MUST HAVE THE ASSOCIATED LEGAL DESCRIPTION WRITTEN.

10. EDGE OF PAVEMENT, ROADS (ASPHALT SHADED), CURBS, DRIVEWAY CONNECTIONS, BUILDINGS, PARKING LOTS, RIGHT-OF-WAY, AND STREET NAMES MUST BE SHOWN IN ALL APPLICATIONS. ALL ITEMS MENTIONED ABOVE MUST BE FIELD LOCATED.

11. IF A LIFT STATION IS TO BE DEDICATED TO THE CITY THE PLAN MUST SHOW A DETAIL SCALED AT 1"=10' SHOWING ALL IMPROVEMENTS INCLUDING: WATER AND SEWER SERVICES, MANHOLES, INVERTS, RIMS, BFP'S, YARD HYDRANTS, CONTROL PANELS, FENCING, PARCEL BOUNDARY, LEGAL DESCRIPTION OF PARCEL BOUNDARY, WET WELL, VALVE BOX, FORCE MAIN,

13. INVERTS, GRATES, TOPS, RIMS MUST BE SHOWN FOR ALL STORM WATER DRAINAGE STRUCTURES. INVERTS (PIPES AND CLEANOUTS) AND RIMS MUST BE SHOWN FOR ALL GRAVITY SEWER MANHOLES. SLOPES MUST BE SHOWN ON EACH RUN OF PIPE FOR REVIEW AND

14. "AS-BUILT" PROFILE OF ALL DIRECTIONAL BORES AND JACK-AND-BORES INDICATING GRADE AND PIPE ELEVATIONS AT 10 FOOT INTERVALS SHALL BE PROVIDED ON AS-BUILT PLAN SHEETS BASED ON BORE LOGS DEVELOPED BY BORING CONTRACTOR DURING INSTALLATION. PROFILES SHALL USE HORIZONTAL STATIONING WHICH TIES TO STATIONING ON PLANS. PROFILES SHALL ALSO SHOW EXISTING SURFACE ELEVATIONS AS WELL AS ANY PROPOSED SURFACE ELEVATIONS ON THE PROFILE. SURFACE PROFILES MUST SHOW ANY PAVEMENT, SIDEWALKS, DITCHES, SWALES ETC. NOTE THAT PROFILES LOCATING PIPE SOLELY BY "DEPTH DEFLOW EXISTING CROUND" WILL NOT BE ACCEPTED

16. ELEVATIONS AND LOCATION OF ANY FLOOD ZONES ALONG THE FLOOD HAZARD BOUNDARIES SHALL BE DELINEATED.

18. STORM WATER MANAGEMENT SYSTEM FEATURES INCLUDING DIMENSIONS OF : WET AND DRY SWALES, WET AND DRY PONDS, CONVEYANCE SYSTEMS, EASEMENTS, ALONG WITH ALL ASSOCIATED M.E.S. STRUCTURES AND INVERTS, OUTFALL STRUCTURES AND INVERTS, SKIMMERS, DISCHARGE STRUCTURES AND INVERTS AND SLOT ELEVATIONS, TOP OF BANK, SLOPE OF BANK AND BOTTOM OF ALL PONDS, SWALES, CLOSED AND OPEN CONVEYANCES. FOR FEMA LOMR SUBMITTALS ALSO PROVIDE: FINISHED FLOOR ELEVATIONS, SPOT ELEVATIONS AND/OR CONTOURS SHOWING LOWEST LOT ELEVATIONS.

19. THE ENGINEER OF RECORD SHALL REVIEW AND APPROVE THE AS-BUILT PRIOR TO SUBMISSION TO THE CITY FOR FINAL APPROVAL. WRITTEN APPROVAL BY THE ENGINEER OF RECORD SHALL BE NOTED ON A TRANSMITTAL WITH A STATEMENT OF NO EXCEPTIONS TO MINIMUM STANDARDS PROVIDED HEREIN.

STORM WATER REQUIREMENTS FOR THE AS-BUILT SURVEYS ONLY APPLY TO PARCELS WITHIN CITY LIMITS. PLEASE SUBMIT THREE (3) HARD COPIES AND ONE (1) DIGITAL (AUTOCAD FORMAT

STORM SEWER,

STORMWATER FORCE

VACUUM SANITARY

SANITARY SEWER,

ON - SITE SEWAGE

SEWER

MAIN

SYSTEM

15. COASTAL SETBACK LINE OR COASTAL CONSTRUCTION CONTROL LINE SHOULD BE DESIGNATED.

17. NEARBY WETLANDS AND OTHER ENVIRONMENTALLY SIGNIFICANT RESOURCES CLEARLY

3. ALL UTILITIES IN THE PUBLIC RIGHT OF WAY AND WITHIN EASEMENTS OR TO THE END OF THE PUBLICLY OWNED PORTION OF THE UTILITY (I.E. METER AND BACKFLOW PREVENTER, CLEANOUT, ETC.) SHALL BE SHOWN WITH ASSOCIATED SIZES LABELED. THIS INCLUDES, BUT IS NOT LIMITED TO, STUB-OUTS/LATERALS, METERS, BFP'S, WATER MAINS, FORCE MAINS, GRAVITY SEWER MAINS, MANHOLES, STORM WATER PIPING AND ASSOCIATED STRUCTURES, VALVES, FIRE HYDRANTS, LIFT STATIONS, ETC. ALL PIPE LINE WORK MUST BE CONNECTED WITHIN THE SITE AS WELL AS THE CONNECTION TO EXISTING UTILITIES ADJACENT TO THE SITE (IT IS THE SURVEYOR'S RESPONSIBILITY TO COORDINATE WITH ALL CONTRACTORS FOR LOCATIONS AND SIZINO', ALL LITY CONNECTIONS TO THE BUILDINGS MUST BE SHOWN

CITY OF PANAMA CITY BEACH DATED MAY, 2012

SURVEYORS AND MAPPERS MUST MEET THE FOLLOWING MINIMUM STANDARD OF ACCURACY, COMPLETENESS, AND QUALITY FOR THE CITY OF PANAMA CITY BEACH TO ACCEPT AS-BUILTS:

5. MUST BE SIGNED AND SEALED BY THE SURVEYOR IN RESPONSIBLE CHARGE.

SIZING). ALL UTILITY CONNECTIONS TO THE BUILDINGS MUST BE SHOWN.

12. PROPERTY BOUNDARY MUST BE CLEARLY LABELED AND DIMENSIONED.

FLOW METER (IF APPLICABLE), DRIVEWAY, GATE.

BELOW EXISTING GROUND" WILL NOT BE ACCEPTED.

& PDF) FOR REVIEW AND APPROVAL.

APPROVAL

LABELED

PIPE MINIMUM FOR FOR

LINES SHALL BE TESTED FOR LEAKAGE BY LOW PRESSURE AIR TESTING. LOW PRESSURE AIR TESTING FOR CONCRETE PIPES SHALL BE AS PRESCRIBED IN ASTM C 828. LOW PRESSURE AIR TESTING FOR PVC PIPE SHALL BE AS PRESCRIBED IN ASTM F1417. AND PRESSURE DROP LIMITS SHALL BE DETERMINED BY USING ASTM F1417 TABLE 1. SHOWN BELOW. LOW PRESSURE AIR TESTING PROCEDURES FOR OTHER PIPE MATERIALS SHALL USE THE PRESSURES AND TESTING TIMES PRESCRIBED IN ASTM C 828 AND ASTM C 924. AFTER CONSULTATION WITH THE PIPE MANUFACTURER. VISIBLE LEAKS ENCOUNTERED SHALL BE CORRECTED REGARDLESS OF LEAKAGE TEST RESULTS. WHEN LEAKAGE EXCEEDS THE MAXIMUM AMOUNT SPECIFIED, SATISFACTORY CORRECTION SHALL BE MADE AND RETESTING ACCOMPLISHED. TESTING, CORRECTION, AND RETESTING SHALL BE MADE AT NO ADDITIONAL COST TO THE OWNER.

ASTM F1417 TABLE 1 MINIMUM SPECIFIED TIME REQUIRED FOR 1.0 PSIG PRESSURE DROP FOR SIZE AND LENGTH

INIMUM SPECIFIED TIME REQUIRED FOR THE FOR THE STORE DRAFT FOR OLD THE LETTING FOR 0.22 and 0.2

MINIMUM LONGER MIN:S TIME,FT LENGTH,S 100FT 150FT 200FT 250FT 300FT 350FT 400FT 450FT

SPECIFICATION TIME FOR LENGTH (L) SHOWN, MIN:S

PURPOSE OF

REINFORCED PRECAST CONCRETE MANHOLE SECTIONS INCLUDING CONCENTRIC OR ECCENTRIC CONES AND GRADE RINGS SHALL BE 4000 PSI. CONCRETE AND CONFORM TO ASTM C-478 OR AASHTO M-199. SECTIONS SHALL BE COMPLETE WITH 3/4" ROUND CAST IN PLACE WROUGHT IRON STEPS.

BRICK SHALL BE SOUND, HARD BURNED THROUGHOUT AND OF UNIFORM SIZE AND QUALITY AND SHALL BE IN ACCORDANCE WITH ASTM C-32, GRADE MS OR MM.

CONCRETE MASONRY SHALL BE SOLID PRECAST SEGMENTAL CONCRETE MASONRY UNITS CONFORMING TO ASTM C-139.

IRON CASTING SHALL CONFORM TO ASTM A-48, CLASS 30. BEARING SURFACES BETWEEN CAST IRON FRAMES, COVERS, GRATES SHALL BE MACHINED, FITTED TOGETHER AND MATCH MARKED TO PREVENT ROCKING, SYSTEM IDENTIFYING LETTER 2" HIGH SHALL BE STAMPED OR CAST INTO ALL COVERS SO THAT THEY MAY BE PLAINLY VISIBLE. CASTING SHALL BE MANUFACTURED BY EAST JORDAN IRON WORKS, INC., NEENAH FOUNDRY COMPANY OR EQUAL.

CONCRETE AND MASONRY MATERIALS FOR CONSTRUCTION OF SITE UTILITY STRUCTURES AND PADS SHALL CONSIST OF THE FOLLOWING:

PORTLAND CEMENT SHALL BE STANDARD BRAND OF PORTLAND CEMENT CONFORMING TO ASTM C-150, TYPE I OR II. FINE OR COARSE AGGREGATES FOR CONCRETE SHALL BE PER ASTM C-33. AGGREGATES SHALL BE WELL GRADED FROM FINE TO COARSE WITHIN LIMITS SPECIFIED IN ASTM C-33.

SHALL BE WELL GRADED FROM FINE TO COARSE WITHIN LINITS SPECIFIED IN ASIM C-33. MAXIMUM SIZE OF COARSE AGGREGATE SHALL BE $3/4^{\circ}$. AGGREGATE FOR CEMENT MORTAR SHALL BE CLEAN, SHARP SAND CONFORMING TO ASTM C-144. GRADE SAND FROM COARSE TO FINE WITH 100% PASSING NO. 8 SIEVE, AND NOT OVER 10% TO 30% PASSING NO. 50 SIEVE. HYDRATED LIME SHALL COMPLY WITH ASTM C-207, TYPE S. WATER SHALL BE CLEAN AND FREE FROM DELETERIOUS MATERIALS.

FORMS FOR CONCRETE WORK SHALL BE WOOD. FORMS SHALL BE SUFFICIENT STRENGTH TO PREVENT DEFORMATIONS UNDER LOAD AND TIGHT ENOUGH TO PREVENT LEAKAGE. FOUNDATIONS MAY BE POURED AGAINST EARTH WHERE CONDITIONS PERMIT.

CONCRETE, UNLESS OTHERWISE NOTED, SHALL HAVE COMPRESSIVE STRENGTH AFTER 28 DAYS OF 3000 PSI MINIMUM. MIX SHALL BE SO PROPORTIONED TO PROVIDE A MINIMUM OF 517 POUNDS OF CEMENT PER CUBIC YARD. CONCRETE FILL BELOW GRADE FOR THRUST BLOCKS, PIPE CRADLES ETC. MAY BE 2500 PSI. AT 28 DAYS.

CONCRETE, WHERE EXPOSED TO THE WEATHER, SHALL BE AIR ENTRAINED. AIR ENTRAINMENT SHALL BE ACCOMPLISHED BY THE USE OF ADDITIVES CONFORMING TO ASTM C-260. AIR CONTENT SHALL BE 6% + 1%. ADDITIVE SHALL BE USED IN STRICT ACCORDANCE WITH

TYPE M, AVERAGE COMPRESSIVE STRENGTH 2500 PSI. AT 28 DAYS. MORTAR MIX SHALL BE

MORTAR FOR PARGING SHALL CONSIST OF ONE PART PORTLAND CEMENT AND TWO PARTS

FLUSHING TIME SHALL BE AT LEAST THAT AMOUNT OF TIME NEEDED TO FLUSH 6 TIMES THE PIPE VOLUME AFTER 3 FPS VELOCITY IS REACHED OR UNTIL CLEAR, WHICHEVER IS LONGER. MAXIMUM LENGTH OF PIPE BETWEEN FLUSHING ASSEMBLIES SHALL BE 5,000 FEET.

POLY (VINYL CHLORIDE) PIPE (PVC): PLASTIC GRAVITY SEWER PIPE AND FITTINGS SHALL BE

PIPE LENGTHS SHALL NOT EXCEED 20 FEET AND PROVISIONS SHALL BE MADE AT EACH JOINT TO ACCOMMODATE EXPANSION AND CONTRACTIONS.

MATERIALS FOR SEWER FORCE MAINS: PVC PIPE FOR FORCE MAINS SHALL CONFORM TO

MATERIALS FOR SEWER FORCE MAINS: PVC PIPE FOR FORCE MAINS SHALL CONFORM TO THE REQUIREMENTS OF ASTM SDR-21 FOR PRESSURE RATING OF 200 PSI 230 C (73 DEGREES F). HDPE FORCE MAIN SHALL BE SDR-11. PIPE JOINTS SHALL BE INTEGRAL BELL AND SPIGOT TYPE WITH RUBBER RING SEALING GASKET. THE PIPE BELL SHALL BE DESIGNED TO BE AT LEAST AS STRONG AS THE PIPE WALL. STANDARD LENGTHS SHALL BE 20 FEET, EXCEPT THAT 15% OF TOTAL FOOTAGE FOR A PARTICULAR PROJECT MAY BE RANDOM LENGTHS OF NOT LESS THAN 10 FEET EACH. EACH PIECE OF PIPE SHALL BE TESTED BY THE MANUFACTURER OF 6000 PSI FOR A MINIMUM OF 5 SECONDS. THE BELL SHALL BE TESTED WITH THE PIPE. ALL PIPE SHALL BE LISTED BY UNDERWRITER'S LABORATORIES, INC., AND BY FACTORY MUTUAL AS APPROVED FOR USE IN UNDERGROUND MUNICIPAL WATER DISTRIBUTION SYSTEMS AND PRIVATE FIRE PROTECTION SYSTEM. CAST IRON OR DUCTILE IRON FITTINGS SHALL BE USED WITH PVC PIPE.

CAST IRON FITTINGS SHALL BE MECHANICAL JOINT AND SHALL CONFORM TO ANSI SPECIFICATION A21.10 FOR SIZES 3 INCHES THROUGH 12 INCHES AND SHALL BE CLASS 250. FITTINGS 14 INCHES AND LARGER SHALL BE CLASS 150 AND SHALL BE OF THE DIMENSIONS AND METAL THICKNESSES AS SHOWN IN THE HANDBOOK OF CAST IRON PIPE AS PUBLISHED BY THE CAST IRON PIPE RESEARCH ASSOCIATION. CAST IRON FITTINGS MAY BE USED IN DUCTILE IRON OR CAST IRON LINES, EXCEPT WHERE SHOWN OTHERWISE ON THE DRAWINGS

DUCTILE IRON FITTINGS SHALL BE DESIGNED FOR PRESSURE RATING OF 250 PSI AND SHALL BE IN ACCORDANCE WITH ANSI SPECIFICATIONS A21.10. FITTING SHALL BE MECHANICAL JOINT. DUCTILE IRON FITTINGS MAY BE USED IN DUCTILE IRON OR CAST IRON LINES, EXCEPT WHERE SHOWN OTHERWISE ON THE DRAWINGS.

THE EXTERIOR OF ALL CAST IRON AND DUCTILE IRON FITTINGS SHALL BE COATED WITH AN APPROVED BITUMINOUS COATING. THE INTERIOR OF THE PIPE SHALL BE EPOXY LINED (PROTECTO 401) IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATION (40 MILS

MATERIALS FOR CONCRETE MANHOLES: PRECAST OF CAST-IN-PLACE, AT CONTRACTOR'S OPTION. USE CONCRETE WHICH WILL ATTAIN A 28-DAY COMPRESSIVE STRENGTH OF 3000 \propto

INSPECTIONS AND TESTS: IT IS IMPERATIVE THAT ALL SEWERS AND MANHOLES BE BUILT PRACTICALLY WATERTIGHT AND THAT THE CONTRACTOR MUST ADHERE RIGIDLY TO THE SPECIFICATIONS FOR MATERIAL AND WORKMANSHIP.

THE ALLOWABLE LIMIT OF GROUNDWATER INFILTRATION FOR THE GRAVITY SYSTEM OF NEW SEWERS OR ANY ONE TRUNK, OR INTERCEPTOR, SHALL BE IN COMPLETE ACCORDANCE WITH ASTM 425-71T AND SHALL NOT EXCEED A LIMIT OF INFILTRATION EQUAL TO 0.2 GAL/INCH DIAMETER/HOUR/100 LINEAR FEET OF PIPE.

THE TEST WILL BE MADE BY MEASURING THE INFILTRATED FLOW OF WATER OVER A MEASURING WEIR SET UP IN THE INVERT OF THE SEWER, OR BY ALTERNATE METHOD APPROVED BY THE ENGINEER, A KNOWN DISTANCE FROM A TEMPORARY BULKHEAD OR OTHER LIMITING POINT OF INFILTRATION. AFTER THE SEWER OF SEWERS HAVE BEEN PUMPED OUT, AND NORMAL INFILTRATION CONDITIONS PREVAIL, TESTS SHALL BE STARTED.

TESTS SHALL BE RUN CONTINUOUSLY FOR A PERIOD OF NOT LESS THAN THREE HOURS, WITH WEIR READINGS TAKEN AT 20 MINUTE INTERVALS.

ALLOWABLE LEAKAGE PER 1000 FT OF PIPELINE (IN GALLONS)

PRESSURE AND LEAKAGE TESTS OF SEWAGE FORCE MAIN PIPING

CONTRACTOR SHALL FURNISH ALL GAUGES, METERS, PRESSURE PUMPS, EQUIPMENT, FITTINGS, AND LABOR NEEDED TO TEST THE LINE. THE COST OF THESE ITEMS SHALL BE INCLUDED IN THE PRICE OF THE PIPE. CONTRACTOR SHALL NOTIFY ENGINE 48 HOURS PRIOR TO START OF TEST. ALL PIPE INSTALLED SHALL BE TESTED AND WRITTEN ACCEPTANCE ISSUED BY THE ENGINEER PRIOR TO CONNECTION OF NEW LINE TO EXISTING LINES.

THE CONTRACTOR MAY TEST THE SYSTEM WITH JOINTS EXPOSED OR BACKFILLING COMPLETE AT HIS OPTION. THE CONTRACTOR SHALL OBTAIN AND PAY FOR ALL WATER USED. CARE SHAALL BE USED TO PREVENT BACKFLOW OF TEST WATER INTO POTABLE WATER SOURCE. POTABLE WATER SOURCE SHALL BE DISCONNECTED PRIOR TO PRESSURIZING TEST LINE. WATER USED DURING TEST SHALL BE TAKEN FROM A CONTAINER, NOT DIRECTLY FROM THE EXISTING WATER SYSTEM.

AT LEAST 24 HOURS PRIOR TO THE START OF THE PRESSURE AND LEAKAGE TEST, PRESSURE SHALL BE RAISED TO 150 PSIG AND HELD TO ALLOW ANY "SOIL CREEP" OR OTHER STRESS RELAXATION TO OCCUR. IF ANY PRESSURE REDUCTION OCCURS DURING THE 24 HOUR "SHAKEDOWN" PERIOD, REESTABLISH THE REQUIRED HYDROSTATIC TEST PRESSURE, THEN PROCEED WITH THE LEAKAGE TEST.

THE LEARAGE TEST. THE PRESSURE REQUIRED FOR THE FIELD HYDROSTATIC PRESSURE TEST SHALL BE 150 PSI. THE CONTRACTOR SHALL PROVIDE TEMPORARY PLUGS AND BLOCKING NECESSARY TO MAINTAIN THE REQUIRED TEST PRESSURE. CORPORATION COCKS AT LEAST ³/ INCHES IN DIAMETER, PIPE RISERS AND ANGLE GLOBE VALVES SHALL BE PROVIDED AT EACH PIPE DEAD-END AND HIGH POINTS IN ORDER TO BLEED AIR FROM THE LINE. DURATION OF PRESSURE TEST SHALL BE AT LEAST TWO HOURS. ALL LEAKS EVIDENT AT THE SURFACE SHALL BE REPAIRED AND LEAKAGE ELIMINATED REGARDLESS OF TOTAL LEAKAGE AS SHOWN BY TEST. LINES WHICH FAIL TO MEET TESTS SHALL REPAIRED AND RETESTED AS NECESSARY UNTIL TEST REQUIREMENTS ARE COMPLIED WITH. DEFECTIVE MATERIALS, PIPES, VALVES AND ACCESSORIES SHALL BE REMOVED AND REPLACED. THE PIPE LINES SHALL BE TESTED IN SUCH SECTION AS MAY BE DIRECTED BY THE ENGINEER BY SHUTTING VALVES OR INSTALLING TEMPORARY PLUGS AS REQUIRED. THE LINE SHALL BE FILLED WITH WATER, ALL AIR REMOVED, AND TEST PRESSURE SHALL BE MAINTAINED IN THE PIPE FOR THE ENTRE TEST PERIOD BY MEANS OF A GASOLINE OR ELECTRIC DRIVEN TEST PUNTO TO BE FURNISHED BY THE CONTRACTOR. ACCURATE MEANS SHALL BE PROVIDED FOR MEASURING THE WATER REQUIRED TO MAINTAIN THIS PRESSURE. THE AMOUNT OF WATER REQUIRED IS A MEASURE OF THE LEAKAGE.

NO PIPE INSTALLATION WILL BE ACCEPTED UNTIL THE LEAKAGE (EVALUATED ON A PRESSURE BASIS OF 150 PSI) IS LESS THAN 2.2 GALLONS PER 24 HOURS PER THOUSAND FEET PER INCH NOMINAL DIAMETER. THE FOLLOWING TABULATES THE ALLOWABLE LEAKAGE:

 1 HOUR
 0.18
 0.28
 0.37
 0.55
 0.74
 0.92
 1.10
 1.29

 2 HOURS
 0.37
 0.55
 0.74
 1.10
 1.47
 1.84
 2.20
 2.57

 WHERE ANY SECTION OF A MAIN IS PROVIDED WITH CONCRETE REACTION BACKING THE HYDROSTATIC PRESSURE TEST SHALL

NOT BE MADE UNTIL AT LEAST FIVE (5) DAYS HAVE ELAPSED AFTER THE CONCRETE REACTION BACKING WAS INSTALLED. IF HIGH EARLY-STRENGTH CEMENT IS USED IN THE CONCRETE REACTION BACKING, THE HYDROSTATIC PRESSURE TEST SHALL NOT BE MADE UNTIL AT LEAST THREE (3) DAYS HAVE ELAPSED.

<u>2</u> <u>3</u> <u>4</u> <u>6</u> <u>8</u> <u>10</u> <u>12</u> <u>14</u>

UNPLASTICIZED POLYVINYL CHLORIDE (PVC) MEETING AND/OR EXCEEDING ASTM SPECIFICATIONS D-3034 (LATEST EDITION).

COMPLY WITH REQUIREMENTS OF FS RR-F-621, FOR TYPE AND STYLE REQUIRED.

BACKFILL SHALL BE SAME MATERIAL SPECIFIED FOR PIPE BEDDING. WHERE SERVICE OR UTILITY LINES CROSS A STREET, BEDDING SHALL BE CARRIED TO FIVE FEET (5') BEHIND THE CURB, OR WHERE SIDEWALKS EXIST, TO THE SIDE OF THE SIDEWALK FARTHEST AWAY FROM THE STREET.

READY-MIX CONCRETE SHALL CONFORM TO THE REQUIREMENTS OF ASTM C-94.

FLUSHING REQUIREMENTS FOR WATER

MANUFACTURER'S PRINTED DIRECTIONS.

AND SEWER FORCE MAINS

SEWER COLLECTION SYSTEM

PROPORTIONED BY VOLUME.

THE DRAWINGS.

DURATION OF TEST

NOMINAL DRY FILM THICKNESS).

REINFORCING STEEL FOR CONCRETE SHALL BE INTERMEDIATE GRADE NEW BILLET STEEL CONFORMING TO ASTM A-615, GRADE 40.





4.) ALL PIPE FITTINGS SHALL BE PVC ASTM 3034 SDR35, GREEN IN COLOR.

SERVICE LATERAL DETAIL NOT TO SCALE

OTHER PIPE	HORIZONTAL SEPARATION	CROSSINGS (SEE NTOE 1)	JOINT SPACING @ CROSSINGS (FULL JOINT CENTERED)
TORM SEWER, FORMWATER FORCE AIN, RECLAIMED WATER	WATER MAIN 3' MIN.	WATER MAIN 12" MIN. EXCEPT FOR STORM SEWER, THEN 6" IS THE MIN. AND 12" IS PREFERRED	ALTERNATE 3' MIN. WATER MAIN
ACUUM SANITARY SEWER	WATER MAIN 10' PREFERRED 3' MIN.	WATER MAIN 12" PREFERRED 6" MIN.	ALTERNATE 3' MIN. WATER MAIN
GRAVITY OR PRESSURE GANITARY SEWER, GANITARY SEWER FORCE MAIN	WATER MAIN 10' PREFERRED 6' MIN. (SEE NTOE 2)	WATER MAIN 12" MIN. EXCEPT FOR GRAVITY SEWER, THEN 6" IS THE MIN. AND 12" IS PREFERRED	ALTERNATE 6' MIN. WATER MAIN
DN - SITE SEWAGE REATMENT & DISPOSAL SYSTEM	10' MIN.		
WATER MAIN SHOULD CROSS ABOVE OTHER I SEPARATION IS 12". '' '	PIPE. WHEN WATER MAIN MUST BE BELOW OTHER PIP E BOTTOM OF THE WATER MAIN IS LAID AT LEAST 6" A DED SEE DETAIL M-35B FOR REQ'D ADDITIONAL PROTEK	E, THE BOVE CTION.	

STANDARD - MAIN **CROSSING/SEPARATION DETAIL** NOT TO SCALE

REVISIONS: ND. DESCRIPTION DRAWN CHECKED DATE 1 | _ PHASE: DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22 2211 THOMAS DRIVE, SU PANAMA CITY BEACH, FL PHONE: (850) 236-9832 2211 THOMAS DRIVE, SUITE 100 PANAMA CITY BEACH, FL ARCHITECTS COMMISSION NUMBER 21804 CONSULTANTS: MCNEIL 17800 Panama City Beach Parkway Panama City Beach Elorida 32413 Panama City Beach, Florida 32413 -CARROLL Phone: 850-234-1730 Fax: 850-234-1731 ENGINEERING, INC. Professional Engineering Consultants STATE OF FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER: 7288 PROJECT:

PANAMA CITY BEACH **REPLACEMENT FIRE STATION # 31**

PANAMA CITY BEACH, FLORIDA SHEET TITLE:

CONSTRUCTION DETAILS





6. MAINTAIN A 3 FOOT MINIMUM SEPARATION BETWEEN POTABLE AND REUSE WATER SERVICES.



1" CORPORATION SINGLE METER BOX STOP & 1" SERVICE AND WATER METER TUBING (BY CITY) R/W LINE NOTES: 1. ALL FITTINGS SHALL BE BRASS WITH COMPRESSION/PACK JOINT TYPE CONNECTIONS. 2. NO SERVICE LINE SHALL TERMINATE UNDER A DRIVEWAY. 3. EACH SERVICE SHALL TERMINATE AT A CURB STOP WHICH SHALL BE FASTENED TO A 1" x 4" x 30" STAKE PAINTED WHITE AND MARKED WITH THE NUMBER OF THE LOT TO BE SERVED. 4. CURB STOP SHALL BE A FORD BALL METER VALVE B43–342W, B43–344W OR CITY APPROVED EQUAL. 5. ALL SERVICE TAPS TO BE LOCATED IN FIELD. TAPS SHALL BE NO CLOSER THAN AND WILL NOT BE SET IN DRAINAGE SWALES, EASEMENTS OR SIDEWALKS. 5. MUNITIAN A 2 FOOT MUNITIAN SECRAPTION DETINES AND DELICE WATER SERVICES



TYPICAL WATER SERVICE CONNECTION





LENGTHS MODIFIED ACCORDINGLY.

REQUIRED LENGTH OF RESTRAINED JOINT PIPE



PRESSURE IN EITHER DIRECTION. 5.) PIPE SIZES ARE GIVEN IN INCHES. 6.) PIPE LENGTHS ARE GIVEN IN FEET. 7.) LENGTHS SHOWN ARE FOR A TEST PRESSURE OF 180 PSI.

1.) RESTRAIN TO NEXT FULL JOINT BEYOND GIVEN LENGTH. 2.) RESTRAIN 11.25" BENDS 50% OF LENGTH FOR 22.5" BENDS. 3.) ALL VALVES AND FITTINGS SHALL BE RESTRAINED TO THE CONNECTING SECTIONS OF PIPE. 4.) ALL VALVES MUST BE PROPERLY ANCHORED OR RESTRAINED TO RESIST A 180 PSI TEST



_													
	MAIN	HOF	RIZ. B	ENDS			TEES				REDU	CERS	PLUGS
	SIZE	90°	45°	22.5 °		SIZ	ZE LE	NGTH		SIZ	ĽE LE	ENGTH	
	24	90	38	18	X24 177	X20 139	X16 94	X12 40	X10 6	X20 64	X16 117	X12 158	214
	20	78	32	15	X20 148	X16 105	X12 56	X10 25	X8 0	X16 65	X12 115	X10 149	184
	16	66	27	13	X16 116	X12 70	X10 42	X8 12		X12 64	X10 90	X8 111	151
	12	51	22	10	X12 83	X10 59	X8 32	X6 0		X10 34	X8 62	X6 86	118
	10	44	18	9	X10 66	X8 41	X6 8			X8 33	X6 61	X4 81	100
	8	37	15	7	X8 50	X6 21	X4 0	X3 0		X6 35	X4 59		83
	6	29	12	5	X6 30	X4 0				X4 32	X3 44		63
	4	21	8	4	X4 14								45
	3	17	7	4	X3 10								36

DISINFECTION SHALL BE AFTER THE DISTRIBUTION SYSTEM HAS BEEN TESTED TO THE SATISFACTION OF THE ENGINEER AND SHALL BE DISINFECTED IN ACCORDANCE WITH AWWA SPECIFICATION C-651 WHICH PROVIDES FOR THE INJECTION OF A 50 PPM SOLUTION OF CHLORINE REMAINING FOR 24 HOURS. IN THE PROCESS OF CHLORINATING WATER PIPE, ALL VALVES OR OTHER APPURTENANCES SHALL BE OPERATED WHILE THE PIPE LINE IS FILLED WITH CHLORINATING AGENT. WATER VALVES 12" AND LESS SHALL BE EPOXY COATED RESILIENT SEAT GATE VALVE.

PERMISSIBLE LEAKAGE: NO PIPE INSTALLATION WILL BE ACCEPTABLE UNTIL OR UNLESS THIS LEAKAGE (EVALUATED ON A PRESSURE BASIS OF 150 PSI) IS LESS THAN 4 U.S. GALLONS PER 24 HOURS PER THOUSAND FEET PER INCH NOMINAL DIAMETER IN ACCORDANCE WITH

INSPECTION AND HYDROSTATIC TESTING: AFTER THE PIPE HAS BEEN LAID AND BACKFILLED AS SPECIFIED EACH VALVED SECTION OF NEWLY LAID PIPE SHALL BE SUBJECTED TO HYDROSTATIC PRESSURE OF 150 PSI. THE DURATION OF EACH PRESSURE TEST SHALL BE AT LEAST TWO HOURS OR UNTIL THE LINE HAS BEEN COMPLETELY INSPECTED FOR VISIBLE LEAKS.

WATER LINE BELOW". FLEXIBLE COUPLINGS: STEEL MIDDLE RING, TWO STEEL FOLLOWER RINGS, TWO RESILIENT GASKETS AND STEEL BOLTS. DRESSER TYPE 38 OR APPROVED EQUAL.

BOLTS: STEEL, ANSI/ASTM A-307 CAST IRON WASHERS: ANSI/ASTM A-126, CLASS A WATER SERVICE IDENTIFICATIONS: PLASTIC LINE MARKS, NOMENCLATURE "CAUTION, BURIED

RODS: STEEL, ANSI/ASTM A-575 ROD COUPLINGS: MALLEABLE IRON, ANSI/ASTM A-197

CLAMPS, STRAPS AND WASHERS: STEEL ANSI/ASTM A-506

PROVIDE ANCHORAGES FOR TEE, PLUGS, CAPS, AND BENDS. AFTER INSTALLATION, APPLY A FULL COAT OF ASPHALT OR OTHER ACCEPTABLE CORROSION-RETARDING MATERIAL TO SURFACES OF RODS AND CLAMPS.

CHECK VALVES: THE CHECK VALVES OVER THREE INCHES SHALL BE IRON BODY, BRONZE MOUNTED, HORIZONTAL SWING CHECK WITH FLANGED ENDS. ALL WORK PARTS SHALL BE SPRING LOCATED TO PREVENT SLAMMING. THE CHECK VALVES SHALL BE CLOW F-2955, OR APPROVED EQUAL. CHECK VALVES UNDER THREE INCHES SHALL BE SCREWED END, BRONZE BODY, SILENT CHECK VALVES AS MANUFACTURED BY CRANE COMPANY, NO. 34 OR APPROVED EQUAL.

UNDER FOUR-INCHES: GATE VALVES UNDER FOUR-INCHES SHALL BE IRON OR BRONZE BODY, SOLID WEDGE VALVES EQUIPPED WITH OPERATING HAND WHEELS. ALL ECCENTRIC VALVES 10-INCHES OR LARGER SHALL BE GEAR OPERATED WITH HAND WHEELS FOR ABOVE GROUND VALVES AND HUB OPERATED FOR BELOW GROUND VALVES. ALL ECCENTRIC VALVES 8-INCHES AND SMALLER SHALL BE LEVEL OPERATED FOR ABOVE GROUND VALVES AND HUB OPERATED FOR BELOW GROUND VALVES. ALL HUB OPERATED UNITS SHALL BE PROVIDED A CAST-IRON VALVES BOX AND COVER.

FOUR-INCHES AND OVER: SHALL BE CAST-IRON BODY, FULLY BRONZE MOUNTED DOUBLE-DISC, PARALLEL SEAL VALVES WIDE FLANGE OR SPIGOT END DEPENDING ON INSTALLATION. FLANGED GATE VALVES SHALL BE PROVIDED WITH 125 POUND AMERICAN STANDARD FLANGES. ALL VALVES TO BE INSTALLED ABOVE THE GROUND SHALL BE FITTED WITH WHEEL-TYPE HAND OPERATORS. ALL VALVES TO BE SET BELOW GRADE SHALL BE FITTED WITH HUB-TYPE OPERATORS AND SHALL HAVE A CAT-IRON VALVE BOX INSTALLED CONCENTRICALLY OVER THE VALVE.

MINIMUM WORK PRESSURE, 160 PSI, UNLESS OTHERWISE INDICATED. GATE VALVES: STANDARD SHUT-OFF VALVES WITH MAXIMUM WORK PRESSURE CAST INTO OUTSIDE-SCREW-AND-YOKE TYPE COMPLYING WITH AWWA C-500. ALL VALVES SHALL BE COUNTERCLOCKWISE.

PROVIDE VALVES AND FLOW CONTROL DEVICES AS INDICATED:

MECHANICA PIPE FITTINGS SHALL BE ASSEMBLED WITH A NON-TOXIC LUBRICANT AS RECOMMENDED BY THE MANUFACTURER. PVC PIPE SHALL BE AS MANUFACTURED BY THE U.S. PIPE COMPANY, THE CERTAIN-TEED PRODUCTS CORPORATION, THE JOHNS-MANSVILLE COMPANY, THE ETHYL CORPORATION, OR APPROVED EQUAL.

RING-TYPE NEOPRENE GASKETS SHALL BE PROVIDED IN RECESSED IN THE BELLS TO MAKE JOINTS WATER TIGHT. ALL PIPES SHALL BE SUITABLE FOR USE AT MAXIMUM HYDROSTATIC PRESSURES OF 165 PSI AT 75 DEGREES F AND MEETING AND/OR EXCEEDING THE MINIMUM REQUIREMENTS OF AWWA C-900-07 MADE TO SDR 25 DIMENSIONS. MAXIMUM LAYING LENGTHS SHALL BE 40 FEET WITH MANUFACTURER'S OPTION TO SUPPLY UP TO 15 PERCENT RANDOMS (MINIMUM LENGTH EQUALS 10 FT.). ALL FITTINGS SHALL BE CAST IRON WITH

ACCEPTABLE TO THE ENGINEER. UNPLASTICIZED POLYVINYL CHLORIDE (PVC PIPE SHALL HAVE AN INTEGRATED BELL-TYPE JOINT DESIGNED FOR CONVEYING POTABLE WATER UNDER PRESSURE.



TAPPING SLEEVE ASSEMBLY AND

VALVE BLOCKING DETAIL

NOT TO SCALE

/12" MIN.

1.) FIRE HYDRANT SHALL BE SUPPLIED WITHOUT A WEEP HOLE OR WITH A PERMANENTLY PLUGGED WEEP HOLE.

2.) THE SHEAR PAD MAY BE RECESSED UP TO 6 INCHES BELOW FINISHED GRADE.

3.) CLEARANCE BETWEEN BOTTOM OF BOLTS AND TOP OF SHEAR

4.) HYDRANT SHALL BE AVK MODEL 2780 NOSTALGIC, AMERICAN DARLING B-84-B, OR US FIRE HYDRANT, MODEL SENTINEL 250 WITH SS VALVE ROD.

5.) A WEATHER SHIELD SHALL BE PROVIDED TO PROTECT OPERATING

6.) THE HYDRANT'S UPPER AND LOWER STEM, BREAK COUPLING. INTERNAL PINS AND CLIPS. AND ALL EXTERNAL BOLTING SHALL BE MANUFACTURED OF STAINLESS STEEL.

5-1/4" FIRE HYDRANT

ASSEMBLY DETAIL

NOT TO SCALE

PAD SHALL BE A 6" MINIMUM.

-PUMPER NOZZLE

-M.J. TEE WITH

6" BRANCH

-RESILIENT SEAT GATE

VALVE AND BOX

(SEE SHEET W-1)

FACING STREE

MAIN PIPE DIAMETER PLUS (2) TAP PIPE

DIAMETERS (WHICHEVER IS LARGER) FROM A JOINT OR FITTING.

OPERATING NUT

× · · · /

M.J. ANCHORING COUPLING

WITH RESTRAINED JOINTS

STEM OR NUT.

(2) 25"-

HOSE NOZZLE

24" SQUARE-

(SEE NOTE 2)

AND 6" THICK REINFORCED CONCRETE SHEAR PAD

COMPACTED-

2 - #4 @ 9"

O.C. ALL AROUND

SEE NOTE

NOTES:

BACKFILL

WATER DISTRIBUTION SYSTEM PRODUCTS: PROVIDE ELLS, TEES, REDUCING TEES, WYES, COUPLINGS, AND OTHER REQUIRED PIPING ACCESSORIES OF SAME TYPE AND CLASS OF MATERIALS AS CONDUIT, OR OF MATERIAL HAVING EQUAL OR SUPERIOR PHYSICAL AND CHEMICAL PROPERTIES AS





ASPHALTIC CONCRETE PAVING

PROVIDE ALL LABOR, MATERIALS, EQUIPMENT, SERVICES, ETC. NECESSARY AND INCIDENTAL TO THE COMPLETION OF ALL PAVEMENT AS SHOWN ON THE DRAWINGS AND AS SPECIFIED SUBMIT A "LETTER OF INTENT" FOR THE FOLLOWING:

ASPHALT PAVING MATERIAL AND MIX DESIGN. PROVIDE COPIES OF MATERIALS CERTIFICATES SIGNED BY MATERIAL PRODUCER AND CONTRACTOR, CERTIFYING THAT EACH MATERIAL ITEM COMPLIES WITH, OR EXCEEDS, SPECIFIED REQUIREMENTS. WEATHER LIMITATIONS: APPLY PRIME AND TACK COATS WHEN AMBIENT TEMPERATURE IS

ABOVE 50 DEGREES F. (10 DEGREES C), AND WHEN TEMPERATURE HAS NOT BEEN BELOW 35 DEGREES F. (1 DEGREE C) FOR 12 HOURS IMMEDIATELY PRIOR TO APPLICATION. DO NOT APPLY WHEN BASE IS WET OR CONTAINS AN EXCESS OF MOISTURE. CONSTRUCT ASPHALT CONCRETE SURFACE COURSE WHEN ATMOSPHERIC TEMPERATURE IS ABOVE 40 DEGREES F. (4 DEGREES C), AND WHEN BASE IS DRY. SURFACE COURSE MAY BE PLACED WHEN AIR TEMPERATURE IS ABOVE 30 DEGREES F. (-1 DEGREE C) AND RISING.

GRADE CONTROL: ESTABLISH AND MAINTAIN REQUIRED LINES AND ELEVATIONS. THE SUBCONTRACTOR SHALL WARRANT ALL ASPHALT PAVING AGAINST DEFECTS IN MATERIALS AND WORKMANSHIP FOR A PERIOD OF TWO YEARS. PRODUCTS: USE LOCALLY AVAILABLE MATERIALS AND GRADATIONS WHICH EXHIBIT A SATISFACTORY RECORD OF PREVIOUS INSTALLATIONS.

AGGREGATE: CRUSHED STONE, CRUSHED GRAVEL, AND SHARP-EDGED NATURAL SAND. MAXIMUM AGGREGATE SIZE SHALL BE NO GREATER THAN ONE-HALF OF THE DESIGN THICKNESS OF THE WEARING OR BINDER COURSE.

SURFACE PREPARATION: PROOF ROLL PREPARED BASE SURFACE TO CHECK FOR UNSTABLE AREAS AND AREAS REQUIRING ADDITIONAL COMPACTION. NOTIFY CONTRACTOR OF UNSATISFACTORY CONDITIONS. DO NOT BEGIN PAVING WORK UNTIL DEFICIENT BASE AREAS HAVE BEEN CORRECTED AND ARE READY TO RECEIVE PAVING. PRIME COAT: APPLY AT RATE OF 0.2 TO 0.5 GAL. PER SQ. YD., OVER COMPACTED BASE. APPLY MATERIAL TO PENETRATE AND SEAL, BUT NOT FLOOD SURFACE. CURE AND DRY AS LONG AS NECESSARY TO ATTAIN PENETRATION AND EVAPORATION OF VOLATILE.

TACK COAT: APPLY TO CONTACT SURFACE OF PREVIOUSLY CONSTRUCTED ASPHALT OR PORTLAND CEMENT CONCRETE AND SURFACES ABUTTING OR PROJECTING INTO ASPHALT CONCRETE PAVEMENT. DISTRIBUTE AT RATE OF 0.05 TO 0.51 GAL. PER SQ. YD. OF SURFACE.

ALLOW TO DRY UNTIL AT PROPER CONDITION TO RECEIVE PAVING. ASPHALT CONCRETE MIX: THIS ITEM SHALL CONSIST OF A WEARING SURFACE CONSTRUCTED OF ASPHALTIC CONCRETE ON A PREPARED BASE.

THE MATERIALS AND CONSTRUCTION METHODS SHALL COMPLY WITH THOSE SET FORTH FOR ASPHALTIC CONCRETE IN THE LATEST F.D.O.T. EDITION OF THE STANDARD SPECIFICATIONS. THE ASPHALTIC CEMENT SHALL MEET THE REQUIREMENTS OF AASHTO SPECIFICATIONS M-20. VISCOSITY GRADE AC-20 (PENETRATION GRADE 60-70). JOB MIX FORMULA: THE MARSHALL TESTING WILL BE USED IN ESTABLISHING THE JOB MIX FORMULA AND FOR CONTROL TESTING THROUGHOUT THE WORK. THE DENSITY OF FIELD SAMPLES SHALL NOT BE LESS THAN 95% OF THE MARSHALL LABORATORY COMPACTED MIXTURE COMPOSED OF THE SAME MATERIALS IN LIKE PROPORTIONS.

THE THICKNESS OF THE SURFACE SHALL BE AS SPECIFIED IN THE SITE WORK PLANS. THIS REQUIREMENT SHALL BE CHECKED BY CORES AND WHERE A DEFICIENCY OF MORE THAN 1/4" EXISTS, THE CONTRACTOR SHALL BE REQUIRED TO CORRECT THE DEFICIENCY EITHER BY REPLACING THE FULL THICKNESS OR OVERLAYING THE AREAS TO THE SATISFACTION OF THE ENGINEER. SAND ASPHALT BASE

PLACE ASPHALT CONCRETE MIXTURE ON PREPARED SURFACE, SPREAD AND STRIKE-OFF. SPREAD MIXTURE AT MINIMUM TEMPERATURE OF 225 DEGREES F. (107 DEGREES C). PLACE IN STRIPS NOT LESS THAN 10' WIDE, UNLESS OTHERWISE ACCEPTABLE TO THE ENGINEER. AFTER FIRST STRIP HAS BEEN PLACED AND ROLLED, PLACE SUCCEEDING STRIPS AND EXTENDED ROLLING TO OVERLAP PREVIOUS STRIPS. COMPLETE BASE COURSE FOR A SECTION BEFORE PLACING SUPERCE COURSE SECTION BEFORE PLACING SURFACE COURSE.

MAKE JOINTS BETWEEN OLD AND NEW PAVEMENTS, OR BETWEEN SUCCESSIVE DAYS' WORK, TO ENSURE CONTINUOUS BOND BETWEEN ADJOINING WORK. CLEAN CONTACT SURFACES AND APPLY TACK COAT. BEGIN ROLLING WHEN MIXTURE WILL BEAR ROLLER WEIGHT WITHOUT EXCESSIVE DISPLACEMENT.

ACCOMPLISH BREAKDOWN OR INITIAL ROLLING IMMEDIATELY FOLLOWING ROLLING OF JOINTS AND OUTSIDE EDGE. CHECK SURFACE AFTER BREAKDOWN ROLLING, AND REPAIR DISPLACED AREAS BY LOOSENING AND FILLING, IF REQUIRED, WITH HOT MATERIAL. CONTINUE SECOND ROLLING UNTIL MIXTURE HAS BEEN THOROUGHLY COMPACTED.

PERFORM FINISH ROLLING WHILE MIXTURE IS STILL WARM ENOUGH FOR REMOVAL OF ROLLER MARKS. CONTINUE ROLLING UNTIL ROLLER MARKS ARE ELIMINATED AND COURSE HAS ATTAINED MAXIMUM DENSITY. AFTER FINAL ROLLING, DO NOT PERMIT VEHICULAR TRAFFIC ON PAVEMENT UNTIL IT HAS COOLED AND HARDENED. ERECT BARRICADES TO PROTECT PAVING FROM TRAFFIC UNTIL MIXTURE HAS COOLED ENOUGH NOT TO BECOME MARKED MARKED

TEST IN-PLACE ASPHALT CONCRETE COURSES FOR PAVING AS DIRECTED BY ENGINEER FOR THICKNESS: IN-PLACE COMPACTED THICKNESS WILL NOT BE ACCEPTABLE IF EXCEEDING FOLLOWING ALLOWABLE VARIATION FROM REQUIRED THICKNESS:

BASE COURSE: 1/2" PLUS OR MINUS SURFACE COURSE: 1/4" PLUS OR MINUS

SURFACE SMOOTHNESS: TEST FINISHED SURFACE OF EACH ASPHALT CONCRETE COURSE FOR SMOOTHNESS, USING 10' STRAIGHT EDGE APPLIED PARALLEL WITH, AND AT RIGHT ANGLES TO CENTER OF PAVED AREAS. SURFACES WILL NOT BE ACCEPTABLE IF EXCEEDING THE FOLLOWING TOLERANCES FOR SMOOTHNESS:

BASE COURSE SURFACE: 1/4" WEARING COURSE SURFACE: 3/16" CHECK SURFACED AREAS AT INTERVALS AS DIRECTED BY ENGINEER.

FIELD DENSITY AND SOIL BEARING CAPACITY TESTS SHALL BE PERFORMED BY THE GEOTECHNICAL ENGINEER. PROVIDE INSPECTION, CERTIFICATION OF PAVEMENT CONSTRUCTION, FIELD TESTS AND CORE SAMPLES OF THE COMPLETE PAVEMENT CONSTRUCTION.

MISCELLANEOUS PAVEMENT

WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: CONCRETE SIDEWALKS, CURBS, CURB AND GUTTER, INCLUDING POROUS FILL

CONCRETE LIGHT POLE BASES.

SUBMIT A "LETTER OF INTENT" FOR THE FOLLOWING:

CONCRETE MIX DESIGN THIS SUBCONTRACTOR SHALL WARRANT ALL ASPHALT PAVING AGAINST DEFECTS IN MATERIALS AND WORKMANSHIP FOR A PERIOD OF TWO (2) YEARS. POROUS FILL SHALL BE CLEAN COARSE SAND, FREE DRAINING GRAVEL, OR CRUSHED ROCK ALL AS APPROVED BY THE GEOTECHNICAL ENGINEER.

POROUS FILL UNDER SIDEWALKS, ETC., SHALL BE GRADED BETWEEN 3/8" AND NO. 200 SIEVE. POROUS FILL SHALL BE CAPABLE OF BEING COMPACTED TO NOT LESS THAN 95% OF THE MAXIMUM DRY DENSITY AS DETERMINED BY ASTM-1557.

STEEL REINFORCING BARS SHALL CONFORM TO "SPECIFICATIONS FOR DEFORMED BILLET STEEL BARS FOR CONCRETE REINFORCEMENT", ASTM A-615 GRADE NO. 60, HAVING A MINIMUM YIELD STRENGTH OF 60,000 PSI.

TIE WIRE SHALL BE BLACK ANNEALED WIRE, 16 GAUGE MINIMUM. BAR SUPPORTS SHALL CONFORM TO THE "BAR SUPPORT SPECIFICATIONS" CONTAINED IN "MANUAL OF STANDARD PRACTICE" AS PUBLISHED BY CRSI AND WCRSI. BAR SUPPORTS AND ACCESSORIES WITHIN 1/2" OF SURFACE OF CONCRETE EXPOSED TO WEATHER SHALL BE NON-CORROSIVE. CEMENT SHALL BE GRAY PORTLAND CEMENT, TYPE I OR II, CONFORMING TO ASTM C-150 OR ASTM C-175 FOR AIR-ENTRAINING PORTLAND CEMENT. CONCRETE AGGREGATES SHALL CONFORM TO ASTM C-33.

FINE AND COARSE AGGREGATES SHALL BE REGARDED AS SEPARATE INGREDIENTS AND EACH SHALL CONFORM TO THE APPROPRIATE GRADING REQUIREMENTS OF ASTM C-33. AIR-ENTRAINING ADMIXTURES SHALL CONFORM TO ASTM C-260. EXPANSION JOINTS SHALL BE 1/2" THICK CANE FIBER EXPANSION JOINTS, CONFORMING TO ASTM D-1751. EXPANSION JOINT SEALANT SHALL BE TRAFFIC GRADE, SELF LEVELING TREMCO THC-900" OR PERCORA CORPORATION "NF-200". COLOR SHALL BE BLACK. SHALL BE AS RECOMMENDED BY SEALANT MANUFACTURER.

CURING COMPOUND SHALL BE CLEAR, CONFORMING TO ASTM C-309. CURING COMPOUND SHALL BE COMPATIBLE WITH PAINTS, ETC., SCHEDULED OR SPECIFIED FOR APPLICATION TO CONCRETE SURFACE.

ALL CONCRETE, UNLESS OTHERWISE NOTED, SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3,000 PSI AT 28 DAYS. MIX DESIGN SHALL BE SO PROPORTIONED TO PROVIDE A MINIMUM OF 517 POUNDS OF CEMENT PER CUBIC YARD. ALL CONCRETE SHALL BE PROPORTIONED TO HAVE A SLUMP OF 4" MAXIMUM. TOLERANCE IN SLUMP SHALL NOT EXCEED ACI RECOMMENDATIONS. READY-MIXED CONCRETE SHALL CONFORM TO ASTM C-94 AND THE NATIONAL READY MIX CONCRETE ASSOCIATION. POROUS FILL SHALL BE LAID AND COMPACTED TO A MINIMUM DEPTH OF 3", UNLESS OTHERWISE INDICATED, UNDER ALL SIDEWALKS, ETC..

POROUS FILL SHALL BE COMPACTED TO NOT LESS THAN 95% MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D-1557. IT IS THE CONTRACTOR'S RESPONSIBILITY TO SUPPLY ALL MATERIALS NECESSARY TO COMPLETE PAVING.



SITE IMPROVEMENTS

ALL OFF-SITE WORK INCLUDED CONSISTS OF BUT IS NOT LIMITED TO THE FOLLOWING: SITE RELATED FENCING. GUARD POSTS, GUARD RAIL AND POSTS AND SIGN POSTS LOCATED ON THE SITE. TRAFFIC CONTROL SIGNS. GUARD POSTS, GUARD RAIL AND POSTS AND SIGN POSTS:

STEEL SHAPES SHALL CONFORM TO ASTM A-36. STEEL PIPE SHALL CONFORM TO ASTM A-53, E OR S, TYPE B. STEEL PIPE SHALL CONFORM TO ASTM A-501.

ASPHALT BASED COATING IS NOT PERMITTED.

SHOP COAT SHALL BE RUST INHIBITING RED OXIDE, RED LEAD OR LEAD CHROMATE OR EQUAL. IT IS THE INTENT TO PERMIT THE USE OF THE FABRICATORS STANDARD PRIME COATING

CONCRETE FOR SETTING FENCE AND GUARD RAIL POSTS AND SETTING AND FILLING OF SIGN AND GUARD POSTS SHALL BE PORTLAND CEMENT COMPLYING WITH ASTM C-150, AGGREGATES COMPLYING WITH ASTM C-33, AND CLEAN WATER. MIX MATERIALS TO OBTAIN CONCRETE WITH A MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 2500 PSI, USING AT LEAST 4 SACKS OF CEMENT PER CU. YD., 1" MAXIMUM SIZE AGGREGATES, MAXIMUM 3" SLUMP, AND 2% TO 4% ENTRAINED AIR. PREPARE TO CONFORM TO ASTM C-94

MISCELLANEOUS NOTES

THE CONTRACTOR IS CAUTIONED TO VISIT THE SITE AND FAMILIARIZE HIMSELF WITH THE PROJECT PRIOR TO BIDDING.

THE ENGINEER HAS ATTEMPTED TO LOCATE EXISTING STRUCTURES AND EXISTING UTILITIES IN THE PROJECT AREA. IT IS THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE EXACT LOCATIONS OF THESE STRUCTURES OR UTILITIES AND TO DETERMINE IF OTHER STRUCTURES OR UTILITIES WILL BE ENCOUNTERED DURING THE COURSE OF THE WORK. THE CONTRACTOR SHALL TAKE WHATEVER STEPS NECESSARY TO PROVIDE FOR THEIR PROTECTION AND RELOCATION OF UTILITIES IN CONFLICT WITH NEW CONSTRUCTION BY APPROPRIATE UTILITY COMPANY.

THE CONTRACTOR SHALL PLACE AND MAINTAIN ADEQUATE BARRICADES, CONSTRUCTION SIGNS, FLASHING LIGHTS, TORCHES, RED LANTERNS AND GUARDS DURING PROGRESS OF CONSTRUCTION WORK IN ACCORDANCE WITH STATE STANDARDS AND UNTIL IT IS SAFE FOR BOTH PEDESTRIAN AND VEHICULAR TRAFFIC.

CONTRACTOR IS RESPONSIBLE FOR REPLACING EXISTING SURROUNDINGS (I.E., ASPHALT, SIDEWALKS, CURBS, ETC.) THAT ARE DAMAGED DURING CONSTRUCTION. REPLACEMENT SHALL MATCH EXISTING.

ALL SITE WORK MATERIALS AND CONSTRUCTION METHODS SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE FLORIDA DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS. CTOR SHALL HAVE ALL PERMITS PRIOR TO CONSTRUCTION IN WETLANDS, COUNTY

CONSTRUCTION PLANS ARE BASED ON FIELD SURVEY AND OTHER DATA AS SHOWN. IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY ALL LOCATIONS OF NEW AND EXISTING CONNECTIONS NECESSARY TO COMPLETE THE INTENT OF THE PLANS. IN THE EVENT THERE IS A CONFLICT DUE TO UNFORESEEN OBSTRUCTIONS OR SHORT FALLS TO CONNECTIONS (WHICH DOES NOT MEET THE INTENT OF THE CONSTRUCTION PLANS). THE CONTRACTOR SHALL CONTACT THE ENGINEER IMMEDIATELY FOR DIRECTION. THE CONTRACTOR SHALL RELOCATE OR REMOVE OBSTACLES AS DIRECTED BY OWNER.



 FDOT 8" CRUSHED LIME ROCK, CRUSHED CONCRETE OR GRADED AGGREGATE BASE (COMPACTED TO 98% DENSITY ASTM D-1557.) 12" SUB-BASE (STABILIZED TO 40 LBR. MIN.) (COMPACTED TO 98% DENSITY ASTM D-1557.)

ASPHALTIC PAVEMENT DETAIL NOT TO SCALE

FDOT 8" CRUSHED CONCRETE (COMPACTED TO 98% DENSITY ASTM D-1557.)



SMOOTH DOWEL #4 X 24" @ 12" CTRS. DOWEL COATING └─ DOWEL CAP (DOWEL TO BE 1 1/4" 3" CLR.— CLEAR OF CLOSED END) - 3/4" EXPANSION JOINT MATERIAL EXPANSION JOINT #3 REBAR ◎ 18" O.C.-E.W.-__ 2" CLR MIN. 3" CLR MIN. └-4000 PSI. CONCRETE — #3 REBAR @ 18" O.C.-E.W. CONCRETE FOOTING AT PERIMETER PERIMETER 10'± SQUARE SECTION



SUB-BASE (PER SITE CONSTRUCTION MATERIALS TESTING SCHEDULE) CONSTRUCTION JOINT

CONSTRUCTION JOINTS MUST BE USED WHERE AN INCOMPLETE POUR IS MADE BETWEEN PLANNED EXPANSION JOINTS. THE MAXIMUM SQUARE MUST BE HALF THE DISTANCE BETWEEN EXPANSION JOINTS (SEE PLANS). WHERE A COMPLETE POUR IS MADE A SAW CUT OR SCORE SHALL BE PLACED IN LIEU OF CONSTRUCTION JOINTS.

CONCRETE BASE – FDOT 8" CRUSHED LIME ROCK, CRUSHED CONCRETE OR GRADED AGGREGATE BASE. (COMPACTED TO 98% DENSITY ASTM D-1557.)

CONCRETE PAVEMENT SUBGRADE – CLEAN FINE SAND BEDDING COURSE WITH LESS THAN 12 PERCENT FINES (THROUGH A 200 SIEVE). A MINIMUM OF 18" OF FREE DRAINING SUBGRADE SOILS (COMPACTED TO 98% MODIFIED PROCTOR ASTM D-1557.

HEAVY DUTY CONCRETE PAVEMENT DETAIL

NOT TO SCALE



NOT TO SCALE

CONCRETE PAVEMENT SUBGRADE – CLEAN FINE SAND BEDDING COURSE WITH LESS THAN 12 PERCENT FINES (THROUGH A 200 SIEVE). A MINIMUM OF 18" OF FREE DRAINING SUBGRADE SOILS COMPACTED TO 98% MODIFIED PROCTOR ASTM D-1557.

SEE GEO-TECH REPORT COMPACT TOP 12" OF EXISTING SOILS TO A DENSITY OF 95% OF THE MODIFIED PROCTOR MAX. DRY DENSITY (ASTM D-1557)

CONSTRUCTION JOINTS MUST BE USED WHERE AN INCOMPLETE POUR IS MADE BETWEEN PLANNED EXPANSION JOINTS. THE MAXIMUM SQUARE MUST BE HALF THE DISTANCE BETWEEN EXPANSION JOINTS (SEE PLANS). WHERE A COMPLETE POUR IS MADE A SAW CUT OR SCORE SHALL BE PLACED IN LIEU OF CONSTRUCTION JOINTS.



1'–6"|

CURB CUT

→ <u>1'-6" 6" 1'-6"</u> TAPER TAPER

CURB CUT

PLAN

#4 REBAR CONTINUOUS



RIBBON CURB DETAIL NOT TO SCALE



BEYOND THE DROP CURB OR TO THE EXTENT THAT NO REMAINING SECTION OF CURB OR CURB AND GUTTER IS LESS THAN 5' LONG. THE EXISTING SIDEWALK SHALL BE REMOVED TO THE NEAREST JOINT BEYOND THE TRANSITION SLOPE OR WALK AROUND OR TO THE EXTENT THAT NO REMAINING SECTION OF SUBMALK JEESE THAN 5' LONG SECTION OF SIDEWALK IS LESS THAN 5' LONG. NOT TO SCALE 1/2" EXPANSION TYP.

 \sum

SIDEWALK AT CURB

2″____

SIDEWALK AT PAVEMEN

10' SECTION TYP.

1/2" EXPANSION TYP.-

2"R —

4" BELOW FINISHED PAVEMENT -



HANDICAP RAMP DETAIL

NOT TO SCALE

35 S.F.

SOLID WHITE EDGE LINE OR LANE LINE

SOLID WHITE CHANNELIZING LINE

EXTENSION OF EDGE LINE

THROUGH CROSS-OVER AREA

- - - - - -

6' 10' 6' 10' 6' 10' 6' 10' 6' 10' 6' 10' 6' 10' 6' 10' 6'

BROKEN WHITE LANE LINE

ROKEN YELLOW CENTER LINE



DIMENSIONS ARE + OR - 1"

27 S.F.

/ <u>- | - | 0</u> -

¹⁰

		TESTING	SCHEDULE	
ITEM	TEST	TEST IDENTIFICATION	TEST REQUIREMENTS	TEST FREQUENCY
UTILITY TRENCH FILL & BACKFILL	MAXIMUM DENSITY OPTIMUM MOISTURE FIELD DENSITY GRADATION	AASHTO T-180 ASTM D-1557 AASHTO T-191, T-204 ASTM D-1556, D-2937 AASHTO M-92	N/A 95% OF MAXIMUM DENSITY (15% PASSING NO. 200)	PER SOIL TYPE ONE PER 500 LF HORIZONTAL OR ONE PER 750SY WITH A MINIMUM OF 3 TESTS, ALTERNATING LIFTS (12") ONE PER SOIL TYPE
FILL & BACKFILL UNDER ROADWAYS AND STRUCTURES	MAXIMUM DENSITY OPTIMUM MOISTURE FIELD DENSITY GRADATION	AASHTO T-180 ASTM D-1557 AASHTO T-191, T-204, T-238 ASTM D-1556, D-2937, D-2922 AASHTO M-92	N/A 98% OF MAXIMUM DENSITY (15% PASSING NO. 200)	PER SOIL TYPE ONE PER 500 LF OR ONE PER 750SY WITH A MINIMUM OF 3 TESTS, ALTERNATING LIFTS (12") ONE PER SOIL TYPE
SUBGRADE	BEARING VALUES MAXIMUM DENSITY OPTIMUM MOISTURE FIELD DENSITY & THICKNESS	LBR-FDOT AASHTO T-180 ASTM D-1557 AASHTO T-191, T-204 ASTM D-1556, D-2937	40 (MIN.) N/A 98% OF MAXIMUM DENSITY	ONE PER SITE OR AT MATERIAL CHANGES PER SOIL TYPE ONE PER 500 LF HORIZONTAL OR ONE PER 750SY WITH A MINIMUM OF 3 TESTS
BASE	MAXIMUM DENSITY OPTIMUM MOISTURE FIELD DENSITY & THICKNESS	AASHTO T-180 ASTM D-1557 AASHTO T-191, T-204 ASTM D-1556, D-2937	N/A 98% OF MAXIMUM DENSITY	ONE PER SOURCE OR AT MATERIAL CHANGES ONE PER 500 LF HORIZONTAL OR ONE PER 750SY WITH A MINIMUM OF 3 TESTS
ASPHALT	MATERIALS QUALITY BITUMEN CONTENT & GRADATION FIELD DENSITY & THICKNESS	AASHTO T-164, T-30 ASTM D-2172 ASTM D-2950	FDOT SPEC. 320, 330, 334 FDOT SPEC. 916 95% OF LAB DENSITY	MIN. ONE PER DAY FOR GRADATION OR AS REQUIRED BY INSPECTOR ONE PER 500 LF HORIZONTAL OR ONE PER 750SY WITH A MINIMUM OF 3 TESTS
CONCRETE (MISC. SITE WORK)	SLUMP TEST COMPRESSIVE STRENGTH AIR CONTENT	AASHTO T-119 ASTM C-143 AASHTO T-23 ASTM C-31 AASHTO T-199	2" TO 3" 4000 PSI 3% TO 6%	AS REQUIRED BY INSPECTOR OR ONE PER SET OF CYLINDERS ONE SET OF 3 CYLINDERS PER 50CY PER DAY ONE PER SET OF CYLINDERS

19 S.I 36 S.F

PAVEMENT ARROWS AND MESSAGE DETAILS

DIMENSIONS ARE + OR - 1"

YELLOW EDGE LINE

16 S.F.

DOTTED LINE (TURNING GUIDE LINE)

DOUBLE SOLID YELLOW (OR WHITE)

2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2''4' 2'

TWO-LANE PASSING PROHIBITED (YELLOW)

12 S.F.

. CONCRETE FOR SITE WORK INCLUDES BUT IS NOT LIMITED TO CURB, CURB & GUTTER, SIDEWALKS, CONCRETE PAVING, ETC. . THIS TEST SCHEDULE APPLIES TO SITE WORK ONLY. SEE ARCHITECT'S SPECIFICATIONS FOR FOUNDATION/BUILDING TESTING.

DEPTH OF SAW CUT

3-1/2" MA

20' R —

PLAN

PROFILE FLARED END

<u>6" 1'-0"</u> 3" R

 \rightarrow

EDGE OF PAVT .-

GUTTER/

ON PLANS.

<u> 1'–</u>6"

TYPE F

TOP OF CURB

0" MIN. 📕

6' - END OF CURB

EDGE OF PAVEMENT/

CURB AND GUTTER TYPES E AND F

" MIN.*

TOP OF CURB

GUTTER-

HANDICAP STRIPING DETAIL NOT TO SCALE

" WHITE



CONSTRUCTION DETAILS

PANAMA CITY BEACH, FLORIDA SHEET TITLE:



PROJECT:

SHEET NUMBER:

Professional Engineering Consultants STATE OF FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER: 7288



17800 Panama City Beach Parkway Panama City Beach, Florida 32413 Phone: 850-234-1730

Fax: 850-234-1731

CONSULTANTS:

ARCHITECTS COMMISSION NUMBER 21804



90% CONSTRUCTION DOCUMENTS

CONSTRUCTION DOCUMENTS 2211 THOMAS DRIVE, SUITE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 PANAMA CITY BEACH, FL

DESIGN DEVELOPMENT 60% DOCUMENTS

SCHEMATIC DESIGN

PHASE:

DRAWN CHECKED DATE

DRAWN CHECKED DATE

11/05/21

12/17/21

02/11/22

03/31/22

05/16/22

07/01/22

DESCRIPTION

REVISIONS:

NOTE: FOR USE ADJACENT TO CONCRETE OF FLEXIBLE PAVEMENT, CONCRETE SHOWN. FOR DETAILS DEPICTING USAGE ADJACENT TO FLEXIBLE PAVEMENT, SEE DIAGRAM RIGHT, EXPANSION JOINT, PERFORMED JOINT FILLER AND JOINT SEAL ARE REQUIRED BETWEEN CURB & GUTTER AND CONCRETE PAVEMENT ONLY, SEE DIAGRAM RIGHT.

1. FOR CURB. GUTTER AND CURB AND GUTTER PROVIDE 1/8" - 1/4" CONTRACTION

CURB, GUTTER AND CURB AND GUTTER EXPANSION JOINTS SHALL BE LOCATED IN ACCORDANCE WITH SECTION 520 OF THE STANDARD SPECIFICATIONS.

IOINTS AT 10' CENTERS (MAX.). CONTRACTION JOINTS ADJACENT TO CONCRETE

PAVEMENT ON TANGENTS AND FLAT CURVES ARE TO MATCH THE PAVEMENT

2. ENDS OF CURBS TYPES B AND D SHALL TRANSITION FROM FULL TO ZERO

JOINTS, WITH INTERMEDIATE JOINTS NOT TO EXCEED 10' CENTERS.

MODIFIED TYPE "F" CURB DETAIL

*WHEN USED ON HIGH SIDE OF ROADWAYS, THE CROSS SLOPE OF THE GUTTER SHALL MATCH THE CROSS SLOPE OF THE ADJACENT PAVEMENT. THE THICKNESS OF THE LIP SHALL BE 6", UNLESS OTHERWISE SHOWN AND CONCRETE PAVEMENT

EXPANSION JOINT BETWEEN GUTTER

DAPPLIES TO BOTH HIGH AND LOW SIDES OF PAVEMENT, LOW SIDE SHOWN

JOINT SEA CONCRETE PAVEMENT PRE FORMED JOINT FILLER.

CURB AND GUTTER AND TYPE A CURB ADJACENT TO FLEXIBLE PAVEMENT

△ APPLIES TO BOTH HIGH AND LOW SIDES OF PAVEMENT, LOW SIDE SHOWN.

1-1/2"---

SAW CUTS SHOULD BE AVOIDED WITHIN VALLEY GUTTER AND WITHIN CURB AND GUTTER ENDINGS. **CONTRACTION JOINT IN CURB AND GUTTEF**

PLAN

PROFILE

STRAIGHT END

GENERAL NOTES

HEIGHTS IN 3 FEET.

SLOPE VARIES ίπτη ↓ FLEXIBLE PAVT

URFACE ON LOW SIDE OF PAVEMENT TO BE 1/4" ABOVE LIP OF GUTTER. SURFACE ON HIGH SIDE TO BE FLUSH WITH LIP OF CURB OR CURB AND GUTTER.

TOP OF STALL OR SIDEWALK.



4" BLUE-

4" WHI



TOTAL VUA	PERCENTAGE REQUIREMENT	REQUIRED LANDSCAPE AREA
8,658 SQ. FT.	20%	1,732 SQ. FT.
1 CANOPY TREE	REQUIRED	PROVIDED
PER 400 SQ. FT.	5	5
3HRUBS		
8 SHRUBS	REQUIRED	PROVIDED
PER 50 SQ. FT.	277	277
<u></u>		
GROUNDCOVERS		
1 SQ. FT. OF GROUNDCOVER	REQUIRED	PROVIDED
PER 5 SQ. FT.	347	347

* 50 % TURF GRASS SUBSTITUTION CLAIMED. SEE PLANT SCHEDULE FOR TOTAL SOD QUANTITY.

- LANDSCAPE NOTES: 1. ALL PLANT MATERIAL FLORIDA #1 OR BETTER.
- 2. FERTILIZE ALL PLANTINGS WITH OSMOCOTE OR OTHER APPROVED SLOW RELEASE FERTILIZER AT MANUFACTURER'S RECOMMENDED
- RATE BEFORE MULCHING. 3. DECREASE PLANT SPACING AS REQUIRED TO ALLOW PLACEMENT
- OF THE DESIGNATED NUMBER OF PLANTS PER GROUPING.
- 4. APPLY CASARON OR OTHER APPROVED PRE-EMERGENT HERBICIDE TO ALL PLANTING AREAS BEFORE MULCHING.
- 5. MULCH ALL AREAS OF TREE, SHRUB AND GROUNDCOVER MASS
- PLANTINGS WITH 3" PINESTRAW MULCH. 6. SOD ALL DISTURBED AREAS.
- 7. AUTOMATIC IRRIGATION SYSTEM TO PROVIDE 100% COVERAGE OF ALL LANDSCAPE AREAS.
- 8. PROVIDE BACKFLOW PREVENTION PER CITY REQUIREMENTS. 9. PROVIDE RAIN SHUT OFF DEVICE PER FL. STATE LAW.

5 'MUSKOGEE' CRAPE MYRTLE LAGERSTROEMIA INDICA 'MUSKOGEE' 30 GAL. MIN. 3 STEMS @ 1" CAL.

126 PURPLE MUHLY GRASS

82 FAKAHATCHEE GRASS

TRIPSACUM DACTYLOIDES

57 DWARF YAUPON HOLLY

ILEX VOMITORIA 'NANA'

100 PINEAPPLE GUAVA

ACCA SELLOWIANA

1 GAL 42" O.C.

1 GAL 42" O.C.

3 GAL. 30" O.C.

3 GAL. 4' O.C.

MUHLENBERGIA CAPILLARIS

 \bigcirc

 \bigcirc

0

 \odot

(+)







LP 1



TOP OF ROOTBALL LEVEL WITH OR SLIGHTLY ABOVE SURROUNDING GRADE.

REMOVE CONTAINER BEFORE PLANTING. CLEANLY PRUNE ANY ENCIRCLING ROOTS.

MULCH – SEE LANDSCAPE NOTES. NO MORE THAN 1" OF MULCH ON TOP OF ROOT BALL

LOOSENED SOIL. DIG AND TURN SOIL TO -REDUCE COMPACTION TO THE AREA AND DEPTH SHOWN

BOTTOM OF ROOT BALL RESTS ON -EXISTING OR RECOMPACTED SOIL.



-CLEANLY PRUNE ONLY DAMAGED, DISEASED AND/OR WEAK BRANCHES. — ROOTBALL

-4" HIGH X 8" WIDE ROUND-TOPPED SOIL BERM ABOVE ROOT BALL SURFACE SHALL BE CONSTRUCTED AROUND THE ROOT BALL. BERM SHALL BEGIN AT ROOT BALL PERIPHERY

-PRIOR TO MULCHING, LIGHTLY TAMP SOIL AROUND THE ROOTBALL IN 6" LIFTS TO BRACE SHRUB. DO NOT OVER COMPACT. WHEN THE PLANTING HOLE HAS BEEN BACKFILLED, POUR WATER AROUND THE ROOT BALL TO SETTLE THE SOIL -EXISTING SOIL

- CLEANLY PRUNE DAMAGED, DISEASED AND/OR WEAK BRANCHES. DO NOT PRUNE CENTRAL LEADER.

- TOP OF ROOTBALL LEVEL WITH OR SLIGHTLY ABOVE SURROUNDING GRADE. -EARTH SAUCER BEYOND EDGE OF ROOTBALL.

- REMOVE CONTAINER BEFORE PLANTING. CLEANLY PRUNE ANY ENCIRCLING ROOTS.

MORE THAN 1" OF MULCH ON TOP OF ROOT BALL

NOTE: PRIOR TO MULCHING, LIGHTLY TAMP SOIL AROUND THE ROOTBALL IN 6" LIFTS TO BRACE TREE. DO NOT OVER COMPACT. WHEN THE PLANTING HOLE HAS BEEN BACKFILLED, POUR WATER AROUND THE ROOT BALL TO SETTLE THE SOIL

-EXISTING SOIL

-LOOSENED SOIL. DIG AND TURN SOIL TO REDUCE COMPACTION TO THE AREA AND DEPTH SHOWN

-BOTTOM OF ROOT BALL RESTS ON EXISTING OR RECOMPACTED SOIL.



Alan D. Holt, A.S.L.A. LANDSCAPE

ARCHITECT, PA FL LC#26000193 P.O. BOX 2549 PANAMA CITY, FL 32402 TELEPHONE: (850)914-9006 E-MAIL:alan@alandholtasla.com

Job Number: 22026

REVISIONS

DAIL
DATE
11/05/21
12/17/21
02/11/22
03/31/22
05/16/22
07/01/22
-



2211 THOMAS DR. , STE 100 2211 THOMAS DR., SIE IN PANAMA CITY BEACH, FL PHONE: (850) 236-9832

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA Sheet Title: ANDSCAPE DETAILS SHEET NUMBER: LP2



GATION SCH	EDULE		
JANTITY	KEY	MODEL (HUNTER UNLESS OTHERWISE NOTED)	GALLONS PER MINUTE
	4	PROS-04-PRS40-CP-NP-MP1000-210 14'HALF	0.42 @ 40 PSI
)	6	PROS-04-PRS40-CP-NP-MP2000-90 20'QUARTER	0.43 @ 40 PSI
)	$\langle \overline{\mathcal{D}} \rangle$	PROS-04-PRS40-CP-NP-MP2000-210 19'HALF	0.77 @ 40 PSI
5	8	PROS-04-PRS40-CP-NP-MP2000-360 19'FULL	1.48 @ 40 PSI
	9	PROS-04-PRS40-CP-NP-MP3000-90 30'QUARTER	0.86 @ 40 PSI
2	10	PROS-04-PRS40-CP-NP-MP3000-210 30'HALF	1.82 @ 40 PSI
		PROS-04-PRS40-CP-NP-MP3000-360 30'FULL	3.64 @ 40 PSI
	1"	1" ELECTRIC REMOTE CONTROL VALVE PGV-NP-100G-S	
	1-1/2"	1–1/2" ELECTRIC REMOTE CONTROL VALVE PGV–NP–150G–S	
	ICZ101	1" DRIP VALVE KIT ICZ–NP–101	
	A	HUNTER PRO C	
	A	WEATHER SENSOR	
	Ē	FLUSH VALVE	
		RAINBIRD XFD-06-12 INLINE DRIP SPACE LINE 4" OFF CURB, 12" OFF BUILDING	18" O.C.





2211 THOMAS DR. , STE 1 PANAMA CITY BEACH, FL PHONE: (850) 236–9832 Commission Number: 21804 2211 THOMAS DR. , STE 100

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA Sheet Title:

IRRIGATION LAN SHEET NUMBER:

 $|P^{1}$











IP2 SCALE: N.T.S.





- TO 24-INCHES MINIMUM ABOVE FINISH GRADE.
- 4. MECHANICALLY TAMP TO 95% PROCTOR.
- **SLEEVING DETAIL** IP2 SCALE: N.T.S.

24" MIN. TO FINISH GRADE -PVC CAP (TYPICAL)



Alan D. Holt, A.S.L.A. LANDSCAPE ARCHITECT, PA FL LC#26000193 P.O. BOX 2549 PANAMA CITY, FL 32402 TELEPHONE: (850)914-9006 E-MAIL:alan@alandholtasla.com Job Number: 22026 REVISIONS NO. DESCRIPTION DRAWN CHECKED DATE

PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 02/11/22 60% DOCUMENTS 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 **BID SET** 07/01/22



2211 THOMAS DR. , STE 100 JRA 2211 THUMAS DR., STE TO PANAMA CITY BEACH, FL PHONE: (850) 236-9832

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA Sheet Title: IRRIGATION DETAILS



04-PCB Replacement Fire Station 31\A0-1.dwg, 7/1/2022 8:47:21 AM, Shane Boullie, Adobe PDF, 1:1

804-PCB Replacement Fire Station 31\A0-2.dwg, 7/1/2022 8:48:05 AM, Shane Boullie, Adobe PDF, 1:1





FINISH SCHEDULE

CEILING

- SUSPENDED ACOUSTIC PANEL CEILING (ACT)
- EPOXY PAINTED GYPSUM WALL BOARD EGGSHELL ENAMEL PAINTED GYPSUM WALL BOARD.

<u>KEY:</u>

SPACE NAME

CLG CLG HT

FLR BASE WALL

SPACE NO REMARKS

4. METAL SOFFIT PANELS 5. PAINTED EXPOSED STRUCTURE

FLOORS

CARPET

CERAMIC TILE SEALED CONCRETE

- BASE
- VINYL
- CERAMIC TILE PAINTED WOOD BASE
- WALLS
- EGGSHELL ENAMEL PAINTED GYPSUM WALL BOARD.
- EPOXY PAINTED GYPSUM WALL BOARD.
- EPOXY PAINTED GYPSUM WALL BOARD & CERAMIC TILE. 4. EPOXY PAINTED CONCRETE
- 5. EXPOSED CONCRETE

REMARKS

- PROVIDE CONT 3.5" SOUND BATTS ABOVE FINISH CEILING,
- PROVIDE 5/8" PAINTED PLYWOOD BACKBOARD -COORDINATE WITH ELECTRICAL.
- SLOPE TO FLOOR DRAINS, SEE STRUCT. COORD WITH FINISH FLOOR. INSTALLER.. DEPRESS SLAB 2" AT SHOWER.
- 5. INSTALL CERAMIC TILE AT BACKSPLASH. SEE ELEVATIONS. 6. PROVIDE MR GYP. BD. ON THE CEILING IN THIS SPACE

CONSTRUCTION KEYNOTES

- HI-LO ELECTRIC WATER COOLER WITH BOTTLE FILLER, SEE PLUM.
- 2 FLOOR SINK, SEE PLUMBING
- 3 SS UTILITY SHELF WITH HOOKS & MOP HOLDERS.
- PROVIDE 1/2" RESILIENT CHANNELS FOR SOUND
- ATTENUATION, THIS SIDE OF STUD WALL.
- PROVIDE 6" STUDS THIS WALL
- WATER SUPPLY W/ SHUT-OFF VALVE FOR OWNER PROVIDED COFFEE MAKER
- PREFABRICATED SHOWER CURB, SEE SPECIFICATIONS.
- DOWNSPOUT CONNECT TO UNDERGROUND STORM WATER SYSTEM SEE 4/AØ2 AND SEE CIVIL

REVISIONS

NO.	DESCRIPTION	DRAWN	CHECKED	DATE
ρĻ	IASE	DRAWN	CHECKED	DATE
SCł	HEMATIC DESIGN			11/Ø5/21
DE	GIGN DEVELOPMENT			12/17/21
60	% DOCUMENTS			Ø2/11/22
309	% CONSTRUCTION DOCUMENTS			Ø3/31/22
co	NSTRUCTION DOCUMENTS			Ø5/16/2
BID	> SET			Ø7/Ø1/2



2211 THOMAS DR. , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832



A11A

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT

BAY COUNTY, FLORIDA SHEET TITLE:

ARCHITECTURAL FLOOR PLAN







SHEET NUMBER:

A1.18



NOTES

- 1. UNLESS NOTED OTHERWISE INTERIOR PLAN DIMENSIONS ARE TO INTERIOR FACE OF ICF FORM (FOAM)
- 2. UNLESS NOTED OTHERWISE EXTERIOR PLAN DIMENSIONS ARE TO EXTERIOR FACE OF SPLITFACE VENEER

REVISIONS NO. DESCRIPTION

Image: Sector of the sector	NO.	DESCRIPTION	DRAWN	CHECKED	DATE
Image: Sector					
Image: Sector of the sector					
Image: Sector of the sector					
Image: Sector Struction documents Image					
PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN DRAWN CHECKED DATE SCHEMATIC DESIGN II/05/21 II/05/21 DESIGN DEVELOPMENT I II/05/21 60% DOCUMENTS I 02/11/22 90% CONSTRUCTION DOCUMENTS I 03/31/22 CONSTRUCTION DOCUMENTS I 05/16/22 BID SET I 07/01/2					
PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN II II/05/21 DESIGN DEVELOPMENT I I2/I7/21 60% DOCUMENTS I 02/II/22 90% CONSTRUCTION DOCUMENTS I 03/31/22 BID SET I 07/01/22					
SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22	Ē	IASE	DRAWN	CHECKED	DATE
DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22	SCł	HEMATIC DESIGN			11/Ø5/21
60% DOCUMENTS 02/11/22 90% CONSTRUCTION DOCUMENTS 03/31/22 CONSTRUCTION DOCUMENTS 05/16/22 BID SET 07/01/22	DE	BIGN DEVELOPMENT			12/17/21
90% CONSTRUCTION DOCUMENTS 03/31/2 CONSTRUCTION DOCUMENTS 05/16/2 BID SET 01/01/2	60	% DOCUMENTS			Ø2/11/22
CONSTRUCTION DOCUMENTS Ø5/16/2 BID SET Ø1/01/2	90%	& CONSTRUCTION DOCUMENTS			@3/31/22
BID SET 07/01/2					
	co	NSTRUCTION DOCUMENTS			Ø5/16/22



2211 THOMAS DR., STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832



A1.1C

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT

BAY COUNTY, FLORIDA SHEET TITLE:

DIMENSIONED FLOOR PLAN



04-PCB Replacement Fire Station 31\A1-2.dwg, 7/1/2022 8:55:06 AM, Shane Boullie, Adobe PDF, 1:1



304-PCB Replacement Fire Station 31\A1-2.dwg, 7/1/2022 8:54:29 AM, Shane Boullie, Adobe PDF, 1:

04-PCB Replacement Fire Station 31\A2-1.dwg, 7/1/2022 8:55:48 AM, Shane Boullie, Adobe PDF, 1:1





SYMBOL LEGEND

2'x4' FLUORESCENT FIXTURE

1'x4' FLUORESCENT FIXTURE

2'x2' FLUORESCENT FIXTURE

RECESSED EMERGENCY LIGHT

RECESSED LIGHT

2'x4' EMERGENCY FLOURECENT FIXTURE

22222222 1'x4' EMERGENCY FLOURECENT FIXTURE

2'x2' EMERGENCY FLOURECENT FIXTURE



t-PCB Replacement Fire Station 31\A4-1.dwg, 7/1/2022 8:56:31 AM, Shane Boullie, Adobe PDF, 1:



04-PCB Replacement Fire Station 31\A5-1.dwg, 7/1/2022 8:57:12 AM, Shane Boullie, Adobe PDF, 1:1









PCB Replacement Fire Station 31\A6.x Wall Sections.dwg, 7/1/2022 8:59:07 AM, Shane Boullie, Adobe PDF,



04-PCB Replacement Fire Station 31\A6.x Wall Sections.dwg, 7/1/2022 8:59:38 AM, Shane Boullie, Adobe PDF, 1:1





21804-PCB Replacement Fire Station 31\A1-1.dwg, 7/1/2022 8:53:35 AM, Shane Boullie, Adobe PDF, 1:1

RE	VISIONS			
NO.	DESCRIPTION	DRAWN	CHECKED	DATE
PH	IAGE	DRAWN	CHECKED	DATE
SCH	HEMATIC DESIGN			11/Ø5/
DES	SIGN DEVELOPMENT			12/17/2
60	% DOCUMENTS			Ø2/11/2
90%	& CONSTRUCTION DOCUMENTS			Ø3/31/
00	NSTRUCTION DOCUMENTS			Ø5/16/
BID) SET			Ø7/Ø1/
A	RCHITECTS	MA CITY E: (850) ion Number:	BEACH 236-98 21804	1, FL .32
	RCHITECTS	A CITY E: (850) ion Number:	BEACH 236-98 21804	1, FL 32
A	RCHITECTS	A CITY E: (850) ion Number:	BEACH 236-98 218Ø4	1, FL 32
A	RCHITECTS	A CITY E: (850) fon Number:	BEACH 236-98 21804	1, FL 32
A	ANAN RCHITECTS	IA CITY E: (850) ion Number:	BEACH 236-98 21804	1, FL 32
PRO	ANAN RCHITECTS	A CITY (850) ion Number:	BEACH 236-98 21804	5, FL 32
	VECT:	A CITY (850) ion Number:	BEACH 236-98 21804	1, FL 32
	ANAMA CITY BEA	ACH	BEACH 236-98 21804	1, FL 32
	ANAMA CITY BEA	ACH		
	ANAMA CITY BEA	ACH		
	AT COUNTY, FLORIDA	ACH		I, FL 32
	AY COUNTY, FLORIDA	ACH		
	AT COUNTY, FLORIDA ET TITLE:	ACH		
	AT COUNTY, FLORIDA ET TITLE: 200F PLAN	ACH		
	AT COUNTY, FLORIDA ET TITLE: COOF PLAN	ACH		
	AT COUNTY, FLORIDA ET TITLE: COOF PLAN	ACH		




14-PCB Replacement Fire Station 31\A8.x Casework.dwg, 7/1/2022 9:02:31 AM, Shane Boullie, Adobe PDF, 1









						Ľ	DOORS							
MARK	TYPE	WIDTH	HEIGHT	THICK	DOOR MAT	GLAZING	RATING	FRAME TYPE	FRAME MAT	HDW-SET	HEAD	JAMB	SILL	REMARKS
100A	F	3-Ø	7-Ø	1-3/4	HМ	-	-	2	НМ	17	3/49.3	2/49.3	1/A9.1	-
100B	F	3-Ø	7-Ø	1-3/4	HМ	-	-	2	НМ	09	3/49.3	2/49.3	1/A9.1	-
1000	F	3-Ø	۵-۲	1-3/4	HМ	-	-	2	НМ	18	3/49.3	2/49.3	1/A9.1	-
100D	F	3-Ø	7-Ø	1-3/4	НM	-	-	2	НМ	14	3/49.3	2 \$ 1/A9.3	1/A9.1	-
100E	F	PR3-Ø	7-Ø	1-3/4	НM	-	-	2	НМ	19	5/49.3	4/49.3	1/A9.1	-
100F	F	3-Ø	7-Ø	1-3/4	HМ	-	-	1	HM	Ø4	8/A9.2	7/49.2	1/A9.1	1
100G	ОН	14-0	14-0	PER MFG	STL	-	-	PER MFG	STL	Øl	11/49.2	9 \$ 10/A9.2	-	-
100H	ОН	14-0	14-0	PER MFG	STL	_	-	PER MFG	STL	Øl	11/A9.2	9 \$ 10/A9.2	-	-
100J	ОН	14-0	14-0	PER MEG	STL	-	-	PER MEG	STL	Øl	11/49,2	9 \$ 10/A9,2	-	-
100K	F	3-0	7-0	1-3/4	НМ	_	-	1	HM	04	8/49.2	7/49.2	1/49,1	1
1001	ОН	14-0	14-0	PER MEG	STI	_	-	PER MEG	STI	01	11/492	9 \$ 10/492	-	_
100M	ОН	14-0	14-0	PER MEG	STI	_	-		STI	01	11/492	9 \$ 10/492	-	_
100N		14-0	14-0		STI	_	_		STI	Ø1	11/492	9 \$ 10/492	-	
101	EG	3-0	7-0			GI = 2	_			@1 	36/192	26/492	1/491	1.2
	- -	3-0	7-0	1-3/4	SCUID		_	2		02	2//91	20/45.2	1//91	1,2
102		3-0	0 0	1-3/4	SCUID		_	2		20	2/43.	2/45.	1//91	- 1, 2
102	NG	3-0	7-0	1-3/4	SCUD	- GL_1	_	2		10	2/43.	2/A91	1/401	_
1/02 /		3-0		1-2/4			-	2		<i>n</i> o	2/401	2/AJ.	1/101	-
		20		1 2/4		-	-	2		11	2/43.	2/43.	1//01	-
		2-0		1-2/4		-	-	2		14	2/43.	2/43.	1/43.	-
		2-0		1-2/4			-	2		20	2/43.	2/43.	1/43.	-
		3-0		1-3/4			-	2			2/49.	2/43.	1/43.	-
	NG	3-0 2 0		1-3/4			-	2			2/49.	2/43.	1/49.1	-
108	NG -	3-0	1-0	1-3/4	SCUD	GL-I	-	2	HM	09	2/49.1	2/49.1	1/49.1	-
108A	F	3-0	7-0	1-3/4	SCWD	-	-	2	HM	21	2/49.1	2/49.1	1/A9.1	-
109	F	3-0	7-0	1-3/4	SCWD	-	-	2	HM	22	2/49.1	2/49.1	1/49.1	-
110	NG	3-Ø	0-٦	1-3/4	SCWD	GL-1	-	2	HM	10	2/A9.1	2/49.1	1/49.1	-
111	NG	3-Ø	0-٦	1-3/4	SCWD	GL-1	-	2	HM	10	2/49.1	2/49.1	1/49.1	-
112	NG	3-Ø	0-٦	1-3/4	SCWD	GL-1	-	2	HM	10	2/49.1	2/49.1	1/49,1	-
113	NG	3-Ø	0-٦	1-3/4	SCWD	GL-1	-	2	HM	10	2/49.1	2/49.1	1/49.1	-
114	HG	3-Ø	0-٦	1-3/4	SCWD	GL-1	-	2	HM	24	2/49.1	2/49.1	1/49.1	-
114A	F	3-Ø	0-٦	1-3/4	SCWD	-	-	2	HM	23	2/49.1	2/49.1	1/49.1	-
114B	F	3-Ø	0-٦	1-3/4	HM	-	-	1	HM	28	8/A9.2	7/49.2	1/49.1	-
115	F	3-Ø	0-٦	1-3/4	SCWD	-	-	2	HM	Ø9	2/49.1	2/49.1	1/49.1	-
116	F	3-Ø	0-٦	1-3/4	SCWD	-	-	2	HM	23	2/49.1	2/49.1	1/49.1	-
דוו	NG	3-Ø	0-٦	1-3/4	SCWD	GL-1	45 Min.	2	HM	11	2/A9.1	2/49.1	1/49.1	-
118	F	3-Ø	0-٦	1-3/4	SCWD	-	20 Min.	2	ΗM	12	2/A9.1	2/A9.1	1/A9.1	-
119	F	3-Ø	0-٦	1-3/4	SCWD	-	20 Min.	2	НM	12	2/A9.1	2/49.1	1/A9.1	-
12Ø	F	3-Ø	7-Ø	1-3/4	SCWD	-	20 Min.	2	НМ	12	2/A9.1	2/A9.1	1/A9.1	-
121	F	3-Ø	7-Ø	1-3/4	SCWD	-	20 Min.	2	HM	14	2/A9.1	2/A9.1	1/A9.1	-
122	F	3-Ø	7-Ø	1-3/4	SCWD	-	20 Min.	2	HM	12	2/A9.1	2/A9.1	1/A9.1	-
123	F	3-Ø	0-٦	1-3/4	SCWD	-	20 Min.	2	HM	14	2/A9.1	2/49.1	1/A9.1	-
124	F	3-Ø	7-Ø	1-3/4	SCWD	-	20 Min.	2	HM	12	2/A9.1	2/A9.1	1/A9.1	-
125	F	3-Ø	7-Ø	1-3/4	SCWD	-	20 Min.	2	HM	14	2/A9.1	2/A9.1	1/A9.1	-
126	F	3-Ø	۵-۲	1-3/4	SCWD	-	20 Min.	2	HM	12	2/A9.1	2/A9.1	1/A9.1	-
127	F	3-Ø	7-Ø	1-3/4	SCWD	-	45 Min.	2	HM	15	2/A9.1	2/A9.1	1/A9.1	-
128	F	3-Ø	۵-۲	1-3/4	SCWD	_	20 Min.	2	HМ	13	2/A9.1	2/A9.1	1/A9.1	-
128A	F	3-Ø	7-Ø	1-3/4	SCWD	-	-	2	НМ	ΓØ	2/A9.1	2/49.1	1/A9.1	-
129	F	4-0	7-Ø	1-3/4	SCWD	_	45 Min.	2	HM	27	2/A9.1	2/49.1	1/A91	-
130	F	3-0	7-0	1-3/4	SCUD	-	-	2	HM	08	2/491	2/49.1	1/491	-
131	F	3-0	7-0	1-3/4	SCUD	-	-	2		09	2/491	2/491	1/291	-
132		4-0	7-0	1-3/4	ЦM	_	-	3		26	12/292	7/492	1/291	-
133	G	4-0	5-4			_	_	-		BY MEG		6/493	-	3
134	NG	3-0	יב ח-ר	1_3/4		GI -1	_	2		05	3/193	2/293	1/291	
		3.0	T-0	1_2/7				1		22	2/107	7//02	1//01	
125		2.0		1_2/4			- /5 Min			20	2/143.2	2//01	1//01	-
		20		1 2/4				2		25	2/43.	2/43.	1/43.	-
1250		2-0		1-2/4			40 111h.	2		25	2/43.	2/43.	1/43.	-
		2-0 2-0		1-5/4			-			<i>2</i> /4	0/43.2	1/43.2	1/43.	
126		2-0		1-2/4			-	2		00	2/43.	2/43.	1/43.	-
136A		<u> </u>	1-0	1-3/4	HIT	GT-1	-	2	 [™]	60	2/AJ.3	2/43.3	1/AJ.	

	ACCESSORY BUILDING DOOR SCHEDULE-PHASE 4 U.N.O.													
MARK	TYPE	WIDTH	HEIGHT	THICK	MAT	GLZ	LABEL	FRAME	FMAT	HDW-SET	HEAD	JAMB	SILL	REMARKS
AB-101	F	3-Ø	7-Ø	1-3/4	HМ	-	-	1	HM	3Ø	9/49.3	8/A9.3	1/49.1	PHASE 1
AB-101A	F	3-Ø	7-Ø	1-3/4	HМ	-	-	2	НМ	29	2/49.1	2/A9.1	1/49.1	-
AB-101B	F	3-Ø	7-Ø	1-3/4	HМ	-	-	2	НМ	29	2/49.1	2/49.1	1/49.1	-
AB-102	F	3-Ø	7-Ø	1-3/4	НМ	-	-	1	НМ	3Ø	9/49.3	8/A9.3	1/49.1	-
AB-102A	CD	12-0	8-0	PER MFG	STL	-	-	PER MFG	STL	Øl	11/A9.2	9/A9.2	-	-
AB-103	F	3-Ø	7-Ø	1-3/4	НМ	-	-	1	НМ	3Ø	9/49.3	8/A9.3	1/49,1	-
AB-103A	CD	12-0	8-Ø	PER MFG	STL	-	-	PER MFG	STL	ØI	11/A9.2	9/49.2	-	-
AB-201	F	3-Ø	٦-∅	1-3/4	НМ	-	-	1	НМ	31	9/A9.3	8/49.3	7/49.3	-

GENERAL NOTES:

ALL WIDTH AND HEIGHT INFORMATION SHOWN ARE NOMINAL DIMENSIONS FOR REFERENCE ONLY. ACTUAL DIMENSIONS SHALL BE ADJUSTED FOR PROPER CLEARANCES, SHIM SPACES AND CONSTRUCTION TOLERANCES INTHE CONTRACTOR AND SUBMITTED FOR APPROVAL. SILL HEIGHTS ABOVE F.F. ARE TYPICAL CONDITIONS U.O.N. ALL WINDOWS WITHIN 4'-0" OF ADJACENT DOORS ARE TO HAVE TEMPERED GLASS. COORD W/ MECHANICAL FOR DOOR UNDERCUTS.

'S' SUFFIX AT HEAD, JAMB & SILL DETAIL REFERENCES IN DOOR SCHEDULE DENOTES SIMILAR CONDITION.

DOOR SCHEDULE REMARKS:

CARD READER, SEE TELECOM DWGS REMOTE DOOR RELEASE, SEE TELECOM DWGS 3. WIDTH IS ROUGH OPENING WIDTH

GLAZING TYPES:

TYPE GL-1 FULLY TEMPERED GLAZING, SEE SPECIFICATIONS. TYPE GL-2: LAMINATED GLAZING, SEE SPECIFICATIONS. TYPE IG-1: SEALED INSULATING GLASS, SEE SPECIFICATIONS

REVISIONS NO. DESCRIPTION

PH	ASE	DRAWN	CHECKED	DATE
SCH	IEMATIC DESIGN			11/Ø5/21
DES	BIGN DEVELOPMENT			12/17/21
60	% DOCUMENTS			Ø2/11/22
90%	6 CONSTRUCTION DOCUMENTS			Ø3/31/22
CO	NSTRUCTION DOCUMENTS			Ø5/16/22
BID	SET			@7/@1/22



2211 THOMAS DR , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832

DRAWN CHECKED DATE



Å9.

PROJECT:

PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT

BAY COUNTY, FLORIDA SHEET TITLE:

DOOR SCHEDULE AND FRAME ELEVATIONS

SHEET NUMBER:





304-PCB Replacement Fire Station 31\A9-2.dwg, 7/1/2022 9:05:35 AM, Shane Boullie, Adobe PDF, 1

	SLIPT-FACE CMU VENEER
	FLASHING
	WEEPS FLUID APPLIED
	AIR BARRIER
	PEEL AND STICK AT CORNER
	STL. LOOSE LINTEL PAINT UNDERSIDE C STL. SEE SPECS
	(3) LC
	SLIPT-FACE CMU VENEER FLUID
	APPLIED VAPOR RETARDER
	PEEL AND STICK AT
	3/4
	BACKER ROD AND SEALANT, CONT. AT PERIMETER
	$2 \frac{AL}{2}$
	BACKER ROD AND SEALANT, CONT. AT
	METAL FLASHING WITH HEMMED EDGE, EXTEND
	PEEL AND STICK AT CORNER
	FLUID APPLIED AIR
	BARRIER SPLIT FACE CMU
	SCALE





4-PCB Replacement Fire Station 31\A10.1.dwg, 7/1/2022 9:06:12 AM, Shane Boullie, Adobe PDF, 1:

TRUCTU	RAL NOTES:	3.11.5
1. GEN	ERAL COORDINATE ALL INFORMATION CONTAINED IN THIS STRUCTURAL SET WITH THE	3.11.6
1.1.	ARCHITECTURAL, MECHANICAL, ELECTRICAL, PLUMBING AND OTHER TRADES. CONTACT BTK	0.11.7
1.2.	SEE ARCHITECTURAL DRAWINGS FOR FINISHES.	3.11.8
1.3.	REVIEW OF SUBMITTALS AND/OR SHOP DRAWINGS BY THE STRUCTURAL ENGINEER DOES NOT RELIEVE THE CONTRACTOR OF THE RESPONSIBILITY TO REVIEW AND CHECK SHOP DRAWINGS BEFORE SUBMITTAL TO THE STRUCTURAL ENGINEER. THE CONTRACTOR REMAINS SOLELY	3.11.9 3.11.1
	RESPONSIBLE FOR ERRORS AND OMISSIONS ASSOCIATED WITH THE PREPARATION OF SHOP DRAWINGS AS THEY PERTAIN TO MEMBER SIZES, DETAILS, AND DIMENSIONS SPECIFIED IN THE CONTRACT DOCUMENTS.	3.12. 3.13.
1.4. 1.4.1.	SHOP DRAWINGS REQUIRED: CONCRETE REINFORCEMENT/EMBEDS FABRICATION DRAWINGS	4. MAS
1.4.2. 1 4 3	STRUCTURAL STEEL - FABRICATION/ERECTION DRAWINGS	4.1.
1.4.4.	LIGHT GAUGE METAL STUD FRAMING (EXTERIOR) - ENGINEERED	4.2.
1.4.5.	ICF - LAYOUT DRAWINGS	4.3.
1.5. 1.5.3.	SUBMITTALS REQUIRED: SOILS COMPACTION REPORTS.	4.4.
1.5.4. 1.5.5.	CONCRETE MIX DESIGN. MORTAR MIX DESIGN	4.4.1. 4.4.2.
1.5.6. 1.5.7	CONCRETE TEST REPORTS. MASONRY UNIT - PRODUCT DATA	4.5.
1.5.8.	METAL DECK - PRODUCT DATA	4.6.
1.5.9. 1.6.	CONTRACTOR IS ALSO RESPONSIBLE FOR MEANS, METHODS, TECHNIQUES, SEQUENCES, AND	4.7. 4.8.
1.7.	PROCEDURES OF CONSTRUCTION. SITE AND CONSTRUCTION SHALL COMPLY WITH OSHA OR EM385 AT ALL TIMES.	
1.8.	SITE SHALL BE MAINTAINED IN A CLEAN, ORDERLY, AND SAFE MANNER AT ALL TIMES.	5. INSU 5.1.
SOIL	S	5.2.
2.1. 2.2	CONTRACTOR SHALL FOLLOW THE GEOTECH REPORT PERFORMED BY NOVA TESTING.	5.3.
 ∠.	TESTING ONCE THE EXISTING BUILDING IS DEMOLISHED. FOUNDATION DESIGN IS SUBJECT TO	5.4.
2.3.	CHANGE BASED ON THE FINDINGS OF THE SECONDARY SUBSURFACE GEOTECHNICAL REPORT. CONTRACTOR SHALL VERIFY SOIL IS FREE OF MUCK, CLAY, SILT, ORGANICS, OR OTHER	
2.4.	UNSUITABLE MATERIALS. CONTRACTOR SHALL REMOVE ALL LAYERS OF SOIL THAT CONTAIN ORGANICS.	5.5.
2.5.	CONTRACTOR SHALL VERIFY FLOOD ZONES AND WATER TABLES AND ASSURE FINISH FLOOR IS	5.6.
	CONTRACTOR SHALL VERIFY AND COMPLY WITH ALL BUILDING SETBACKS AND EASEMENTS.	5.7.
<i>7</i> . 8.	CONTRACTOR SHALL VERIFY ALL SOILS ARE COMPACTED TO 98% MAXIMUM DENSITY	5.8.
2.9.	(MODIFIED PROCTOR). ALL SOILS UNDER SLABS SHALL BE TREATED FOR TERMITES.	5.9.
2.10.	STRUCTURAL BACKFILL AND FILL SOILS COMPLY WITH GEOTECHNICAL REPORT FOR STRUCTURAL FILL OR FILL REQUIRED FOR	5.10.
	SITE DEVELOPMENT. THIS SHOULD BE PLACED IN LOOSE LIFTS NOT EXCEEDING 12 INCHES	5.11.
	THICKNESS WHEN COMPACTED BY THE USE OF A VIBRATORY DROM ROLLER. THE LIFT THICKNESS SHOULD BE REDUCED TO 8 INCHES IF THE ROLLER OPERATES IN THE STATIC	5.12.
	COMPACTION EQUIPMENT IS USED, THE LIFT THICKNESS SHOULD BE FURTHER REDUCED	
	TO 6 INCHES. STRUCTURAL FILL IS DEFINED AS A NON-PLASTIC, INORGANIC, GRANULAR SOIL HAVING LESS THAN 10 PERCENT MATERIAL PASSING THE NO. 200 MESH SIEVE AND	6. STRI 6.1.
	CONTAINING LESS THAN 4 PERCENT ORGANIC MATERIAL. TYPICALLY, THE MATERIAL SHOULD EXHIBIT MOISTURE CONTENTS WITHIN +2 PERCENT OF THE MODIFIED PROCTOR	6.2
	OPTIMUM MOISTURE CONTENT (ASTM D 1557) DURING THE COMPACTION OPERATIONS.	
	MODIFIED PROCTOR MAXIMUM DRY DENSITY (ASTM D 1557) HAVE BEEN ACHIEVED WITHIN	
2.10.2.	THE FILL UNDER THE APPARATUS BAYS SHALL CONSIST OF AN 8" FDOT CRUSHED LIME	
	ROCK, CRUSHED CONCRETE, OR GRADED AGGREGATE ROAD BASE. COMPACTED IN TWO LIFTS, AND PROVIDE A MODULUS SUBGRADE REACTION OF 300 PCI MINIMUM.	6.3.
200 3.1	<u>CRETE</u> CAST IN PLACE CONCRETE SHALL BE IN ACCORDANCE WITH ACL318-14	
3.2.	CONCRETE SHALL HAVE THE FOLLOWING MINIMUM COMPRESSIVE BREAK STRENGTH AFTER 28	6.4.
3.2.1.	COLUMN FOOTINGS 3000 PSI	
3.2.2. 3.2.3.	WALL FOOTINGS3000 PSIICF WALLS4000 PSI450 PSI FLEXURAL	6.5.
3.2.4. 3.2.5	SLAB4500 PSI500 PSI FLEXURALSLAB (APPARATUS BAY)5000 PSI600 PSI FLEXURAL	
3.3.	CONCRETE MIX DESIGN SHALL BE SUBMITTED TO BTK ENGINEERING FOR APPROVAL PRIOR TO	6.6
3.4.	CONCRETE SHALL HAVE FIELD CYLINDERS TAKEN AND TESTED IN ACCORDANCE WITH ACI 318.	0.0.
3.5.	(SEE ICF WALLS FOR ADDITIONAL REQUIREMENTS) CONCRETE SLUMP SHALL BE BETWEEN 3 AND 6 INCHES AT THE TIME OF PLACEMENT.	6.7.
5.0.	CONCRETE COVER SHALL BE IN ACCORDANCE WITH SECTION 7.7.1, ACIS 16-14.	
:	#6 THROUGH #18 BARS 2"	6.8.
:	#5 BAR W31 OR D31 WIRE OR SMALLER $1\frac{1}{2}$	
	CONCRETE NOT EXPOSED TO EARTH OR WEATHER	
:		6.9.
	-OOTINGS AND GRADE BEAMS SHALL HAVE 3" REGARDLESS OF THE BAR SIZE OR THE DIRECTION TO THE EDGE.	0.40
3.7.	ALL FOUNDATION REINFORCING BARS SHALL BE GRADE 60, ASTM616 AND LAP 36 BAR DIAMETERS.	6.10.
3.8.	ALL CAST IN PLACE NOT ASSOCIATED WITH THE FOUNDATION SHALL BE GRADE 60, ASTM615 AND HAVE A CLASS, B TENSION LAP SPLICE	6.11.
3.9.	WELDED WIRE REINFORCEMENT SHALL OF DIAGED IN THE HODED ONE HALE OF THE OLDED ONE HALE OF THE OLDED ONE	6.12.
3.10.	WELDED WIRE REINFORCEMENT SHALL BE PLACED IN THE UPPER ONE HALF OF THE SLAB ON SUPPORTS (NOT PULLED INTO PLACE.)	6.13.
3.11. 3.11.1.	PROPORTION NORMAL-WEIGHT CONCRETE MIXTURE AS FOLLOWS: PORTLAND CEMENT: ASTM C 150, TYPE I/II, NO FLY ASH PERMITTED	
3.11.2. 3 11 3	MINIMUM COMPRESSIVE STRENGTH: 3000, 4500, AND 5000 PSI AT 28 DAYS. MAXIMUM WATER-CEMENTITIOUS MATERIALS RATIO: 0.51	
3.11.4.	SLUMP LIMIT: 3" TO 6".	

- NORMAL-WEIGHT AGGREGATES: ASTM C 33, CLASS 3M COARSE AGGREGATE OR BETTER,
- GRADED. MAXIMUM COARSE-AGGREGATE SIZE: 3/4" MAXIMUM UNLESS NOTED.
- FINE AGGREGATE: FREE OF MATERIALS WITH DELETERIOUS REACTIVITY TO ALKALI IN CEMENT.
- AIR CONTENT: 4 PERCENT, PLUS OR MINUS 1.5 PERCENT AT POINT OF DELIVERY FOR 3/4-INCH (38-MM) NOMINAL MAXIMUM AGGREGATE SIZE.
- NO CALCIUM CHLORIDE PERMITTED.
- 10. HIGH EARLY SET ADMIXTURES ARE ENCOURAGED IF THEY ARE NON CORROSIVE TO THE REINFORCEMENT.

FINISH TEXTURE SHALL BE VERIFIED WITH ARCHITECT. CONCRETE SURFACE SHALL BE UNIFORM AND STRAIGHT AND LEVEL TO WITHIN 1/8" IN A TEN FOOT STRAIGHT EDGE.

ONRY

ALL CMU BELOW FINISH FLOOR SHALL BE POURED SOLID WITH 3000 PSI GROUT CONFORMING TO ASTM C476.

CONCRETE MASONRY WORK SHALL CONFORM TO ACI 530, BUILDING CODE REQUIREMENTS FOR MASONRY STRUCTURES AND ACI 530.1 SPECIFICATION FOR MASONRY STRUCTURES. CONCRETE MASONRY SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 1,500 PSI. MORTAR SHALL COMPLY WITH THE BUILDING CODE REQUIREMENTS FOR CONCRETE MASONRY AND SHALL BE.

WALLS BELOW GRADE

WALLS ABOVE GRADE

TYPE M TYPE S

REINFORCED CONCRETE MASONRY UNITS SHALL BE GROUTED WITH 3,000 PSI COURSE GROUT CONFORMING TO ASTM C476.

WALL HORIZONTAL REINFORCEMENT SHALL BE 9 GA TRUSS TYPE AT 16" O/C. ALL WALL REINFORCEMENT SHALL BE LAPPED A MINIMUM OF 48 BAR DIAMETER. MASONRY CONTROL JOINTS SHALL BE LOCATED BY ARCHITECT AT NATURAL BREAKS OR BENDS IN THE STRUCTURE AND 20'-0" O/C MAX.

JLATED CONCRETE FORM WALLS

INSULATED CONCRETE FORMS FOR THIS SET OF DRAWINGS WERE BASED ON NURDUA WALL SYSTEM. ANY SUBSTITUTION SHALL BE APPROVED BY BOTH THE ARCHITECT AND ENGINEER. CONTRACTOR SHALL PROVIDE SHOP DRAWINGS FOR THE COMPLETED FORM SYSTEM. CONTRACTOR SHALL PROCURE THE SERVICES OF AN INDEPENDENT INSPECTOR TO CERTIFY THE PLACEMENT OF THE REINFORCEMENT PRIOR TO POURING CELLS WITH CONCRETE. DUE TO THE LACK OF VISUAL INSPECTION AFTER THE CONCRETE HAS BEEN POURED EACH TRUCK OF CONCRETE SHALL HAVE FIELD CYLINDERS TAKEN AND TESTED IN ACCORDANCE WITH ACI 318.

CONCRETE FORM MANUFACTURER SHALL SUBMIT IN WRITING THE MAXIMUM POUR HEIGHT BASED ON THE FORMS SUBMITTED.

VERTICAL AND HORIZONTAL V JOINTS ON EXPOSED WALLS SHALL BE LOCATED PER ARCHITECT'S DRAWINGS AND TO A DEPTH NOT TO EXCEED 1".

COLD JOINTS SHALL BE PREPPED AND PATCHED PER ARCHITECT'S DRAWINGS.

ALL NON-INSULATED CONCRETE SHALL BE SEALED. INCLUDING BLOCK OUTS FOR EXTERIOR ATTACHMENTS.

CONTRACTOR SHALL VERIFY WITH THE EACH TRADE CONTRACTOR EACH'S REQUIREMENT FOR BLOCK-OUTS OR INSULATION REMOVAL FOR ATTACHMENT REINFORCEMENT SHALL BE TIED OR SPLICED PER MANUFACTURER'S INSTALLATION

INSTRUCTIONS. FORMS SHALL HAVE AN INTEGRAL VERTICAL EXTERIOR ATTACHMENT POINTS AT A MAXIMUM

SPACING OF 8" O/C.

FORMS SHALL PROVIDE FOR CORNER AND OPENING TRIM ATTACHMENTS AT LOCATIONS THAT WILL RECEIVE HARDIE BOARD COVERING.

UCTURAL STEEL

STRUCTURAL STEEL SHALL BE DETAILED, FABRICATED AND ERECTED ACCORDING TO AISC 360-10 "SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS."

STEEL FABRICATOR'S SPECIALTY ENGINEER SHALL DESIGN ANY CONNECTIONS NOT DETAILED IN THESE DOCUMENTS. THE SPECIALTY ENGINEER SHALL BE REGISTERED IN THE PROJECT STATE. CONNECTION DESIGN CALCULATIONS AND STEEL DETAILER'S SHOP DRAWINGS SHALL BE SIGNED AND SEALED BY THE SPECIALTY ENGINEER AND SUBMITTED TO THE STRUCTURAL ENGINEER FOR REVIEW. SUBMIT SHOP DRAWINGS PREPARED IN ACCORDANCE WITH AISC MANUAL "DETAILING FOR STEEL CONSTRUCTION", LATEST EDITION. STEEL

STRUCTURAL STEEL WIDE FLANGE SHAPES SHALL CONFORM TO ASTM A992, 50 KSI. STRUCTURAL STEEL SHAPES, PLATES, ANGLES, AND CHANNELS SHALL CONFORM TO ASTM A36 UNLESS NOTED OTHERWISE. STRUCTURAL TUBING SHALL CONFORM TO ASTM A500. GRADE B. FY = 46 KSI, UNLESS NOTED OTHERWISE. ANCHOR BOLTS SHALL CONFORM TO ASTM F1554-07a GRADE 36 UNLESS NOTED OTHERWISE.

BOLTS SHALL CONFORM TO ASTM A325, TYPE 3 (CORROSION RESISTANCE), 34-INCH DIAMETER MINIMUM. UNLESS NOTED OTHERWISE. BOLTS IN BEARING CONNECTIONS SHALL BE DESIGNATED TYPE N, TENSIONED, SNUG-TIGHT AS DEFINED BY AISC. ALL OTHER BOLTS SHALL **BE PRE-TENSIONED.**

USE PRE-QUALIFIED WELDED JOINTS AS PER AISC, AND AWS D1.1 "STRUCTURAL WELDING CODE." USE ONLY CERTIFIED WELDERS; ALL ELECTRODES SHALL CONFORM TO AWS A5 GRADE E70XX. BARE ELECTRODE AND GRANULAR FLUX SHALL CONFORM TO AWS A5, F70 AWS FLUX CLASSIFICATION. MINIMUM WELD SIZE TO BE 3/16" FILLET WELD, U.N.O.

CUTS, BOLTS, COPING, ETC. REQUIRED FOR WORK OR OTHER TRADES SHALL BE SHOWN ON THE SHOP DRAWINGS AND MADE IN THE SHOP. CUTS OR BURNING HOLES IN STRUCTURAL STEEL MEMBERS IN THE FIELD WILL ONLY PERMITTED ON AN INDIVIDUAL, REVIEWED BASES. SHOP CONNECTIONS NOT SPECIFICALLY DETAILED ON THE DRAWINGS MAY BE WELDED OR BOLTED. FIELD CONNECTIONS NOT SPECIFICALLY DETAILED ON THE DRAWINGS SHALL BE BOLTED, WHERE POSSIBLE.

STRUCTURAL DRAWINGS SHALL BE USED IN CONJUNCTION WITH ARCHITECTURAL AND MECHANICAL DRAWINGS AND DRAWINGS RELATED TO OTHER TRADES. CONTRACTOR SHALL BE RESPONSIBLE TO CHECK AND COORDINATE DIMENSIONS, CLEARANCES, ETC. WITH THE WORK OF OTHER TRADES. THE STRUCTURAL STEEL CONTRACTOR SHALL PROVIDE FRAMING AROUND OPENINGS IN ROOF AS INDICATED IN THE MECHANICAL AND ARCHITECTURAL DRAWINGS.

STRUCTURAL STEEL CONTRACTOR SHALL COORDINATE THE BOTTOM OF BASE PLATE ELEVATION WITH THE TOP OF CONCRETE ELEVATION. IN CASE OF CONFLICT, THE CONTRACTOR SHALL MAKE ALLOWANCE IN HIS BID FOR MORE STRINGENT REQUIREMENTS. STRUCTURAL STEEL SHALL BE PRIMED AND PAINTED IN ACCORDANCE WITH THE PROJECT SPECIFICATIONS.

ALL STRUCTURAL STEEL FOR THIS PROJECT SHALL BE HOT DIPPED GALVANIZED MINIMUM OF G90 COATING.

ALL WELDS OR FIELD CUTTING AND FITTING SHALL BE GROUND CLEAN AND COATED WITH COLD APPLIED GALVANIZING.

ALL STRUCTURAL STEEL TO BE GROUNDED TO PEOJECT ELECTRICAL GROUND.

EAVE HEIGHT TOWER **APPARATUS BAY** OFFICE SPACE AUX BUILDING ROOF SLOPE COLLATERAL/GRAVITY ROOF LIVE LOAD (REDUCIBLE) FIRST FLOOR LIVE LOAD AUX BUILDING MEZZ LIVE LOAD APPARATUS BAY (AASHTO)

TABLE OF CONTENTS

STRUCTURAL NOTES

COMPONENT AND CLADDING WIND MAP

FOUNDATION PLAN

ROOF BEARING PLAN

ROOF FRAMING PLAN

ACCESSORY BUILDING

STRUCTURAL WALL SECTIONS

STRUCTURAL WALL SECTIONS

STRUCTURAL WALL SECTIONS

STRUCTURAL WALL SECTIONS

STRUCTURAL WALL REINFORCEMENT

STRUCTURAL CONCRETE DETAILS

STRUCTURAL WALL DETAILS STRUCTURAL WALL DETAILS

STRUCTURAL STAIR DETAILS

APPLICABLE CODES

Florida Building Code, Building (FBC-B) Minimum Design Loads For Building and Other Structures

45'-2" 23'-4" 10'-8" 23'-4" 3:12 10 PSF 20 PSF 100 PSF (OFFICE) 125 PSF HL-93

> S0.1 S0.2 S1.1 S1.2 S1.3 S1.4 S2.1 S2.2 S2.3 S2.4 S2.5 S3.1 S3.2 S3.3 S3.4

2020 ASCE 7-16

> REVISIONS DESCRIPTION ND. DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21 BK **BK** 02/11/22 60% DOCUMENTS BK **BK** 03/31/22 90% CONSTRUCTION DOCUMENTS BK **BK** 05/16/22 CONSTRUCTION DOCUMENTS BK **BK** 07/01/22 BID SET 2211 THOMAS DR. , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS Commission Number: 21804 STRUCTURAL ENGINEERING BTK ENGINEERING SERVICES, INC. 1101 BRICKYARD ROAD, CHIPLEY, FL 32428 ENGINEERING BUSINESS #9613 BRADLEY T. KENT P.E. FLORIDA REGISTRATION #59384 PHONE: (850) 676-4140 EXODUS 4:11 PR0JECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: STRUCTURAL NOTES SHEET NUMBER:



Design Criteria		Building Specifications	
Design Velocity (ult 3 sec gust)	160.00 mph	Building Depth	82.67 ft
Building Category	П	Building Width	160 ft
Risk Category	IV	Eave Height	22.67 ft
Wind Exposure	С	Mean Roof Height	26 ft
Enclosure Classification	Enclosed	Roof Slope	3 on 12
Internal Pressure Coefficient	±0.18	End Zone Width	8.267 ft
Base Pressure	53.09 psf	Velocity (ASD 3 sec gust)	124 mph
Component and Cladding Pressu	res (Effective Wind Area < 10 soft)	MRES Design Pres	sures

Compone	nt and Clade	ding Pressu	res (Effecti	ve Wind Area	i≤ 10 sqft)	MRF	S Design Pr	essures	97
Zone	GCp	GCpi	qh psf	(GCp+GC pi)	qh[(GCp+ GCpi)] psf	Building Section	Zone	Inward psf	Outward psf
1+	0.5	0.18	53.09	0.68	36.10	Wall (Windward)	1	37.70	-33.45
1-	-0.9	-0.18	53.09	-1.08	-57.34	Roof (Windward)	2	0.00	-46.19
2+	0.5	0.18	53.09	0.68	36.10	Roof (Leeward)	3	0.00	-35.04
2-	-1.7	-0.18	53.09	-1.88	-99.82	Wall (Leeward)	4	0.00	-33.45
20	-2.2	0	53.09	-2.2	-116.80	Gable (Windward)	5	30.79	0.00
3+	0.5	0.18	53.09	0.68	36.10	Gable (Leeward)	6	0.00	-24.95
3-	-2.1	-0.18	53.09	-2.28	-121.05	Wall (Windward)	1E	52.03	-35.04
30	-3.7	0	53.09	-3.7	-196.44	Roof (Windward)	2E	0.00	-66.37
4+	1	0.18	53.09	1.18	62.65	Roof (Leeward)	3E	0.00	-46.19
4-	-1.1	-0.18	53.09	-1.28	-67.96	Wall (Leeward)	4E	0.00	-43.54
5+	1	0.18	53.09	1.18	62.65	Gable (Windward)	5E	41.94	0.00
5.	-14	-0.18	53.09	-1.58	-83.89	Gable (Leeward)	6E	0.00	-32 39

NOTE: DESIGN PRESSURES ARE ULTIMATE DESIGN PRESSURES AND MAY BE REDUCED BY A FACTOR OF 0.6 TO CONVERT TO ALLOWABLE STRESS PRESSURES.

WALLS



- 8'-6" -

MAIN BUILDING

Design Criteria		Building Specifications		
Design Velocity (ult 3 sec gust)	160.00 mph	Building Depth	40 ft	
Building Category	Ш	Building Width	40 ft	
Risk Category	IV	Eave Height	23.4 ft	
Wind Exposure	С	Mean Roof Height	30 ft	
Enclosure Classification	Partial	Roof Slope	3 on 1	12
Internal Pressure Coefficient	±0.55	End Zone Width	4 ft	
Base Pressure	54.72 psf	Velocity (ASD 3 sec gust)	124 mph	L
Component and Cladding Pressur	as (Effective Wind Area < 10 catt)	MRES Design Pres	euree	_

Compone	nt and Clade	ding Pressu	res (Effection	ve Wind Area	l≤ 10 sqft)	MRF	S Design Pr	essures	
Zone	GCp	GCpi	qh psf	(GCp+GC pi)	qh[(GCp+ GCpi)] psf	Building Section	Zone	Inward psf	Outward psf
1+	0.5	0.55	54.72	1.05	57.45	Wall (Windward)	1	59.09	-54.72
1-	-0.9	-0.55	54.72	-1.45	-79.34	Roof (Windward)	2	0.00	-67.85
2+	0.5	0.55	54.72	1.05	57.45	Roof (Leeward)	3	0.00	-56.36
2-	-1.7	-0.55	54.72	-2.25	-123.11	Wall (Leeward)	4	0.00	-54.72
20	-2.2	0	54.72	-2.2	-120.38	Gable (Windward)	5	51.98	0.00
3+	0.5	0.55	54.72	1.05	57.45	Gable (Leeward)	6	0.00	-45.96
3-	-2.1	-0.55	54.72	-2.65	-145.00	Wall (Windward)	1E	73.87	-56.36
30	-3.7	0	54.72	-3.7	-202.45	Roof (Windward)	2E	0.00	-88.64
4+	1	0.55	54.72	1.55	84.81	Roof (Leeward)	3E	0.00	-67.85
4-	-1.1	-0.55	54.72	-1.65	-90.28	Wall (Leeward)	4E	0.00	-65.11
5+	1	0.55	54.72	1.55	84.81	Gable (Windward)	5E	63.47	0.00
5-	-1.4	-0.55	54.72	-1.95	-106.70	Gable (Leeward)	6E	0.00	-53.62

NOTE: DESIGN PRESSURES ARE ULTIMATE DESIGN PRESSURES AND MAY BE REDUCED BY A FACTOR OF 0.6 TO CONVERT TO ALLOWABLE STRESS PRESSURES.

WALLS





WM-2 WIND MAP S0.2 SCALE: 1/16"=1'



REVISIONS ND. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21
 BIK
 BIK
 02/11/22

 BIK
 BIK
 03/31/22

 BIK
 BIK
 05/16/22

 BIK
 BIK
 07/01/22
 60% DECUMENTS 90% CONSTRUCTION DOCUMENTS CONSTRUCTION DOCUMENTS BID SET 2211 THOMAS DR. , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 Commission Number: 21804 STRUCTURAL ENGINEERING BTK ENGINEERING SERVICES, INC. 1101 BRICKYARD ROAD, CHIPLEY, FL 32428 ENGINEERING BUSINESS #9613 BRADLEY T. KENT P.E. FLORIDA REGISTRATION #59384 인 PHONE: (850) 676-4140 EXODUS 4:11 PR0JECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: WIND CRITERIA SO





















sealed. Digital copies should be verified for valid certification.



FR-1 ROOF FRAMING PLAN S1.3 SCALE: 1/8" = 1'-0"

HAVE METAL DECK SOFFITS. PROVIDE 3.625 18GA METAL STUD BLOCKING AT 48" O/C BETWEEN TRUSS WHEN DECK RUNS WITH TRUSSES



verified for valid certification.























-- 6 13/16"

- #3 STIRRUP AT 6" O/C

ALTERNATE

RD-1 JAMB REINFORCEMENT DETAIL S2.5 SCALE: 1" = 1'-0"









- #3 STIRRUP AT 6" O/C

0.0





#5 REBAR BENT AT 90°



CONTRACTOR TO PROVIDE 3.625 18 GA METAL STUD BLOCKING BETWEEN TRUSSES AT 48" O/C FOR ATTACHMENT WHEN TRUSSES







DAY USE AREA (10'-8" WALL HEIGHT)

APPARATUS BAY AND ACCESSORY BUILDING (WALL HEIGHT 23'-4")

TOWER (WALL HEIGHT 45'-2")

WD-1 WALL SCHEDULE DETAILS S3.3 SCALE: 1" = 1'-0"

MASONRY VENEER LOOSE LINTEL SCHEDULE

OPENING	LINTEL	BEARING EACH END
6' OR LESS	L4x3-1/2x1/4	6"
OVER 6' TO 10'-0"	L6x4x3/8	8"

NOTES:

- 1. FOR OPENINGS 6'-0" AND LARGER, PROVIDE SOLID MASONRY JAMB UNDER LINTEL EACH SIDE OF OPENING.
- 2. FOR OPENINGS LARGER THAN 10'-0", PROVIDE (1) 5/8"Øx1'-0" ANCHOR BOLT EACH END OF LINTEL.
- 3. ALL STEEL ANGLES USED FOR BRICK VENEER LOOSE LINTELS SHALL BE HOT DIPPED GALVANIZED IN ACCORDANCE WITH ASTM A123.







H4

→ 6" → / 3/8" GALVANIZED EMBED





REVISIONS ND. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT 12/17/21

 BLK
 BLK
 02/11/22

 BLK
 BLK
 03/31/22

 BLK
 BLK
 05/16/22

 BLK
 BLK
 07/01/22

 60% DOCUMENTS 90% CONSTRUCTION DOCUMENTS CONSTRUCTION DOCUMENTS BID SET 2211 THOMAS DR., STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS Commission Number: 21804 STRUCTURAL ENGINEERING BTK ENGINEERING SERVICES, INC. 1101 BRICKYARD ROAD, CHIPLEY, FL 32428 ENGINEERING BUSINESS #9613 BRADLEY T. KENT P.E. FLORIDA REGISTRATION #59384 으 PHONE: (850) 676-4140 EXODUS 4:11 PRDJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: STRUCTURAL DETAILS SHEET NUMBER: 23,3





	LEGEN	D		
<u>AHU-1</u>	EQUIPMENT TAG	<u>s</u> 1	<u>6R-1</u> 00	AIR DEVICE TAG. TOP LINE INDICATES TYPE OF DEVICE BOTTOM LINE INDICATES AIRFLOW IN CFM
$\left(\begin{array}{c}1\\M3\end{array}\right)$	DETAIL TAG ("1" INDICATES IDENTIFICATION NUMBER; "M3" INDICATES THE SHEET NUMBER DRAWN ON)	<u>(2</u> 1	<u>)SR-1</u> 00	AIR DEVICE TAG. TOP LINE INDICATES TYPE OF DEVICE BOTTOM LINE INDICATES AIRFLOW IN CFM (2) INDICATES TYPICAL OF TWO DEVICES
	SHEET NOTE		TYP TEMP Sa	TYPICAL TEMPERATURE
$\mathbf{i} \in \mathbf{I}$	SUPPLY DUCT SECTION POSITIVE PRESSURE		RA FA	RETURN AIR EXHAUST AIR
	RETURN OR EXHAUST DUCT NEGATIVE PRESSURE		MA OA	MIXED AIR OUTDOOR AIR
AxB	RECTANGULAR DUCT SIZE ("A" INDICATES SIDE SHOWN; "B" INDICATES SIDE NOT SHOWN)		TA EF CD	TRANSFER AIR EXHAUST FAN CEILING DIFFUSER
\rightarrow	INDICATES RISE IN ELEVATION OF DUCT.		RG EG	RETURN GRILLE EXHAUST GRILLE
	EXTERNALLY INSULATED DUCTWORK		ER CREF	EXHAUST REGISTER CEILING ROOF EXHAUST EAN
	INTERNALLY INSULATED DOUBLE WALL SPIRAL DUCTWORK		AHU	INDOOR AIR HANDLING UNIT
	EXTERNALLY INSULATED ROUND FLEXIBLE DUCTWORK		CU	OUTDOOR CONDENSING UNIT
	DUCT ELBOW WITH TURNING VANES			TEMPERATURE AND HUMIDITY SENSOR WITH SET POINT ADJUSTMENT, "1" INDICATES UNIT
	RADIUSED DUCT ELBOW		S	CONTROLLED DUCT MOUNTED SMOKE
	FLEXIBLE DUCT CONNECTION	\oslash	FD	FLOOR DRAIN
_ (-∐ ►	UC	UNDERCUT DOOR ³ / ₄ "
<u> </u>	MANUAL VOLUME BALANCING DAMPER	-√>	DG	18"x18" DOOR GRILLE WITH AUXILLARY
	MOTORIZED DAMPER		AFF■	Mounting frame. Ittus Model CT-700L Above Finished Floor
FD FD	FIRE DAMPER WITH ACCESS DOORS		FD FD	FIRE DAMPER AT CEILING DIFFUSER OR GRILLE.
BD	BACKDRAFT DAMPER		XFR	TRANSFER AIR
	TEE WITH TURNING VANES		DDC	DIRECT DIGITAL CONTROLS
	TRANSITION		IRH	INFRARED RADIANT HEATER
<u></u>			TC	TIME CLOCK
	FLEX DUCT TAKE OFF WITH MVD SIZE EQUALS DIFFUSER NECK SIZE UNLESS NOTED OTHERWISE	S	WG	SIDE WALL GRILLE WITH OPPOSED BLADE BALANCING DAMPER
	BRANCH DUCT TAKEOFF WITH MVD		\$	EQUIPMENT SWITCH
			CF	CEILING FAN

	100% OUTSIDE AIR UNIT SCHEDULE																					
UN	IT BASIS OF	OAU	CU	CONFIGURATION		/ OA	ESP	FAN	DEHUMIDIFICATI	ON				HEATING		OAU ELECTRICA	4L		CU ELECTRICAL			NOTES
OAU/	CU DESIGN	MODEL	MODEL		(CFM)	(CFM)	(IN. WC)	(HP)	EAT° (DB/WB)	LAT° (DP)	TOTAL (BTUH)	SENSIBLE (BTUH)	ISMRE	EAT (DB)	KW	VOLTS/PHASE	MCA	MOP	VOLTS/PHASE	MCA	MOP	
1	DESERT AIRE	QV08	RC5S051CK	SPLIT	990	990	0.5	4.14	84.0/80.0	50.7	117200	43600	8.9	25	14	208/3	61	70	208/3	7.4	15	1,2,3,4,5,6,7,8,9

1. ISMRE IS INTEGRATED SEASONAL MOISTURE REMOVAL EFFICIENCY.

HOT GAS REHEAT AND LIQUID SUBCOOLING. PROVIDE SCR ELECTRIC HEAT.

2. ESP DOES NOT INCLUDE FILTER, CASING, ETC. 3. PROVIDE 100% OUTSIDE AIR DEHUMIDIFICATION UNIT WITH PROVIDE SINGLE POINT POWER CONNECTION.

6. PROVIDE REFRIGERANT SHOP DRAWINGS.

								SP	LIT SYSTE	M HEAT PL	JMP	SCH	EDULI										
UNIT	BASIS OF	MODEL	SA	OA	ESP	FAN	COOLING					HEATING				SUPPL.	AHU ELECTRICA	۹L		HP ELECTRICAL	-		NC
AHU/HP	DESIGN	(AHU/HP)	(CFM)	(CFM)	(IN.H20)	(HP)	MAT° (DB/WB)	OAT° (DB/WB)	TOTAL (BTUH)	SENSIBLE (BTUH)	SEER	MAT ° (DB)	OAT ° (DB)	TOTAL (BTUH)	HSPF	HEAT (KW)	VOLTS/PHASE	MCA	MOP	VOLTS/PHASE	MCA	MOP	
1	TRANE	TEM6A0B24H21/4TWR5019H1	675	175	0.53	0.33	71.9/60.7	95.0/78.0	15700	13400	15.00	70.0	20	7500	8.85	2.88	208/1	21	25	208/1	12	20	1,2,
2	TRANE	TEM6A0B30H21/4TWR5030H1	1010	300	0.41	0.33	71.6/61.2	95.0/78.0	21600	18100	15.25	70.0	20	3600	9.50	2.88	208/1	21	25	208/1	17	25	1,2,
3	TRANE	TEM6A0B30H21/4TWR5030H1	965	410	0.32	0.33	71.7/60.3	95.0/78.0	21900	19400	15.25	70.1	20	2600	9.50	2.88	208/1	21	25	208/1	17	25	1,2,
4	TRANE	TEM6A0C36H31/4TWR5036H1	1135	105	0.73	0.50	72.0/60.7	95.0/78.0	25000	21900	15.00	69.9	20	8900	9.50	2.88	208/1	23	25	208/1	18	30	1,2,
5	TRANE	TEM6A0B24H21/4TWR5024H1	865	105	0.34	0.33	74.6/63.1	95.0/78.0	22800	17900	15.00	64.7	20	12900	9.50	5.76	208/1	38	40	208/1	14	25	1,2,

1. PROVIDE 2 " 30% FILTERS AND FILTER HOUSING SHOWN IN 4. PROVIDE CONTROL KIT TO INCLUDE BLOWER CONTACTOR OR

DETAILS. 2. EFFICIENCIES IN ACCORDANCE WITH ARI STANDARD

210/240. 3. ESP DOES NOT INCLUDE FILTER, CASING, ETC.

- STARTER, TRANSFORMER, ELECTRIC HEATER INTLERLOCKS. ELECTRICAL SERVICE SHALL BE A SINGLE POINT OF CONNECTION.
- 5. PROVIDE THERMAL EXPANSION VALVES. 6. DIRECT DRIVE AHU FAN.

SEQUENCE OF OPERATION

AHU/HP

GENERAL : PROVIDE PROGRAMMABLE THERMOSTAT FOR EACH UNIT. THERMOSTAT SHALL BE CAPABLE OF PERFORMING THE SEQUENCE OUTLINED BELOW. THERMOSTAT SHALL ACCEPT AN EXTERNAL OCCUPIED SCHEDULE FROM THE ELECTRONIC MECHANICAL EQUIPMENT TIME CLOCK.

OCCUPIED MODE: THE THE INDOOR FAN SHALL RUN CONTINUOUSLY. THE HP SHALL CYCLE TO MAINTAIN SPACE TEMPERATURE. THE ELECTRIC HEAT SHALL OPERATE A 2ND STAGE OF HEAT ONLY WHEN OUTDOOR TEMPERATURE IS BELOW 40°F. THE SETPOINT FOR COOLING SHALL BE 75° F ADJUSTABLE. THE SETPOINT FOR HEATING SHALL BE 70° F ADJUSTABLE.

UNOCCUPIED MODE: THE INDOOR FAN AND HP SHALL CYCLE TO MAINTAIN SETPOINT TEMPERATURE. THE SETPOINT FOR COOLING SHALL BE 85° F ADJUSTABLE. THE SETPOINT FOR HEATING SHALL BE 60°F ADJUSTABLE.

OVERRIDE MODE: THE OVERRIDE MODE SHALL PLACE THE SYSTEM IN OCCUPIED MODE FOR 1 HOUR.

IRH

PROVIDE SINGLE STAGE PROGRAMMABLE THERMOSTAT. OCCUPIED SETPOINT = 65°F (ADJUSTABLE) UNOCCUPIED SETPOINT = 50°F (ADJUSTABLE). WHEN IRH-1,2,3, OR 4 IS RUNNING, EF-7 SHALL RUN TO PROVIDE ADEQUATE VENTILATION.

OAU/CU-1

THE FOLLOWING SEQUENCE OF OPERATIONS SHALL BE PROVIDED BY THE UNIT MANUFACTURER:

GENERAL: PROVIDE FACTORY MOUNTED AND WIRED DIGITAL CONTROLLER CAPABLE OF PERFORMING THE SEQUENCE OUTLINED BELOW. STARTING AND STOPPING OF EQUIPMENT SHALL BE BY A UNIT MOUNTED DIGITAL CONTROLLER. WITH THE DIGITAL CONTROLLER IN THE AUTO POSITION, THE UNIT SHALL BE STARTED AUTOMATICALLY BY THE OCCUPANCY SIGNAL FROM THE ELECTRONIC TIME CLOCK AND ALL CONTROLS ACTIVATED SUBJECT TO THE FIRE ALARM RELAY, SAFETIES, AND OVERLOADS. THE CONTROLLER SHALL BE CAPABLE OF 7 DAY PROGRAMMING WITH OCCUPIED AND UNOCCUPIED SCHEDULING. INTERLOCKED EXHAUST FANS SHALL RUN CONTINUALLY DURING OCCUPIED TIMES.

OCCUPIED MODE DEHUMIDIFICATION: THE MOTORIZED OA DAMPER SHALL OPEN TO THE BALANCED POSITION AND THE INDOOR FAN SHALL RUN CONTINUOUSLY. THE UNIT SHALL DEHUMIDIFY SUPPLY AIR ANYTIME THE OUTDOOR AIR DEWPOINT IS ABOVE 55°F. THE UNIT SHALL REHEAT SUPPLY AIR TO SPACE CONDITIONS WITH VARIABLE HOT GAS REHEAT, MAINTAINING LEAVING AIR TEMPERATURE OF 72°F.

OCCUPIED MODE HEATING: WHEN THE OUTDOOR AIR TEMPERATURE FALLS BELOW 50°F, THE UNIT SHALL MODULATE SCR ELECTRIC STRIP HEAT TO MAINTAIN 70°F LEAVING AIR TEMPERATURE. THE ELECTRIC HEAT SHALL BE LOCKED OUT DURING COOLING.

SUPPLY AIR RESET-TEMPERATURE BASED: AT THE START OF EACH PERIOD OF OCCUPANCY, THE UNIT CONTROLLER SHALL SET SUPPLY AIR TEMPERATURE TO 60F. THE UNIT CONTROLLER SHALL MONITOR THE ASSOCIATED AHU'S IN THE AREAS SERVED BY THE OAU. UPON A CALL FOR HEATING FROM MORE THAN 10% OF THE UNITS SERVED BY THE OAU, THE UNIT CONTROLLER SHALL RESET OAU DISCHARGE AIR TEMPERATURE UP IN 5F INCREMENTS UNTIL THERE ARE FEWER THAN 10% OF THE UNITS SERVED WITH HEATING DEMAND OR A MAXIMUM SUPPLY AIR TEMPERATURE OF 75F HAS BEEN REACHED.

SUPPLY AIR RESET-HUMIDITY BASED: THE UNIT CONTROLLER SHALL MONITOR THE ASSOCIATED AHU'S IN THE AREAS SERVED BY EACH OAU. UPON A RISE IN AVERAGE RELATIVE HUMIDITY ABOVE 65% (ADJUSTABLE), THE CONTROLLER SHALL RESET OAU DISCHARGE AIR TEMPERATURE UP IN 5F INCREMENTS UNTIL THE CALL FOR DEHUMIDIFICATION HAS BEEN SATISFIED OR A MAXIMUM SUPPLY AIR TEMPERATURE OF 75F HAS BEEN REACHED.

UNOCCUPIED MODE: THE MOTORIZED OA DAMPER SHALL CLOSE AND THE UNIT SHALL NOT OPERATE.

EF-6 AND 9:

PROVIDE WALL MOUNTED THERMOSTAT WITH SETPOINT AT 95°F ADJUSTABLE.

AIR PURIFICATION EQUIPMENT SCHEDULE

ZONE	SUPPLY	OA	PRESS.	BASIS OF	MODEL	QUANTITY	ELECTRICAL		NOTES
AHU	CFM	CFM	IN. W.C.	DESIGN			VOLTS/PHASE	WATTS	
5	835	105	0.05	GPS	DM48-AC]	24/1	60	1,2,3,4

1. GPS = GLOBAL PLASMA SOLUTIONS.

PROVIDE BASIS OF DESIGN OR EQUAL BY PLASMA AIR SOLUTIONS OR AIRGENICS

BI-POLAR IONIZATION SYSTEMS REQUIRING PERISHABLE GLASS TUBES ARE NOT ACCEPTABLE

4. MANUFACTURER MUST PASS UL-867-2007 OZONE CHAMBER TESTING BY EITHER UL OR ETL

1000% OUTCIDE AID UNIT COLEDIJIE

7. PROVIDE DIRECT DRIVE FAN WITH ECM MOTOR.

8. MAXIMUM WEIGHT: 965 LBS. 9. PROVIDE MOTORIZED OUTSIDE AIR DAMPER.

COOLING CAPACITY IS NET AND DOES NOT INCLUDE FAN HEAT. 8. PROVIDE UNIT MOUNTED CIRCUIT BREAKER FOR INDOOR AIR

HANDLERS. 9. PRETREATED OUTSIDE AIR.

- 1. ALL DUCT DIMENSIONS ARE NET INSIDE.
- CONNECTIONS.
- SEE SPECIFICATIONS.
- ACCESS.
- 5. ISOLATED.
- SHEET METAL.
- REQUIRING TOOLS.
- EQUIPMENT LOCATED ABOVE CEILING.
- UTILITIES.
- SHALL NOT CROSS WALKING PATH TO INDOOR EQUIPMENT.
- 11. ALL LOW VOLTAGE CONTROLS SHALL BE ROUTED IN CONDUIT.

- RATED OR NOT.
- CLEAR DIMENSIONS.
- INSIDE CLEAR DIMENSIONS.

- 5.
- 6.
- DUCT AND LIGHTS.

GENERAL NOTES

VERIFY COLLAR SIZES ON ALL AIR TERMINALS, EQUIPMENT OUTLETS AND INLETS, TRANSITION DUCTWORK AS NECESSARY. EXTERNALLY INSULATE TRANSITIONS AT EQUIPMENT

3. FIELD VERIFY CLEAR SPACE AVAILABLE, ROUTING PATH, AND CONFLICTS WITH STRUCTURE AND THE WORK OF OTHER TRADES PRIOR TO FABRICATING DUCTWORK. PROVIDE OFFSETS IN DUCTWORK AS REQUIRED. WHETHER SPECIFICALLY INDICATED ON DRAWINGS OR NOT. SUBMIT SHOP DRAWINGS ON DUCTWORK LAYOUT PRIOR TO COMMENCING WORK. MAINTAIN CLEARANCE AROUND ALL LIGHT FIXTURES AS REQUIRED TO REMOVE AND SERVICE FIXTURES. COORDINATE WITH ROOF TRUSSES/STRUCTURE. PRESSURE TEST ALL DUCTWORK FOR LEAKS.

CONTRACTOR SHALL INSTALL ALL EQUIPMENT, PIPING, AND DUCTWORK SUCH THAT MANUFACTURERS' RECOMMENDED CLEARANCES ARE MET FOR ALL ACCESS PANELS, MOTORS, FANS, BELTS, FILTERS AND AIR INTAKES. CONDENSATE LINES SHALL BE CLEAR OF FILTER RACK

PROVIDE DUCT FLEX CONNECTIONS & VIBRATION ISOLATION FOR ALL UNITS NOT INTERNALLY

6. ALL SUPPLY, RETURN, EXHAUST AND OUTSIDE AIR INTAKE DUCTWORK SHALL BE GALVANIZED

ALL AHU AND OAU FILTERS SHALL BE OF A READILY AVAILABLE SIZE, OF DISPOSABLE TYPE, AND BE ACCESSIBLE WITHOUT THE USE OF SCREWS OR OTHER MECHANICAL DEVICES

8. PROVIDE ACCESS PANELS IN CEILINGS AS REQUIRED FOR MAINTENANCE AND ADJUSTMENT OF

9. CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFYING LOCATION OF ALL EQUIPMENT AND

10. ROUTE REFRIGERANT LINES AND CONDENSATE ALONG WALLS OF MECHANICAL ROOMS. LINES

12. ALL WORK SHALL COMPLY WITH 7TH EDITION (2020) FLORIDA BUILDING CODE.

DUCTWORK NOTES

1. ALL ROUND FLEXIBLE DUCT SHALL BE FLEXMASTER TYPE 8M ACOUSTICAL FLEX OR ENGINEER APPROVED EQUAL. MAXIMUM LENGTH OF ANY FLEXIBLE DUCT RUNOUT SHALL BE 5'-O". WHERE LENGTH REQUIRED EXCEEDS 5'-0", INSTALL EXTERNALLY INSULATED ROUND SNAPLOCK DUCT FOR BALANCE OF DISTANCE TO SPIN-IN TAP AT MAIN DUCT TRUNK.

2. SEAL ALL DUCT PENETRATIONS OF WALLS AIRTIGHT, REGARDLESS OF WHETHER WALLS ARE FIRE

3. ALL SUPPLY AIR DUCTWORK FROM AHU'S (EXCEPT TAKEOFFS TO SUPPLY AIR DIFFUSERS) SHALL BE LOW PRESSURE RECTANGULAR, SMACNA STATIC PRESSURE CLASS 2" W.G., SEAL CLASS A, EXTERNALLY INSULATED UNLESS OTHERWISE INDICATED. DUCT SIZES INDICATED ARE INSIDE

4. ALL RETURN AIR DUCTWORK SHALL BE LOW PRESSURE RECTANGULAR, SMACNA STATIC PRESSURE CLASS 2" W.G., SEAL CLASS A, EXTERNALLY INSULATED UNLESS OTHERWISE INDICATED. DUCT SIZES INDICATED ARE INSIDE CLEAR DIMENSIONS.

ALL OUTSIDE AIR INTAKE DUCTWORK SHALL BE LOW PRESSURE RECTANGULAR, SMACNA STATIC PRESSURE CLASS 2" W.G., SEAL CLASS A, EXTERNALLY INSULATED. DUCT SIZES INDICATED ARE

STANDARD EXHAUST AIR DUCTWORK SHALL BE LOW PRESSURE RECTANGULAR, SMACNA STATIC PRESSURE CLASS 1/2" W.G., SEAL CLASS A, EXTERNALLY INSULATED.

7. WHEN ROUTING DUCTWORK OVER LIGHTS, PROVIDE A MINIMUM 6" CLEARANCE BETWEEN



R	VISIONS									
NO.	DESCRIPTION	DRAWN	CHECKED	DATE						
PH	ASE	DRAWN	CHECKED	DATE						
SCH	HEMATIC DESIGN			11/Ø5/21						
DE	BIGN DEVELOPMENT	КАЈ	DNW	12/17/21						
60	% DOCUMENTS	KAJ/KMM	DNW	Ø2/11/22						
909	CONSTRUCTION DOCUMENTS	KMM	DNW	@3/31/22						
co	NSTRUCTION DOCUMENTS	KMM	DNW	Ø5/16/22						
BID	9 SET	KMM	DNW	Ø7/Ø1/22						
	ARCHITECTS PANAMA CITY BEACH, FL PHONE: (850) 236-9832 Commission Number: 21804									
	4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115	DRD RING Certificate of Authoriz Natford, PE Florida I	zation: 27825 icense 58208							
PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT										
SHEET TITLE: HVAC LEGEND, SCHEDULES, AND NOTES										
SHEE	ET NUMBER:		M	D.1						

						FA	N SC	HEDULE			
UNIT	TYPE	CFM	MAX.	ESP	MAX.	SONES/db	BASIS OF	MODEL	CONTROL	ELECTRICAL	NOTES
			RPM	(IN. H20)	POWER	(MAX.)	DESIGN			VOLTS/PHASE	
EF-1	WALL	130	1333	0.2	0.02 HP	3.2	GREENHECK	SE1-8-440-VG	DEDICATED SWITCH	115/1	1,2,3,4,5
EF-2	WALL	1770	1179	0.2	1/2 HP	7.3	GREENHECK	SE1-16-426-VG	DEDICATED SWITCH	115/1	1,2,3,4,5
EF-3	WALL	1770	1179	0.2	1/2 HP	7.3	GREENHECK	SE1-16-426-VG	DEDICATED SWITCH	115/1	1,2,3,4,5
EF-4	ROOF	1310	1311	1.0	3/4 HP	11.6	ACCUREX	XCUBE-140-7	INTERLOCK WITH KITCHEN HOOD	115/1	1,2,3,4,6,7,8,9
EF-5	INLINE	435	1125	0.5	84 W	1.5	GREENHECK	CSP-A700-VG	INTERLOCK WITH OAU-1	115/1	1,2,3,4,5
EF-6	WALL	420	1009	0.2	1/4 HP	4.0	GREENHECK	SE1-12-432-VG	THERMOSTAT	115/1	1,2,3,4,5
EF-7	WALL	640	1551	0.2	1/6 HP	7.3	GREENHECK	SE1-10-440-VG	INTERLOCK WITH INFRARED HEATERS	115/1	1,2,3,4,5
EF-8	INLINE	80	1180	0.2	1/15 HP	2.0	GREENHECK	SQ-70-VG	INTERLOCK WITH AHU-5	115/1	1,2,3,4,5
EF-9	WALL	420	1009	0.2	1/4 HP	4.0	GREENHECK	SE1-12-432-VG	THERMOSTAT	115/1	1,2,3,4,5
SF-1	INLINE	350	562	0.15	1/2 HP	0.6	GREENHECK	SQ-120-VG	INTERLOCK WITH TURNOUT DRYER	115/1	1,2,3,4,5
SF-2	ROOF	1045	627	0.25	1/4 HP	0	ACCUREX	XKSFB-109-H15-01	INTERLOCK WITH KITCHEN HOOD	115/1	1,2,3,4,6,7,8

1. PROVIDE DISCONNECT 2. PROVIDE SOLID STATE SPEED CONTROLLER.

3. PROVIDE BACK DRAFT DAMPER

4. PROVIDE THERMAL OVERLOAD

5. PROVIDE DIRECT DRIVE FAN 6. PROVIDE BELT DRIVEN FAN WITH ROTARY BELT

TENSIONER

8. PROVIDE FAN WITH FLORIDA PRODUCT APPROVAL 9. PROVIDE INSULATED HOUSING

7. PROVIDE ALUMINUM ROOF CURB

	CEILING FAN SCHEDULE										
UNIT	TYPE	MAX.	MAX.	dBA	BASIS OF	MODEL	CONTROL	ELECTRICAL	NOTES		
		RPM	POWER	(MAX.)	DESIGN			VOLTS/PHASE	_		
CF-1	CF	148	1 HP	< 5 5	BIG ASS FAN	BASIC 6 10 FT	VARIABLE SPEED WALL SWITCH	115/1	1,2,3,4		
CF-2	CF	148	1 HP	< 5 5	BIG ASS FAN	BASIC 6 10 Ft	VARIABLE SPEED WALL SWITCH	115/1	1,2,3,4		
CF-3	CF	148	1 HP	< 5 5	BIG ASS FAN	BASIC 6 10 FT	VARIABLE SPEED WALL SWITCH	115/1	1,2,3,4		
CF-4	CF	300	107W	-	GLOBAL INDUSTRIAL	OUTDOOR 5 FT	VARIABLE SPEED WALL SWITCH	120/1	1,2		
CF-5	CF	300	107W	-	GLOBAL INDUSTRIAL	OUTDOOR 5 FT	VARIABLE SPEED WALL SWITCH	120/1	1,2		
1. COI	COLOR TO BE SELECTED BY ARCHITECT. 3. FAN SHALL BE INTERLOCKED TO SHUT DOWN UPON FI										

2. PROVIDE WALL MOUNTED SPEED CONTROL SWITCH TO FIT IN STANDARD SINGLE SWITCH SPACE.

ACTIVATION. 4. MOUNT AT 19 FT A.F.F.

		IN	FRA	RED	HEA	FER SCH	IED	ULE							
	UNIT BASIS OF MODEL BTUH MOUNT REFLECTOR ELECTRICAL GAS NOTES														
	DESIGN				TAILIN	VOLIS/PHASE	AMPS								
1	SPACERAY	DK40	40000	A.F.F.	30°	115/1	0.4	NATURAL	1,2,3,4,5,6						
2	SPACERAY	DK40	40000	20 FT A.F.F.	30°	115/1	0.4	NATURAL	1,2,3,4,5,6						
3	SPACERAY	DK40	40000	20 FT A.F.F.	30°	115/1	0.4	NATURAL	1,2,3,4,5,6						
4	SPACERAY	DK40	40000	20 FT A.F.F.	30°	115/1	0.4	NATURAL	1,2,3,4,5,6						

1. PROVIDE ASSYMETRIC REFLECTOR.

2. HEATERS SHALL BE EQUIPPED WITH A 24-VOLT DIRECT SPARK IGNITION WITH AUTOMATIC 100% SHUTOFF SYSTEM.

3. HEATER CONTROL SHALL INCLUDE A PRESSURE SWITCH DESIGNED FOR COMPLETE UNIT SHUTOFF.

4. HEATERS SHALL BE EQUIPPED WITH AN ON-LINE DIAGNOSIS MONITORING LIGHT SYSTEM. 5. HEATERS SHALL OPERATE UNDER NEGATIVE PRESSURE.

6. HEATER EXHAUST SHALL INCLUDE A DRAFT INDUCER, THE DRAFT INDUCER SHALL BE PERMANENTLY LUBRICATED, TOTALLY ENCLOSED, SHIELDED, FAN COOLED AND HAVE A HEAVY DUTY BALL BEARING MOTOR.

	KITCHEN HOOD SCHEDULE													
UNIT	TYPE	ACCUREX MODEL	DIMENSIONS LxWxH	FILTER FACE VELOCITY FT/MIN	EXHAUST CONNECTION	EXHAUST CFM	EXHAUST S.P.	SUPPLY PLENUM LxWxH	SUPPLY CONNECTION	SUPPLY CFM	SUPPLY S.P.	NOTES		
H-1 (CANOPY	XBDW	72x42x24	131	13x9	1310	0.435	84x14x10	16x10(2)	1045	0.26	1,2,3		
1. PROV SUPPI MOUN WITH	(IDE WET) RESSION (NTED IN U REMOTE	CHEMICAL FIRE SYSTEM JTILITY CABINET PULL STATION.	2. 3.	PROVIDE EXTERNAL AIR CURTAIN SUPPLY PLENUM. PROVIDE TWO LIGHTS IN HOOD.										

	MINI SPLIT SYSTEM HEAT PUMP SCHEDULE											
UNIT	BASIS OF DESIGN	MODEL	NOMINAL COOL CAPACITY (BTUH)	DESIGN COOLING OUTDOOR TEMP DB	SEER	NOMINAL HEAT CAPACITY (BTUH)	DESIGN HEATING OUTDOOR TEMP DB	HSPF	VOLTS/PHASE	MCA (AMPS)	MOP (AMPS)	NOTES
MHP-1	MITSUBISHI	MUY-GL12NA	12000	95.0	23.1	N/A	N/A	N/A	208/1	9	15	1,2,3,4
MHP-2	MHP-2 MITSUBISHI PUZ-HA36NKA 33600 95.0 18.5 38000 25 10.0 208/1 24 35 1,2,3											
1. NOMINAL COOLING CAPACITIES ARE BASED ON INDOOR 3. EFFICIENCY VALUES FOR EER. IEER. AND COP ARE BASED												

COIL EAT OF 80/67°F (DB/WB), OUTDOOR OF 95°F (DB) 2. NOMINAL HEATING CAPACITIES ARE BASED ON INDOOR

COIL EAT OF 70°F (DB), OUTDOOR OF 43°(WB)

ON AHRI 1230 TEST METHOD FOR MIXTURE OF DUCTED AND NON-DUCTED INDOOR UNITS.

4. PROVIDE COOLING-ONLY OUTDOOR UNIT.

					MINI SPI	LIT SYSTE	M AIR HA	NDLINC	UNIT SCH	EDULE					
UNIT	BASIS OF		TYPE	NOMINAL COOL	DESIGN COOLING	DESIGN COOLING	CAPACITY (BTUH)	NOMINAL HEAT	DESIGN HEATING	DESIGN HEATING	AIRFLOW		FAN	FAN FLA	NOTES
	DESIGN	MODEL		CAPACITY (BTUH)	EAT °F DB/WB	COOLING TOTAL	COOLING SENSIBLE	CAPACITY (BTUH)	TOTAL CAPACITY (BTUH)	EAT °F DB	(CFM)	VOLTS/PHASE	(WATTS)	(AMPS)	
WM-1.1	MITSUBISHI	MSZ-GL12NA	WALL MOUNT	12000	75.4/46.2	3700	3700	N/A	N/A	N/A	201	FED FROM HP	30	0.76	1,2,3,4,5,6,7,8,9
WM-2.1	MITSUBISHI	РКА-А36КА7	WALL MOUNT	33600	73.0/61.0	27200	26400	38000	0	70	730	FED FROM HP	56	0.57	1,2,3,4,5,6,7,8

1. NOMINAL COOLING CAPACITIES ARE BASED ON INDOOR COIL EAT OF 80/67°F (DB/WB), OUTDOOR OF 95°F (DB)

2. NOMINAL HEATING CAPACITIES ARE BASED ON INDOOR

COIL EAT OF 70°F (DB), OUTDOOR OF 43°(WB)

4. DESIGN CAPACITY IS NET CAPACITY FOR INSTALLATION ACCOUNTING FOR 65 FT PIPE RUN LENGTHS, ETC.

3. DESIGN COOLING CONDITIONS ARE AT 95°F AMBIENT;

5. CALCULATE REFRIGERANT LINE SIZES BASED UPON FINAL

DESIGN HEATING CONDITIONS ARE AT 26°F AMBIENT

	_
ON FIRE ALARM	-

VENTILATION SCHEDULE					
SPACE TYPE	VENTILATION CFM/S.F.	VENTILATION CFM/PERSON			
CORRIDOR	0.06	0			
CONFERENCE ROOM	0.06	5			
OFFICE	0.06	5			
RECEPTION	0.06	5			
RESTROOM	0	70/FIXTURE			
SHOWER	0	50/FIXTURE			
DWELLING UNIT	0.06	5			
STORAGE	0.12	0			
VEHICLE STORAGE	0.75	0			
LAUNDRY	0.12	5			
KITCHEN	0.12	7.5			

VENTILATION RATES HAVE BEEN REDUCED IN ACCORDANCE WITH ASHRAE STANDARD 62.1-2016, INDOOR AIR QUALITY PROCEDURE.

AIR DEVICE SCHEDULE						
MARK	MAX AIRFLOW CFM	AIR DEVICE SIZE	DUCT CONNECTION SIZE	TITUS MODEL		
CD-1 CFM	80	12x12	бØ	TDC-AA		
CD-2 CFM	245	245 12x12 8Ø 1				
CD-3 CFM	350	12x12	10Ø	TDC-AA		
SWG-1 CFM	205	8×6	8x6	272RS		
RG, EG, SG, TG, RF	R,ER					
xx-1 CFM	450	12x12	12x12	350FL		
xx-2 CFM	1705	22x22	22x22	3 5 OF L		

NOTES: 1. MAX NC=20

PROVIDE 2x2 LAY IN PANEL FOR AIR DEVICES IN LAY IN CEILINGS.

3. PROVIDE BEVELED MOUNTING FRAME FOR CEILING DIFFUSERS IN HARD

CEILINGS. 4. PROVIDE FLAT MOUNTING FRAME FOR GRILLES LOCATED IN HARD CEILINGS. 5. PROVIDE ALUMINUM BIRD SCREEN FOR SOFFIT GRILLES.

DEHUMIDIFIER SCHEDULE								
UNIT	BASIS OF	MODEL	BLOWER	WATER REMOVAL	SOUND RATING	POWER		NOTES
DH	DESIGN		(CFM)	(PINTS/DAY)		VOLTS/PHASE	WATTS	
1	ULTRA-AIRE	MD33	155	33	46 dBA	120/1	324	1,2,3

1. PROVIDE 1/2" WASHABLE AIR FILTER. 2. PROVIDE INTERNALLY MOUNTED CONTROLS BEHIND

TAMPER-PROOF COVER 3. WATTS AND WATER REMOVAL BASED ON 80°F AND 60%RH.

LOUVER SCHEDULE							
MARK	AIRFLOW CFM (MAX)	LOUVER SIZE (WxH) INCHES	FREE AREA FT ² (MIN)				
LVR-1 CFM	1770	36x36	4.5				
LVR-2 CFM	1770	36x36	4.5				
LVR-3 CFM	435	24x12	0.63				
LVR-4 CFM	990	52x16	1.8				

ALUMINUM, WIND-DRIVEN RAIN RESISTANT, STATIONARY LOUVER WITH BIRDSCREEN AND FLORIDA PRODUCT APPROVAL. 2. FINISH TO BE SELECTED BY ARCHITECT FROM MANUFACTURER'S

1. PROVIDE GREENHECK MODEL 'EHV-901D' (OR EQUAL) EXTRUDED

STANDARD COLORS.

WITH ARCHITECT.

FIELD PIPING LAYOUT.

6. EXPOSED (INDOOR OR OUTDOOR) REF PIPING SHALL BE HARD DRAWN COPPER.

7. PROVIDE HARD WIRED REMOTE THERMOSTAT.

8. PROVIDE DISCONNECT.

9. PROVIDE COOLING-ONLY INDOOR UNIT.

3. PROVIDE LOUVERS WITH FLANGED FRAME. VERIFY FRAME TYPE





SHEET NOTES COORDINATE CEILING FAN SWITCH WITH ELECTRICAL DRAWINGS. PROVIDE THREE LVR-1'S PLACED HIGH AND THREE LVR-2'S PLACED LOW. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION. (3) FAN SHALL BE PLACED TO EXHAUST AIR ABOVE LOWER ROOF. REFER TO ARCHITECTURAL DRAWINGS FOR ELEVATION. A PROVIDE SEIHO MODEL SFZC VENT CAP WITH BACKDRAFT DAMPER FOR DRYER EXHAUST. 5 ROUTE REFRIGERANT PIPING ALONG WALL OF MECHANICAL ROOM TO OAU-1 6 PROVIDE UTILITY BOX IN WALL TO ALLOW DRYER DUCT TO RISE UP IN WALL CAVITY. BOX TO HAVE CONNECTION FOR 4" ROUND DUCT. BOX TO BE 22 GAUGE ALUMINIZED STEEL. DRYERBOX MODEL 425 OR APPROVED EQUAL. DUCT FROM DRYER SHALL BE RIGID. 7 ROUTE CONDENSATE TO NEAREST HUB DRAIN. REFER TO PLUMBING DRAWINGS. 8 REFRIGERANT PIPING SHALL BE ROUTED IN PVC CHASE PER DETAIL 2/M2.2 AND SHALL RISE UP INSIDE MECHANICAL ROOM AND CONTINUE TO INDOOR UNIT. REVISIONS NO. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT DNW 12/17/21 KAJ KAJ/KMM DNW **02/11/22** 60% DOCUMENTS 90% CONSTRUCTION DOCUMENTS KAJ/KMM DNW **Ø3/31/22** KMM CONSTRUCTION DOCUMENTS DNW 05/16/22 KMM DNW **@7/@1/22** BID SET 2211 THOMAS DR, STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS commission Number: 21804 WATFORD ENGINEERING 4452 Clinton Street, Marianna, Florida 32446 Florida Certificate of Authorization: 27825 850.526.3447 Project Number: 2021-115 David N Watford, PE Florida License 58208 PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: HVAC FLOOR PLAN SHEET NUMBER:



SHEET NOTES 1 INSTALL BARRIER BARS BEHIND LOUVER. BARRIER BARS SHALL BE 1-1/8"Ø STEEL BARS WELDED IN A GRID PATTERN WITH MAXIMUM OPENING OF 30 SQ. INCHES. (2) INSTALL LOUVER AT 8'-0" A.F.F. COORDINATE WITH ARCHITECTURAL DRAWINGS. (3) INSTALL LOUVER AT 18'-6" A.F.F. COORDINATE WITH ARCHITECTURAL DRAWINGS. REVISIONS NO. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/05/21 DESIGN DEVELOPMENT DNW 12/17/21 KДJ KAJ/KMM DNW **02/11/22** 60% DOCUMENTS 90% CONSTRUCTION DOCUMENTS KMM DNW Ø3/31/22 KMM DNW **Ø5/16/22** CONSTRUCTION DOCUMENTS KMM DNW **@1/@1/22** BID SET 2211 THOMAS DR , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS commission Number: 21804 WATFORD ENGINEERING 4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115 David N Watford, PE Florida License 58208 PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: ACCESSORY BUILDING

HVAC FLOOR PLANS

SHEET NUMBER:

M1.2





RE	VISIONS	I		
NO.	DESCRIPTION	DRAWN	CHECKED	DATE
				D.4**
FH 6C		URAUN	CHECKED	
501	Hematic Design			11/05/21
				12/11/21
909				Ø2/11/22 Ø2/21/22
				05/51/22 05/16/02
BIC				ØT/01/22
	2211 THC PANAMA PHONE: Commission	MAS DI A CITY (850) n Number:	R, STE BEACH 236-98 21804	100), FL 32
	WATFC ENGINEEI 4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115	PRD RING Certificate of Authoriz Vatford, PE Florida I	ation: 27825 icense 58208	
PRO FI	ANAMA CITY BEA RE STATION # 31 F	CH XEPL/	4CEM	IENT







1. Opening Clearance

The opening in the wall or floor shall be larger than the damper/sleeve assembly to permit installation or expansion. For two angle installations the opening shall be a minimum of 1/8" per foot (3 per 305) larger THAN THE OVERALL SIZE OF THE DAMPER/SLEEVE ASSEMBLY. THE MAXIMUM OPENING SIZE SHALL NOT EXCEED 1/8" PER FOOT (3 per 305) plus 2" (51), nor shall the opening be less than 1/4" (6) larger than the damper/sleeve assembly. For one angle installations, the opening shall be a minimum of 1/4" (6) to a maximum of 1" (25) larger THAN THE OVERALL SIZE OF THE dAMPER/SLEEVE ASSEMBLY. THE opening may be as much as 2" (51) larger than the damper/sleeve assembly if a 16ga (1.6) mounting ANGLES IS UTILIZED.

2. FASTENERS AND MULTIPLE SECTION ASSEMBLY Use No. 10 (M5) bolts or screws, 3/16" (5) rivets, tack welds or spot welds as depicted in figures 3 and 4 and spaced as follows when joining individual dampers 6. Duct/Sleeve Connections to make multiple section damper assemblies or when fastening damper to the sleeve: Vertical Mount (In wall)

VERTICAL MOUNT (IN WAIL)	
Galvanized steel dampe	rs 12" (305)
spacing	
Stainless steel dampers	6"(152)
spacing	
Horizontal Mount (In floor)	

All dampers 6" (152) SPACING

Multiple section Horizontal mount dampers require a 14 GAGE THICK $\times 41/2$ " (2 $\times 114$) wide steel reinforcing plate sandwiched between the damper frames with 1/2" (13) long welds staggered intermittently and spaced on MAXIMUM 6" (152) CENTERS. THE REINFORCING plate must be the same material as the dampers. The length must be equal to the damper width of two or more adjoining damper sections. Reinforcing plates are NOT REQUIRED FOR assemblies consisting of two dampers attached

end-to-end or three dampers attached side-to-side as depicted in figure 5 3. DAMPER SLEEVE

Sleeve thickness must be equal to or thicker than the duct connected to it. Sleeve gage requirements are listed in the SMACNA Fire, Smoke and Radiation Damper Installation Guide for HVAC Systems and in NFPA90A. If a breakaway style duct/sleeve connection is not used, the sleeve shall be a minimum of 16 gage (1.6) for dampers up to 36" (914) wide by 24" (610) high and 14 gage (1.9) for dampers exceeding 36" (914) wide by 24" (610) high. Damper sleeve shall not extend more than 6" (152) beyond the fire wall or partition unless damper is equipped with a factory installed access door. Sleeve may extend up to 16" (406) beyond the fire wall or partition on sides equipped with a factory installed access door. Sleeve shall terminate at both sides of wall within dimensions

shown. 4. DAMPER ORIENTATION

Use "Air Flow" and "Mount with Arrow Up" labels on Dynamic DIBD and DIBDX models for proper damper orientation. For Static IBD models use only "Mount With Arrow Up" label on damper for proper damper ORIENTATION.

5. Mounting Angles Mounting angles shall be a minimum of 11/2" x 11/2" x 20 gage steel (38 x 38 x 1.0). For openings in METAL STUD, WOOD STUD WALLS OR CONCRETE/MASONRY WALLS AND FLOORS OF SIZES 90" X 49" OR 49" X 90" (2286 X 1245 or 1245 x 2286) and less mounting angles are only required on one side of the wall or top side of the floor and must be attached to both the sleeve and the wall or floor. Mounting angles may be installed directly

to the metal stud under the wall board on metal stud wall installations only. Larger openings require mounting angles on both sides of the partition and must be attached only to the sleeve. Mounting angles must overlap the partition a minimum of 1" (25). Do not weld or fasten angles together at corners of dampers. Ruskin fire dampers may be installed using Ruskin FAST angle for one angle

installation or Ruskin PFMA for two angle installations. A. MOUNTING ANGLE FASTENERS

Sleeve: #10 bolts or screws, 3/16" (5) steel rivets OR 1/2" (13) long welds. Masonry/Wall or Floor: #10 self-tapping concrete SCREWS.

Wood/Steel Stud Wall: #10 screws b. Mounting Angle Fastener Spacing

For one angle installations the sleeve fasteners shall be spaced at 6" (152) o.c. and the wall or floor fasteners shall be spaced at 12" (305) o.c. with a minimum of 2 fasteners on each side, top and bottom. Screw fasteners used in metal stud must ENGAGE THE METAL STUD A MINIMUM OF 1/2" (13). Screw fasteners used in wood stud must engage the wood stud a minimum of 3/4" (19). Screw fasteners used in masonry walls or floors must engage the wall a minimum of 11/2" (38). For two angle installations the fasteners shall be spaced at 8" (203) o.c.

A. Break-away Duct/Sleeve Connections Rectangular ducts must use one or more of the connections: plain "S" slip, Hemmed "S" slip, double "S" slip, inside slip joint, standing S, standing S (angle reinforced), standing, standing S (bar reinforced), standing S (angle reinforced, or drive slip joint.

A maximum of two #10 sheet metal screws on each side and THE DOTTOM, LOCATED IN THE CENTER OF THE SLIP POCKET

and penetrating both sides of the slip pocket may be used.

Connections using these slip joints on the top and bottom with

flat drive slips up to 20" (508) long on the sides may also be

USEC b. Round and Oval Break-away Connections Round and flat oval break-away connections must

use either A 4" (102) wide drawband or #10 sheet metal

- screws spaced equally around the circumference of the duct as
- follows: • Duct diameters 22" (559) and smaller —
- Maximum 3 screws. • Duct diameters over 22" (559) and including
- 36" (914) Maximum 5 screws. • Duct diameters over 36" (914) and up to and
- including 191" (4851) total perimeter Maximum 8 screws. For flat oval ducts, the diameter is considered the largest (major) dimension of the duct.

Note: When optional sealing of these joints is desired, the following sealants may be applied in accordance with the sealant manufacturer's INSTRUCTIONS:

Hardcast, Inc. – Iron Grip 601 Precision – PA2084T Eco Duct Seal 44-52 Design

Polymerics – DP 1010 Flanged Break-away Style Duct Sleeve Connections. Flanged connection systems manufactured by

DUCTMATE, NEXUS OR WARD ARE APPROVED break-away connections when installed as shown on the Flanged System Breakaway CONNECTIONS SUPPLEMENT. TDC AND TDF Roll-formed

flanged connections using 3/8" (10) steel bolts and NUTS, AND METAL CLEATS, AS TESTED BY SMACNA, ARE approved break-away connections when installed as shown on the Flanged System Breakaway Connections Supplement.

Non-Break-away Duct/Sleeve Connections If other duct sleeve connections are used, the sleeve shall be a minimum of 16 gage (1.6) for dampers ир то 36" (914) wide x 24" (610) high and 14 GAGE (2.0) for dampers exceeding 36" (914) wide х 24" (610) нісн.

Installation and Maintenance To ensure optimum operation and performance, the damper must be installed so it is square and free from racking. Each fire damper should be maintained and tested on a regular basis and in accordance with the latest editions of NFPA 90A and local codes. Care should be exercised to ensure that such tests are performed safely and do not cause system damage.

1. FLOOR OR WALL ASSEMBLY—MIN 2-1/2 IN. THICK REINFORCED LIGHTWEIGHT OR NORMAL WEIGHT (100-150) PCF CONCRETE. WALL MAY ALSO BE CONSTRUCTED OF ANY UL CLASSIFIED CONCRETE BLOCKS*. MAX DIAM OF OPENING IS 18 IN. SEE CONCRETE BLOCKS (CAZT) CATEGORY IN THE FIRE RESISTANCE DIRECTORY FOR NAMES OF MANUFACTURERS. 1A. STEEL SLEEVE—NOM 10 IN. (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL

SLEEVE CAST OR GROUTED INTO FLOOR OR WALL ASSEMBLY. SLEEVE MAY EXTEND A MAX OF 2 IN. ABOVE TOP OF FLOOR OR BEYOND EITHER SURFACE OF WALL. T RATING IS O HR WHEN SLEEVE IS USED. 2. THROUGH PENETRANT—NOM 4 IN. DIAM (OR SMALLER) TYPE L (OR HEAVIER)

COPPER PIPE, NOM 12 IN. DIAM (OR SMALLER) SERVICE WEIGHT (OR HEAVIER) CAST IRON SOIL PIPE, NOM 12 IN. DIAM (OR SMALLER) CLASS 50 (OR HEAVIER) DUCTILE IRON PRESSURE PIPE OR NOM 12 IN. DIAM (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL PIPE CENTERED IN THE OPENING AND RIGIDLY SUPPORTED ON BOTH SIDES OF THE FLOOR OR WALL ASSEMBLY 3. PIPE COVERING*—NOM 1/2 TO 2 IN. THICK HOLLOW CYLINDRICAL HEAVY

TYPICAL FIR SCALE: NONE M2.3

NOTE: ALL SYSTEMS DETAILED BASED ON THE MANUFACTURE MECHANICAL, FIRE PROTECTIC SUBMIT A PENETRATIONS PACKA PRODUCTS TO BE USED TO THE TO BE USED.



DENSITY (MIN. 3.5 PCF) GLASS FIBER UNITS JACKETED ON THE OUTSIDE WITH AN ALL SERVICE JACKET. LONGITUDINAL JOINTS SEALED WITH METAL FASTENERS OR FACTORY-APPLIED SELF-SEALING LAP TAPE. TRANSVERSE JOINTS SECURED WITH METAL FASTENERS OR WITH BUTT STRIP TAPE SUPPLIED WITH THE PRODUCT. SEE PIPE AND EQUIPMENT COVERING—MATERIALS*(BRGU) CATEGORY IN BUILDING MATERIALS DIRECTORY FOR NAMES OF MANUFACTURERS. ANY PIPE COVERING MATERIAL MEETING THE ABOVE SPECIFICATIONS AND BEARING THE UL CLASSIEICATION MARKING WITH A FLAME SPEEAD INDEX OF 25 OR LESS AND A	
SMOKE DEVELOPED INDEX OF 50 OR LESS MAY BE USED.	
4. FIRESTOP SYSTEM—THE DETAILS OF THE FIRESTOP SYSTEM SHALL BE AS	
A. PACKING MATERIAL—MIN 1 IN. THICKNESS OF FIRMLY PACKED MINERAL	
WOOL BATT INSULATION USED AS A PERMANENT FORM. PACKING MATERIAL	60% DOCUMENTS KAJ/KMM DNW 02/11/22
SURFACES OF WALL AS REQUIRED TO ACCOMMODATE THE REQUIRED	90% CONSTRUCTION DOCUMENTS KMM DNW 03/31/22
THICKNESS OF CAULK FILL MATERIAL (ITEM B). B. FILL VOID OR CAVITY MATERIAL* CAULK, APPLIED TO FILL THE ANNULAR	CONSTRUCTION DOCUMENTS KMM DNW 05/16/22
SPACE FLUSH WITH THE TOP SURFACE OF THE FLOOR OR SLEEVE OR FLUSH	BID SET KMM DNW 01/01/22
COVERING THICKNESS IS 1-1/2 IN. OR LESS, MIN THICKNESS OF CAULK FILL MATERIAL IS 1 IN. THE HOURLY F AND T RATINGS OF THE FIRESTOP SYSTEM ARE DEPENDENT UPON THE THICKNESS OF THE FLOOR OR WALL, THE SIZE OF PIPE, THE THICKNESS OF PIPE COVERING MATERIAL AND THE SIZE OF THE ANNULAR SPACE (BETWEEN THE PIPE COVERING MATERIAL AND THE SIZE OF THE CIRCULAR THROUGH OPENING), AS SHOWN IN THE FOLLOWING TABLE: MIN FLOOR OR MAX PIPE NOM PIPE ANNULAR WALL THKNS DIAM COVERING THKNS SPACE F RATING T RATING IN. IN. IN. IN. HR HR 2-1/2 4 1 OR 1-1/2 1/2 TO 2-3/8 2 1 4-1/2 4 2 1/4 TO 3-5/8 2 1-1/2 2-1/2 12 1 1/2 TO 1-1/2 2 1/2 4-1/2 12 1 1/2 TO 2-3/8 3 1 2-1/2 12 1/2 1/2 TO 2-3/8 3 0 MINNESOTA MINING & MFG. CO.—CP 25WB+. *BEARING THE UL CLASSIFICATION MARKING AL FIRE RATED WALL/FLOOR PENDETRATIO	2211 THOMAS DR., STE 100 PANAMA CITY BEACH, FL HONE: (850) 236-9832 Commission Number: 21804 WATFORD UNATEORD ENGINEERING 452 Clinton Street, Marianna, Florida 2244 850:526.3447 Project Number: 2021-11 PROJECT: NAMAGA CITY BEACH
NE FIBERGLASS INSULATED METALLIC PI	PE FIRE STATION " STREFLACEFIENT
	BAY COUNTY, FLORIDA
FAILED ON MECHANICAL PENETRATIONS SHEETS ARE FACTURERS SPECIFIED AS BASIS OF DESIGN AND APPLY TO COTECTION, AND PLUMBING. THE CONTRACTOR SHALL NS PACKAGE DETAILING EACH PENETRATION AND D TO THE PERMITTING AUTHORITY FOR THE ACTUAL SYSTEMS	
	SHEET NUMBER:

REVISIONS

NO. DESCRIPTION

CHECKED DATE

DRAWN

UL SYSTEM CAJ5001



CONSULT CURRENT UNDERWRITERS LABORATORIES, INC. "FIRE RESISTANCE DIRECTORY" FOR DETAILS. UL SYSTEM WL1003

- . WALL ASSEMBLY—THE 1 OR 2 HR FIRE-RATED GYPSUM WALLBOARD/STUD WALL ASSEMBLY SHALL BE CONSTRUCTED OF THE MATERIALS AND IN THE MANNER DESCRIBED IN THE INDIVIDUAL U300 OR U400 SERIES WALL OR PARTITION DESIGN IN THE UL FIRE RESISTANCE DIRECTORY AND SHALL INCLUDE THE FOLLOWING CONSTRUCTION FEATURES:
- A. STUDS—WALL FRAMING MAY CONSIST OF EITHER WOOD STUDS OR STEEL CHANNEL STUDS. WOOD STUDS TO CONSIST OF NOM 2 BY 4 IN. LUMBER SPACED 16 IN. OC WITH NOM 2 BY 4 IN. LUMBER END PLATES AND CROSS BRACES. STEEL STUDS TO BE MIN 3-1/2 IN. WIDE BY 1-3/8 IN. DEEP CHANNELS SPACED MAX 24 IN. OC.
- B. WALLBOARD, GYPSUM*-NOM 5/8 IN. THICK, 4 FT. WIDE WITH SQUARE OR TAPERED EDGES. THE GYPSUM WALLBOARD TYPE, THICKNESS, NUMBER OF LAYERS, FASTENER TYPE AND SHEET ORIENTATION SHALL BE AS SPECIFIED IN THE INDIVIDUAL U300 OR U400 SERIES DESIGN IN THE UL FIRE RESISTANCE DIRECTORY. MAX DIAM OF OPENING IS 15 IN.
- THE HOURLY F RATING OF THE FIRESTOP SYSTEM IS EQUAL TO THE HOURLY FIRE RATING OF THE WALL ASSEMBLY IN WHICH IT IS INSTALLED
- THROUGH-PENETRANT—ONE METALLIC PIPE CONDUIT OR TUBING TO BE INSTALLED EITHER CONCENTRICALLY OR ECCENTRICALLY WITHIN THE FIRESTOP SYSTEM. THE SPACE BETWEEN PIPES, CONDUITS OR TUBING AND THE STEEL SLEEVE (ITEM 3A) SHALL BE MIN OF 0 IN. (POINT CONTACT) TO MAX 2-3/8 IN. PIPE, CONDUIT OR TUBING TO BE RIGIDLY SUPPORTED ON BOTH SIDES OF WALL ASSEMBLY. THE FOLLOWING TYPES AND SIZES OF METALLIC PIPES, CONDUITS OR TUBING MAY BE USED
- A. **STEEL PIPE**—NOM 12 IN. DIAM (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL PIPE. B. IRON PIPE—NOM 12 IN. DIAM (OR SMALLER)
- SERVICE WEIGHT (OR HEAVIER) CAST IRON SOIL PIPE, NOM 12 IN. DIAM (OR SMALLER) OR CLASS 50 (OR HEAVIER) DUCTILE IRON PRESSURE PIPE. C. CONDUIT-NOM 6 IN. DIAM (OR SMALLER) STEEL
- CONDUIT OR NOM 4 IN. DIAM (OR SMALLER) STEEL ELECTRICAL METALLIC TUBING. D. COPPER TUBING—NOM 6 IN. DIAM (OR
- SMALLER) TYPE L (OR HEAVIER) COPPER TUBING. E. COPPER PIPE—NOM 6 IN. DIAM (OR SMALLER) REGULAR (OR HEAVIER) COPPER PIPE.

- 3. FIRESTOP SYSTEM—INSTALLED SYMMETRICALLY ON BOTH SIDES OF WALL ASSEMBLY. THE DETAILS OF THE FIRESTOP SYSTEM SHALL BE AS FOLLOWS.
- A. STEEL SLEEVE—CYLINDRICAL SLEEVE FABRICATED FROM MIN 0.019 IN. THICK (NO. 28 GAUGE) GALV SHEET STEEL AND HAVING A MIN 2 IN. LAP ALONG THE LONGITUDINAL SEAM. LENGTH OF STEEL SLEEVE TO BE EQUAL TO THICKNESS OF WALL PLUS 1 TO 4 IN. SUCH THAT, WHEN INSTALLED, THE ENDS OF THE SLEEVE WILL PROJECT APPROXIMATELY 1/2 TO 2 IN. BEYOND THE SURFACE OF THE WALL ON BOTH SIDES OF THE WALL ASSEMBLY.
- SLEEVE INSTALLED BY COILING THE SHEET STEEL TO A DIAM SMALLER THAN THE THROUGH OPENING, INSERTING THE COIL THROUGH THE OPENINGS AND RELEASING THE COIL TO LET IT UNCOIL AGAINST THE CIRCULAR CUTOUTS IN THE GYPSUM
- WALLBOARD LAYERS. B. PACKING MATERIAL—MIN 1 IN. THICKNESS OF MINERAL WOOL BATT INSULATION FIRMLY PACKED INTO STEEL SLEEVE ON BOTH SIDES OF THE WALL ASSEMBLY AS PERMANENT FORMS. PACKING MATERIAL TO BE RECESSED MIN 1/2 IN. FROM END OF STEEL SLEEVE (FLUSH WITH OR RECESSED INTO GYPSUM WALLBOARD SURFACE) ON BOTH SIDES OF WALL ASSEMBLY.
- B1. PACKING MATERIAL—(NOT SHOWN)—AS AN ALTERNATE TO ITEM B, NOM 1 IN. THICK POLYETHYLENE BACKER ROD MAY BE USED. THE BACKER ROD IS TO BE RECESSED WITHIN THE STEEL SLEEVE A MIN OF 1 IN. FROM EACH SURFACE OF WALL.
- C. FILL, VOID OR CAVITY MATERIALS*—CAULK—WHEN MINERAL WOOL BATT INSULATION IS USED, APPLIED TO FILL THE STEEL SLEEVE TO A MIN DEPTH OF 1/2 IN. ON BOTH SIDES OF WALL ASSEMBLY. WHEN BACKER ROD IS USED, A MIN THICKNESS OF 1 IN. OF CP-25WB+ CAULK IS REQUIRED FLUSH WITH SURFACE OF WALL. A NOM 1/4 IN. DIAM CONTINUOUS BEAD OF CAULK SHALL BE APPLIED AROUND THE CIRCUMFERENCE OF THE STEEL SLEEVE AT ITS EGRESS FROM THE GYPSUM WALLBOARD LAYERS ON BOTH SIDES OF THE WALL ASSEMBLY. MINNESOTA MINING & MFG.
- CO.—CP 25WB+ *BEARING THE UL CLASSIFICATION MARKING

WALLBOARD/STUD WALLASSEMBLY SHALL BE CONSTRUCTED OF THE MATERIALS AND IN THE MANNER DESCRIBED IN THE INDIVIDUAL U300 OR U400 SERIES WALL AND PARTITION DESIGN IN THE UL FIRE RESISTANCE DIRECTORY AND SHALL INCLUDE THE FOLLOWING CONSTRUCTION FEATURES: A. STUDS—WALL FRAMING MAY CONSIST OF EITHER WOOD STUDS OR STEEL CHANNEL STUDS. WOOD STUDS TO

- DEEP CHANNELS SPACED MAX 24 IN. OC. B. WALLBOARD, GYPSUM*-NOM 5/8 IN. THICK, 4 FT WIDE
- WITH SQUARE OR TAPERED EDGES. THE GYPSUM WALLBOARD TYPE, THICKNESS, NUMBER OF LAYERS, SPECIFIED IN THE INDIVIDUAL U300 OR U400 SERIES DESIGN IN THE UL FIRE RESISTANCE DIRECTORY. MAX AND 17 IN. FOR STEEL STUD WALLS.
- THE HOURLY F RATING OF THE FIRESTOP SYSTEM IS 1 HR WHEN INSTALLED IN A 1 HR FIRE RATED WALL AND 2 HR WHEN INSTALLED IN A 2 HR FIRE RATED WALL. 2. THROUGH PENETRANTS—ONE METALLIC PIPE. CONDUIT OR TUBING TO BE CENTERED WITHIN THE FIRESTOP SYSTEM. PIPE. CONDUIT OR TUBING TO BE RIGIDLY SUPPORTED ON BOTH SIDES OF WALL ASSEMBLY. THE FOLLOWING TYPES AND SIZES OF METALLIC PIPES, CONDUITS OR TUBING MAY BE USED:
- A. STEEL PIPE—NOM 12 IN. DIAM (OR SMALLER) SCHEDULE RATING IS 1 HR.
- B. CONDUIT-NOM 3 IN. DIAM (OR SMALLER) STEEL
- STEEL CONDUIT IS USED, T RATING IS 1/4 HR. C. COPPER TUBING—NOM 6 IN. DIAM (OR SMALLER) TYPE L USED. T RATING IS 1/2 AND 1 HR WHEN INSTALLED IN 1 AND 2 HR RATED WALLS, RESPECTIVELY.

T RATING IS 1/2 AND 1 HR WHEN INSTALLED IN 1 AND 2 HR RATED WALLS, RESPECTIVELY 3. PIPE COVERING*—NOM 1 OR 1-1/2 IN. THICK HOLLOW CYLINDRICAL HEAVY DENSITY (MIN 3.5 PCF) GLASS FIBER UNITS JACKETED ON THE OUTSIDE WITH AN ALL SERVICE JACKET. LONGITUDINAL JOINTS SEALED WITH METAL

FASTENERS OR FACTORYAPPLIED SELF-SEALING LAP TAPE.







CONSULT CURRENT UNDERWRITERS LABORATORIES "FIRE RESISTANCE DIRECTORY" FOR DETAILS UL SYSTEM WL5011

1. WALL ASSEMBLY—THE 1 OR 2 HR FIRE-RATED GYPSUM CONSIST OF NOM 2 BY 4 IN. LUMBER SPACED 16 IN. OC WITH NOM 2 BY 4 IN. LUMBER END PLATES AND CROSS BRACES. STEEL STUDS TO BE MIN 3-5/8 IN. WIDE BY 1-3/8

FASTENER TYPE AND SHEET ORIENTATION SHALL BE AS DIAM OF OPENING IS 14-1/2 IN. FOR WOOD STUD WALLS

10 (OR HEAVIER) STEEL PIPE. WHEN STEEL PIPE IS USED, T

ELECTRICAL METALLIC TUBING OR STEEL CONDUIT. WHEN (OR HEAVIER) COPPER TUBING. WHEN COPPER TUBING IS

D. COPPER PIPE—NOM 6 IN. DIAM (OR SMALLER) REGULAR (OR HEAVIER) COPPER PIPE. WHEN COPPER PIPE IS USED, TRANSVERSE JOINTS SEALED WITH METAL FASTENER STRIP TAPE SUPPLIED WITH THE PRODUCT. SEE PIPE AND EQUIPMENT

- COVERINGS—MATERIALS—(BRGU) CATEGORY IN BUILDING MATERIALS DIRECTORY FOR NAMES OF MANUFACTURERS. ANY PIPE COVERING MATERIAL MEETING THE ABOVE SPECIFICATIONS AND BEARING THE UL CLASSIFICATION MARKING WITH A FLAME SPREAD INDEX OF 25 OR LESS AND A SMOKE DEVELOPED INDEX OF 50 OR LESS MAY BE USED.
- STEEL SLEEVE—CYLINDRICAL SLEEVE FABRICATED FROM MIN 0.019 IN. THICK (NO. 28 GAUGE) GALV SHEET STEEL AND HAVING A MIN 2 IN. LAP ALONG THE LONGITUDINAL SEAM. LENGTH OF STEEL SLEEVE TO BE EQUAL TO THICKNESS OF WALL PLUS 1 IN. SUCH THAT, WHEN INSTALLED, THE ENDS OF THE SLEEVE WILL PROJECT APPROX 1/2 IN. BEYOND THE SURFACE OF THE WALL ON BOTH SIDES OF THE WALL ASSEMBLY. THE DIAM OF THE OPENINGS CUT IN THE GYPSUM WALLBOARD LAYERS ON EACH SIDE OF THE WALL ASSEMBLY (CONCENTRIC WITH PIPE) TO BE 2 TO 2-1/2 IN. LARGER THAN OUTSIDE DIAM OF PIPE INSULATION SUCH THAT, WHEN THE STEEL SLEEVE IS INSTALLED, A 1 TO 1-1/4 IN. ANNULAR SPACE WILL BE PRESENT BETWEEN THE STEEL SLEEVE AND THE PIPE INSULATION AROUND THE ENTIRE CIRCUMFERENCE OF THE PIPE. SLEEVE INSTALLED BY COILING THE SHEET STEEL TO A DIAM SMALLER THAN THE THROUGH OPENING INSERTING THE COIL THROUGH THE OPENINGS AND RELEASING THE COIL TO LET IT UNCOIL AGAINST THE CIRCULAR CUTOUTS IN THE GYPSUM WALLBOARD LAYERS
- 5. PACKING MATERIAL—POLYETHYLENE BACKER ROD OR MIN 1 IN. THICKNESS OF MINERAL WOOL BATT INSULATION FIRMLY PACKED INTO STEEL SLEEVE ON BOTH SIDES OF THE WALL ASSEMBLY AS PERMANENT FORMS. PACKING MATERIAL TO BE RECESSED MIN 1 IN. FROM END OF STEEL SLEEVE (RECESSED MIN 1/2 IN. INTO GYPSUM WALLBOARD SURFACE) ON BOTH SIDES OF WALL ASSEMBLY.
- 6. FILL, VOID OR CAVITY MATERIALS*—CAULK—MIN 1 IN. THICKNESS OF FILL MATERIAL APPLIED WITHIN ANNULUS ON BOTH SIDES OF WALL ASSEMBLY. THICKNESS FOR FILL MATERIAL FOR NOM 3 IN. DIAM (OR SMALLER) STEEL PIPES OR CONDUITS MAY BE REDUCED TO A MIN 1/2 IN. A NOM 1/4 IN. DIAM CONTINUOUS BEAD OF CAULK SHALL BE APPLIED AROUND THE CIRCUMFERENCE OF THE STEEL SLEEVE AT ITS EGRESS FROM THE GYPSUM WALLBOARD LAYERS ON BOTH SIDES OF THE WALL ASSEMBLY MINNESOTA MINING & MFG. CO.-CP 25WB+ *BEARING THE UL CLASSIFICATION MARKING

TYPICAL FIRE RATED WALL PENETRATION

SCALE: NONE

INSULATED METALLIC PIPE



- 1. WALL ASSEMBLY—THE 1 OR 2 HR FIRE-RATED GYPSUM WALLBOARD/STUD WALL ASSEMBLY SHALL BE CONSTRUCTED OF THE MATERIALS AND IN THE MANNER DESCRIBED IN THE INDIVIDUAL U300 OR U400 SERIES WALL OR PARTITION DESIGN IN THE UL FIRE RESISTANCE DIRECTORY AND SHALL INCLUDE THE FOLLOWING CONSTRUCTION FEATURES:
- A. STUDS—WALL FRAMING MAY CONSIST OF EITHER WOOD STUDS OR STEEL CHANNEL STUDS. WOOD STUDS TO CONSIST OF NOM 2 BY 4 IN. LUMBER SPACED 16 IN. OC WITH NOM 2 BY 4 IN. LUMBER END PLATES AND CROSS BRACES. STEEL STUDS TO BE MIN 3-5/8 IN. WIDE BY 1-3/8 IN. DEEP CHANNELS SPACED MAX 24 IN. OC.
- B. WALLBOARD, GYPSUM*-5/8 IN. THICK, 4 FT WIDE WITH SQUARE OR TAPERED EDGES. THE GYPSUM WALLBOARD TYPE, THICKNESS, NUMBER OF LAYERS, FASTENER TYPE AND SHEET ORIENTATION SHALL BE AS SPECIFIED IN THE INDIVIDUAL U300 OR U400 SERIES DESIGN IN THE UL FIRE RESISTANCE DIRECTORY. MAX DIAM OF OPENING IS 3-1/8
- 2. THROUGH PENETRANTS—ONE NONMETALLIC PIPE OR CONDUIT TO BE CENTERED INTHE THROUGH OPENING. THE ANNULAR SPACE BETWEEN PIPE OR CONDUIT AND PERIPHERY OF OPENING SHALL BE MIN 1/4 IN. AND MAX 3/8 IN. PIPE OR CONDUIT TO BE RIGIDLY SUPPORTED ON BOTH SIDES OF THE FLOOR-CEILING ASSEMBLY. THE FOLLOWING TYPES AND SIZES OF NONMETALLIC PIPES OR CONDUITS MAY BE USED
- A. POLYVINYL CHLORIDE (PVC) PIPE—NOM 2 IN. DIAM (OR SMALLER) SCHEDULE 40 SOLID CORE PVC PIPE FOR USE IN CLOSED (PROCESS OR SUPPLY) OR VENTED (DRAIN,
- B. RIGID NONMETALLIC CONDUIT++-NOM 4 IN. DIAM (OR SMALLER)(SCHEDULE 40 OR 80) PVC CONDUIT INSTALLED IN ACCORDANCE WITH ARTICLE 347 OF THE NATIONAL
- C. CHLORINATED POLYVINYL CHLORIDE (CPVC) PIPE—NOM 2 IN. DIAM (OR SMALLER) SDR17 CPVC PIPE FOR USE IN CLOSED (PROCESS OR SUPPLY) OR VENTED (DRAIN, WASTE OR VENT) PIPING SYSTEMS.
- D. CELLULAR CORE POLYVINYL CHLORIDE (CCPVC) PIPE—NOM 2 IN. DIAM (OR SMALLER) SCHEDULE 40 CELLULAR CORE PVC PIPE FOR USE IN CLOSED (PROCESS OR SUPPLY) OR VENTED (DRAIN, WASTE OR VENT) PIPING SYSTEM.



LEGEND

	S or W
	V
	CW
	HW
	HWR
A	А
— GAS — GAS —	G
	GV
	CV
<u>ю</u>	BV
I	HB
	WH
———————————————————————————————————————	СО
	FD
-	
Ō	COIC
	COIG COAC
	COIG COAC VTR
	COTG COAC VTR SH
	COTG COAC VTR SH MR
	COTG COAC VTR SH MR UR
	COTG COAC VTR SH MR UR WC
	COTG COAC VTR SH MR UR WC UB
	COTG COAC VTR SH MR UR UR UR UB IWH
	COTG COAC VTR SH MR UR UR UR UR UB IWH EWC

WΗ

HB

KW

AD

WHA

WHB

WHC

HR

<u>UH-1(M)</u>

SC	DIL OR WASTE PIPING
V	ENT PIPING
С	OLD WATER SUPPLY PIPING
H	OT WATER SUPPLY PIPING
H	OT WATER RETURN PIPING
С	ompressed air
G	AS
G	ATE VALVE
С	HECK VALVE
B/	ALL VALVE
H	OSE BIBB
W	ALL HYDRANT
С	LEANOUT TO FLOOR
Fl	OOR DRAIN
С	LEANOUT TO GRADE
С	LEANOUT ABOVE CEILING
U	NION
VI	ENT THRU ROOF
Sł	HEET NOTE
P	DINT OF CONNECTION TO EXISTING
Sł	HOWER
М	OP RECEPTOR
U	RINAL
W	ATER CLOSET
W	ALL MOUNTED UTILITY BOX
IN	ISTANTANEOUS ELECTRIC WATER HEATER
EI	LECTRIC WATER COOLER
LÆ	AVATORY
W	ALL HYDRANT
H	OSE BIBB
KI	LOWATT
A	IR DROP
A	UTOMATIC TRAP PRIMER
T١	PE "A" WATER HAMMER ARRESTER
Τì	(PE "B" WATER HAMMER ARRESTER
Τ١	PE "C" WATER HAMMER ARRESTER
H	OSE REEL
Al	R
G/	45
Al	R COMPRESSOR
eç Me	duipment tag; (m) indicates Echanical equipment. Refer to m sheet

						Pl	LUMBING FIXTURE SCHEDULE
MARK	FIXTURE		PIPI	E SIZES-IN	CHES		REMARKS
		CW	HW	W	G	A	
WC-1	WATER CLOSET (HANDICAP, MANUAL)]	-	4	-	-	HANDICAP HEIGHT @ 17", FLOOR MOUNT, ELONGATED BOWL, 1.5" TOP SPUD, MANUAL FLUSH VALVE, 1.28 GPF, OPEN FF
[-]	LAVATORY (20X17)	3/8	3/8	1-1/4	-	-	COUNTERTOP MOUNT, OVAL, VITREOUS CHINA, 4" CENTERS, MIXING VALVE, POLISHED CHROME PLATED FAUCET, STRAIGH
L-2	LAVATORY (HANDICAP, 20X18)	3/8	3/8	1-1/4	-	-	WALL MOUNT, CHAIR CARRIER, VITREOUS CHINA, 4" CENTERS, INSULATION KIT, MIXING VALVE, POLISHED CHROME PLATER TAILPIECE, STOPS & SUPPLIES
SK-1	SINK (TRIPLE, 63"x22"x10 1/8")	3/8	3/8	1-1/2	-	-	COUNTERTOP, TRIPLE COMPARTMENT, STAINLESS STEEL, TWO (2) SINGLE HOLE PULL OUT FAUCET WITH STRAIGHT LEVER HA
DT-1	TROUGH DRAIN (12"Hx18"Wx3'L)	-	-	4	-	-	ABS PLASTIC DRAIN TROUGH SLOPED BETWEEN 1/8" & 1/4" PER FOOT, LINT SCREEN WITH OVERFLOW AND HINGED LID
SH-1	SHOWER (HANDICAP)	1/2	1/2	2	-	-	WALL MOUNT, STAINLESS STEEL, PRESSURE BALANCING VALVE WITH LIMIT STOP & INTEGRAL SERVICE STOPS, SHOWERHEAD VACUUM BREAKER
UB-1	RECESSED UTILITY WALL BOX (ICE-MAKER HOOK-UP)	1/4	-	-	-	-	FACTORY FABRICATED, 16 GAUGE STEEL EPOXY FINISH, FACTORY INSTALLED SHANK VALVE
UB-2	RECESSED UTILITY WALL BOX (WASHER HOOK-UP)	1/2	1/2	2	-	-	FACTORY FABRICATED, 16 GAUGE STEEL EPOXY FINISH
FD	FLOOR DRAIN	1/2	-	3	-	-	DEEP SEAL, TRAP PRIMER CONNECTION
MV-1	WATER MIXING VALVE	3/4	3/4	-	-	-	THERMOSTATIC, BRASS, BRONZE, STAINLESS STEEL, EXPOSED WALL MOUNT, REGULATOR KNOB
TD-1	TRENCH DRAIN (12"WIDE X 40'LONG)	-	-	4	-	-	RECTANGULAR TOP, VANDAL PROOF, NICKLE BRONZE GRATE, HIGH DENSITY POLYETHYLENE, STAINLESS STEEL FRAME, INTE
GWH-1	GAS WATER HEATER	1-1/2	1-1/2	-	3/4	-	120,000 BTU/H INPUT, NATURAL GAS, 100 GALLONS, 97% THERMAL EFFICIENCY, CONCENTRIC VENT, MANIFOLD KIT
IWH-1	INSTANTANEOUS GAS WATER HEATER	3/4	3/4	-	3/4	-	157,000 BTU/H INPUT, NATURAL GAS, 0.95 ENERGY FACTOR, INDOOR LOCATION
CP-1	CIRCULATOR PUMP	-	3/4	-	-	-	BRONZE, IN-LINE TYPE, 1/4 HP, 115V, FLOW RATE @ 1 GPM, HEAD @ 2.6', CIRCUIT SETTER SET TO 1GPM, CIRCUIT SOLVER
TCV	TEMPERATURE CONTROL VALVE	-	1/2	-	-	-	SELF-ACTING THERMOSTATIC RECIRCULATION VALVE SET AT 100°F.
EWC-1	ELECTRIC WATER COOLER (DUAL LEVEL)	1/2	-	1-1/2	-	-	WALL MOUNT, CHAIR CARRIER, SINGLE LEVEL, BOTTLE FILL STATION, SELF-CONTAINED, STAINLESS STEEL, PUSH BAR
TP	TRAP PRIMER	1/2	-	-	-	-	PPP MODEL MP-500 ELECTRONIC SOLENOID TRAP PRIMER, INTEGRAL VACUUM BREAKER, DISTRIBUTION UNIT, AND MINIMU
HB	HOSE BIB	-	3/4	-	-	-	CHROME FINISH, ANTI-SIPHON VACUUM BREAKER, WHEEL HANDLE
MR-1	MOP SINK (24"x24"x24")	3/8	3/8	3	-	-	FLOOR TYPE, NEO-CORNER, TERRAZZO, 8" CENTERS, TOP BRACE FAUCET WITH INTERGAL STOPS, STRAIGHT LEVER HANDLE

- 1. WATER SUPPLY TAPPING TO EACH PLUMBING FIXTURE SHALL BE FULL SIZE (MINIMUM).
- 2. SEE ELECTRICAL DWGS FOR FINAL POWER REQUIREMENTS.

PLUMBING GENERAL NOTES

1.	COORDINATE ALL PIPING WITH DUCTWORK SHOP DR AVOID CONFLICTS.
2.	PRIOR TO START OF ANY WORK, COORDINATE SANITA WITH CIVIL DRAWINGS.
3.	FIELD VERIFY PIPE INVERTS PRIOR TO LAYING OUT SA
4.	ALL PIPING PASSING THROUGH WALLS SHALL HAVE A
5.	ALL PIPING PASSING THROUGH FIRE-RATED WALLS SH SPECIFICATIONS.
6.	ALL PIPING INDICATED IS ABOVE THE CEILING EXCEP VENT AND POTABLE WATER PIPING BELOW FLOOR OF
7.	SEE TOILET ROOM ELEVATIONS ON ARCHITECTURAL D MOUNTING HEIGHT.
8.	COORDINATE LOCATION OF ALL FLOOR DRAINS SERV EQUIPMENT SHOP DRAWINGS.
9.	UNDER SLAB SOIL, WASTE AND VENT PIPING PASSING FOUNDATION FOOTING, WALL OR GRADE BEAM SHAL OR PIPE SLEEVE 2 (TWO) PIPE SIZES GREATER THAN P COORDINATE FINAL PIPE ROUTING AND LAYOUT WITH
10.	PRIOR TO SUBSTANTIAL COMPLETION OF NEW WORK SANITARY PLUMBING SYSTEM CLEARED OF DEBRIS OF PREVENT ADEQUATE CONVEYANCE OF MATERIALS FR INTO BUILDING OR PUBLIC DISPOSAL FACILITIES.
11.	ALL (VTR'S) VENT THRU ROOF PENETRATIONS INDICAT LOCATIONS SHALL BE COORDINATED WITH ALL TRADE 10'-0" FROM ALL FRESH AIR INTAKE OPENINGS.
12.	ALL PIPING PENETRATIONS THROUGH WALLS OR FLOO RATING OF THE WALLS OR FLOORS.
13	

- 13. ALL TRAP PRIMERS AND DOMESTIC WATER ISOLATION VALVES SHALL BE ACCESSIBLE. TRAP PRIMERS LOCATED IN THE VICINITY OF WATER CLOSETS SHALL BE ACTIVATED BY WATER CLOSET USAGE. ISOLATION VALVES SHALL BE OF THE QUARTER TURN BALL OR GATE TYPE.
- 14. ALL COMPONENTS OF PLUMBING SYSTEMS ARE TO BE INSTALLED PER MANUFACTURERS INSTRUCTIONS AND THE REQUIREMENTS OF THE 2020 FLORIDA BUILDING CODE (7TH EDITION).
- 15. CONTRACTOR SHALL DEVELOP COORDINATION SHOP DRAWINGS WHICH IDENTIFY ROUTING OF PLUMBING PIPE AND LOCATION OF EQUIPMENT. SHOP DRAWINGS SHALL INDICATE COORDINATION WITH THE WORK OF OTHER TRADES.

3. PROVIDE WATER HAMMER ARRESTERS ON HOT & COLD WATER SUPPLY BRANCHES SERVING SINGULAR, MULTIPLE OR GROUPS OF PLUMBING FIXTURES. ADHERENCE TO THE PLUMBING AND DRAINAGE INSTITUTE STANDARD P.D.I.-WH201 (PER SPECIFICATIONS) SHALL BE EMPLOYED IN DETERMINING PROPER SIZE, SELECTION, PLACEMENT, LOCATION AND INSTALLATION OF ARRESTERS.

RAWINGS. ROUTE PIPING AS REQUIRED TO

TARY SEWER AND POTABLE WATER PIPING

ANITARY SEWER PIPING.

A SLEEVE PER SPECIFICATIONS.

HALL HAVE A FIRE-RATED SLEEVE PER

PT THE OBVIOUS SANITARY SOIL, WASTE, DR GRADE.

DRAWINGS FOR PLUMBING FIXTURE

ING HVAC EQUIPMENT WITH HVAC

G TO UNDERSIDE OR THROUGH ALL BE PROVIDED WITH A RELIEVING ARCH PIPE SIZE INDICATED ON PLANS. TH STRUCTURAL DRAWINGS.

AREAS, CONTRACTOR SHALL HAVE OR ANY MATTER THAT WOULD INTERFERE OR FROM MOVING THROUGH AND TERMINATING

ATED ON PLANS ARE PRELIMINARY. FINAL DES. ALL VTR'S SHALL BE A MINIMUM OF

ORS SHALL BE SEALED TO EQUAL THE



RONT SEAT LESS COVER
HT LEVER HANDLES, 1.2 GPM, TAILPIECE, P-TRAP, STOPS & SUPPLIES, INSULATION
D FAUCET, STRAIGHT LEVER HANDLES, 1.2 GPM, P-TRAP,
ANDLE, 1.5 GPM, TAILPIECE, P-TRAP, STOPS & SUPPLIES
d, Wall/Hand Shower with Hose & Slide Bar, Inline
ERLOCKING ENDS, P-TRAP, BUILT-IN SLOPE OF 0.7%
R VALVE, AQUASTAT, DIGITAL TIMER
UM ELEVATION 12" AFF, 120V/1PHASE
es, vacuum breaker, mop hanger





GAS FIRED EQUIP. SCHEDULE INPUT CONNECTION INLET PRESSURE

IAG	(BTUH)	SIZE	RANGE IN. WC	
RANGE BY OTHERS	302,000	1/2"	0" - 5"	
IRH-1-4(M)	40,000	1/2"	7" - 14"	
IWH-1	157,000	1-1/4"	4" - 10.5"	
GWH-1	120,000	1-1/4"	3.5" - 14"	

NOTE: SIZES BASED ON A NATURAL GAS SYSTEM, INLET PRESSURE OF 2 PSI OR LESS, PRESSURE DROP OF 3.0" W.C., AND A SPECIFIC GRAVITY OF 0.60.

(M)MECHANICAL EQUIPMENT FURNISHED BY DIVISION 23. FINAL GAS CONNECTION BY DIVISION 22.

SHEET NOTES

1 INTERFACE WITH GAS UTILITY SERVICE AT 5 FOOT FROM BUILDING.

PROVIDE SLEEVE AND FILLER, EXTEND GAS SERVICE THROUGH EXTERIOR WALL ABOVE GRADE.

GENERAL NOTES

- 1. COORDINATE GAS SERVICE AND METERING WITH GAS UTILITY. CONTRACTOR SHALL PAY ALL FEES AND INSTALLATION COST FOR SERVICE TO THE BUILDING.
- 2. COORDINATE FINAL CONNECTION SIZE AND LOCATION WITH EQUIPMENT SUPPLIED.
- 3. GAS PIPING WITHIN INACCESSIBLE CEILINGS AND WALLS SHALL BE WITHIN A VENTED CONDUIT.
- 4. PROVIDE SHUTOFF GAS COCK AT EACH HEATER, RANGE, AND GAS WATER HEATER.









RE	VISIONS			
NO.	DESCRIPTION	DRAWN	CHECKED	DA1
PH		DRAWN	CHECKED	DAT
501	HEMATIC DESIGN			11/05
DE		KAJ		12/17
900	% CONSTRUCTION DOCUMENTA			02/1
00	NSTRUCTION DOCUMENTS	TLC		Ø5/10
BIT) SET	TIC		Ø1/0
	2211 TH PANAN PHONE Commissi	OMAS DI 1A CITY E: (850) on Number:	R, STE BEACH 236-98 21804	100 1, FL :32
	ZII TH PANAL PHONE Commissi	OMAS DI 1A CITY 5: (850) on Number:	R , STE BEACH 236-98 21804	100 I, FL 32
	ACHITECTS 2211 TH PANAR PHONE Commissi Commissi Commissi Commissi Commissi Commissi Commissi	CMAS DA 1A CITY 5: (850) on Number: On Number: On Number: On Number: On Number: On Number: On Number: On Number:	R , STE BEACH 236-98 21804	100 I, FL 32
	ANAMA CITY BEA	CHAS DA A CITY E: (850) on Number: On Number		100 1, FL
	AX COUNTY ELOPIDA	CMAS DA 1A CITY E: (850) on Number: CONDERING		100 1, FL 132
	ANAMA CITY BEA ANAMA CITY BEA ANAMA SUSSESSION SUSSIONAL SUSSESSIONAL SUSS	CHAS DA LA CITY E: (850) on Number: On Numbe		100 1, FL 132





REVISIONS							
NO. DESCRIPTION	DRAWN	CHECKED	DATE				
PHASE	DRAWN	CHECKED	DATE				
SCHEMATIC DESIGN			11/05/21				
DESIGN DEVELOPMENT	КАЈ	DNW	12/17/21				
60% DOCUMENTS	KAJ/KMM		@2/11/22				
90% CONSTRUCTION DOCUMENTS	КДЈ	DNW	@3/31/22				
CONSTRUCTION DOCUMENTS	TLC	DNW	@5/16/22				
BID SET	TLC	DNW	Ø7/Ø1/22				
ARCHITECTS Commission Number: 21804							
WATERRD ENGINEERING 4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115 Florida Certificate of Authorization: 27825 David N Watford, PE Florida License 58208							
PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT							
BAY COUNTY, FLORIDA							
PLUMBING FLOOR PLAN - DOMESTIC WATER & NATURAL GA							
SHEET NUMBER:			2				
1" DOMESTIC WATER SERVICE, REFER TO CIVIL FOR CONTINUATION





R	VISIONS						
NO.	DESCRIPTION	DRAWN	CHECKED	DATE			
		ļ		<u> </u>			
Pł	IASE	DRAWN	CHECKED	DATE			
SCI	HEMATIC DESIGN			11/05/21			
DE	SIGN DEVELOPMENT			12/17/21			
60	% DOCUMENTS			Ø2/11/22			
909	& CONSTRUCTION DOCUMENTS	+ 6		@3/31/22			
00	NSTRUCTION DOCUMENTS			05/16/22			
	RCHITECTS commission	: (850) n Number:	236-98 21804	532			
PRC	4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115 Florida N David N	DRD RING Certificate of Authoria Vatford, PE Florida I	zation: 27825 License 58208				
PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT							
B	AY COUNTY, FLORIDA						
	PLUMBING TEMP. A BAY FLOOR PLANS	PPAF S	RATU	3			
SHEI	ET NUMBER:			 1			

REFERENCE: FINISHED FLOOR ELEVATION = 0'-0"



NO. DESCRIPTION DRAWN CHECKED DATE Image: Strategy of the strateg	R	EVISIONS							
PHASE DRAWN CHECKED DATE SCHEMATIC DEBIGN III/05 SCHEMATIC DEDIGN III/05 SCHEMATIC DEDIGN III/05 SCHEMATIC DEDIGN III/05 SCHEMATIC DEDIGNERTS III/05 SCHEMATIC TON DOCUMENTS IIII/05 SCHEMATIC TON DOCUMENTS IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	NO.	DESCRIPTION	DRAWN	CHECKED	DATE				
PHASE DRAWN CHECKED DATE SCHEMATIC DEBIGN III/05, SCHEMATIC DEBIGN IIII/05, SCHEMATIC DEBIGN IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII									
PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN III/05, DESIGN DEVELOPMENT III/05, GORD DEVELOPMENT III/05, GORD DEVELOPMENTS III/05, GORD DEVELOPMENTS IIII/05, GORD DEVELOPMENTS IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII									
PHASE DRAIN CHECKED DATE SCHEMATIC DESIGN III/05 SCHEMATIC DESIGN III/05 DESIGN DEVELOPMENT III/05 GRAIN GRAIN CHECKED SCHEMATIC DESIGN III/05 GRAIN DEVELOPMENT III/05 GRAIN DEVELOPMENTS IIII/05 GRAIN DEVELOPMENTS IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII									
PHASE DRAWN CHECKED Data SCHEMATIC DESIGN III/05, DESIGN DEVELOPMENT III/05, GORD DEVELOPMENTS III/05, SCALEMATIC DESIGN III/05, GORD DEVELOPMENTS III/05, SCALEMATIC DESIGN IIII/05, SCALEMATIC DESIGN IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII									
PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN II/05, DESIGN DEVELOPMENT II/07, GAR DOCUMENTS II/07, GAR DOCUMENTS II/07, GAR DOCUMENTS II/07, GAR DOCUMENTS II/07, GAR CONSTRUCTION DOCUMENTS II/07, BID SET TLC DNW GAR CHITECTS III/07, CONSTRUCTION DOCUMENTS III/07, III/07, Construction Number: III/07, Construction Number: III/07, Marcentry Propertion Documents: IIII/07, Construction Profession IIIIIIII PROJECT: PANAMA CITY BEACH			ļ						
Image: Draw Group Participation of the second of the se	Ð			CHECKED	DATE				
CONSTRUCTION DOCUMENTS 1020/10 92% CONSTRUCTION DOCUMENTS 2010/10 92% CONSTRUCTION DOCUMENTS 2010/10 SET TLC DNW 25/16 BID SET TLC DNW 25/16 SET TLC DNW 25/16 BID SET TLC DNW 25/16 SET TLC DNW 25/16 BID SET TLC DNW 25/16 SET TLC DNW 25/16 BID SET TLC DNW 25/16 VEXTOR SET 2100 25/16 VEXTOR SET 2100 21/17 SET SET 2100 21/17	4		Diversity	CHECKED					
BALENCENT DETERMINENTS Image: Construction pocurients Image: Construction pocurients <td< td=""><td>DE</td><td>aign devel opment</td><td></td><td></td><td>12/17/2</td></td<>	DE	aign devel opment			12/17/2				
Serve poount ruition Unit of the serve o	60	% DOCUMENTS			02/11/2				
CONSTRUCTION DOCUMENTS TLC DNU Ø5/16 BID SET TLC DNU Ø7/01 Image: Set in the	90	% CONSTRUCTION DOCUMENTS			Ø3/31/				
BID SET TLC DNU ØT/ØI BID SET TLC DNU ØT/ØI ARCHITECTS 2211 THOMAS DR., STE 1000 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 Commission Number: 21804 2100 WATEORID WATEORD Commission Number: 21804 WATEORD WATEORD Commission Number: 21804 WATEORD VATEORD Commission Number: 21804 WATEORD VATEORD Commission Number: 21804 WATEORD VATEORD Commission Number: 21804 MARCHITE VATEORD Commission Number: 21804 MARCHITER Commission Number: 21804 Commission Number: 21804 MARCHITER VATEORD Commission Number: 21804 MARCHITER Commission Number: 21804 Commission Number: 21804 MARCHITER Commission Number: 21804 Commission Number: 21804 MARCHITER PANAMA CITY BEACH Firedeal Longe Santians BAY COUNTY, FLORIDA SANITARY BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER:	0	NSTRUCTION DOCUMENTS	TLC		Ø5/16/				
221 THOMAS DR , STE 100 ARCHITECTS 221 THOMAS DR , STE 100 ANAMA CITY BEACH, FL HONE: (850) 236-9832 Commission Number: 21804 WATEORED WATE	BIC) SET	TLC		Ø7/Ø1/				
<image/> ACCOUNTY, FLORIDA PLUMBING SANITARY RISER DIAGRAMS									
ASSOCIATION STREET, MARTINAMENT, FLORIDA 2021 ASSOCIATION STREET, FLORIDA 2021 PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER:									
Marina Florida 2242 Forda Carificate of Authorization: 2222 PROJECT: PANAMA CITY BEACH FIRE STATION * 31 REPLACEMENT BAY COUNTY, FLORIDA BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER: PARET NUMBER:		WATFC ENGINEEI	RING						
PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMEN BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER: P3		4452 Clinton Street, Marianna, Florida 32446 Florida C 850.526.3447 Project Number: 2021-115 David N V	Certificate of Authori Vatford, PE Florida	zation: 27825 License 58208					
PANAMA CITY BEACH FIRE STATION # 31 REPLACEMEN BAY COUNTY, FLORIDA GHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS	PRC	DJECT:							
FIRE STATION # 31 REPLACEMEN BAY COUNTY, FLORIDA GHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS	5								
BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER: P23		PE GT / T / N # 31 E							
BAY COUNTY, FLORIDA SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER: P23	I								
SHEET TITLE: PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER:	в	AY COUNTY, FLORIDA							
PLUMBING SANITARY RISER DIAGRAMS SHEET NUMBER:	SHE	ET TITLE:							
RISER DIAGRAMS	F	LUMBING SANITAR	RY .						
	K	SIGER DIAGRAMS							
	1								
$\mathbf{P}_{\mathbf{S}}^{\mathbf{S}}$	SHE	ET NUMBER:		b	~ 1				
· - ·				P	ろし				



DESIGN CRITERIA

THE NEW FACILITY SHALL BE PROTECTED BY A WET PIPE SPRINKLER SYSTEM. INCLUDE A DOMESTIC WATER DEMAND OF - GPM ON THE MAIN SERVING THE SITE FIRE AND DOMESTIC WATER SYSTEMS. THE WET PIPE SYSTEM SHALL BE HYDRAULICALLY DESIGNED WITH AN OUTSIDE HOSE STREAM ALLOWANCE AS NOTED ON EACH SYSTEM ENGINEERING SUMMARY AND DENSITY VALUES AS FOLLOWS:

LIGHT HAZARD = 0.10 GPM/SF WITH A MAXIMUM OF 225 SF COVERAGE PER SPRINKLER

ORDINARY HAZARD GROUP 1 = 0.15 GPM/SF WITH A MAXIMUM OF 130 SF COVERAGE PER SPRINKLER

ORDINARY HAZARD GROUP 2 = 0.20 GPM/SF WITH A MAXIMUM OF 130 SF COVERAGE PER SPRINKLER

THE SPRINKLER DESIGN SHALL BE BASED ON THE MOST HYDRAULICALLY DEMANDING 1500 SF. THE CONTRACTOR IS ALLOWED TO REDUCE THE DESIGN AREA BASED ON THE USE OF QUICK RESPONSE SPRINKLERS AND CEILING HEIGHT IN ACCORDANCE WITH NFPA 13.

THE DESIGN OF THE SPRINKLER SYSTEM SHALL BE BASED UPON WATER SUPPLY INFORMATION OBTAINED BY THE SPRINKLER CONTRACTOR AND WITNESSED BY THE AUTHORITY HAVING JURISDICTION. WATER SUPPLY SHALL BE PRESUMED AVAILABLE AT THE POINT OF CONNECTION OF THE FIRE MAIN TO THE WATER SUPPLY SYSTEM. THE FOLLOWING FLOW TEST DATA WAS OBTAINED BY THE ENGINEER ON DECEMBER 14, 2021, PROVIDED BY SEAGO FIRE PROTECTION.

- HYDRANT #1

- MAINTAIN THE INTEGRITY OF ALL FIRE RATED ASSEMBLIES AND ACOUSTICAL ASSEMBLIES. CONTRACTOR SHALL COORDINATE SYSTEM DESIGN WITH ALL OTHER TRADES.
- JURISDICTION.
- 6. ALL PIPING SHALL OBSERVE PROPER PITCH. PROVIDE DRAINS FOR LOW POINTS.

- THE LOAD OF THE FIRE PROTECTION SYSTEM.
- OF PIPE AS A JOINING COMPOUND.
- IRON FITTINGS WITH JOINTS PER NEPA 13, CPVC PIPING IS NOT ACCEPTABLE.
- BACKFILL AS REQUIRED PER SPECIFICATIONS.
- CEILING TYPES.
- DEPARTMENT CONNECTION.



GENERAL NOTES

1. IT IS NOTED THAT SOME AREAS WILL BE REQUIRED TO BE PROTECTED AS ORDINARY HAZARD (MECHANICAL ROOMS, ETC.) THESE AREAS HAVE BEEN IDENTIFIED BY A DIFFERENT HATCHING PATTERN THEN THE LIGHT HAZARD AREAS ON THE PLANS.

2. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO OBTAIN CURRENT WATER FLOW DATA AND DESIGN SPRINKLER SYSTEMS ACCORDINGLY. SHALL OBTAIN CURRENT WATER FLOW DATA AND DESIGN MODIFICATIONS ACCORDINGLY.

5. CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING INSPECTOR'S TEST LOCATIONS IN ACCORDANCE WITH NFPA 13 AND THE AUTHORITY HAVING

7. THE SPRINKLER SYSTEM SHALL BE ARRANGED FOR FLUSHING. READILY REMOVABLE FITTINGS SHALL BE PROVIDED AT THE END OF ALL CROSSMAINS. 8. PIPE HANGERS SHALL BE INSTALLED AS REQUIRED BY NFPA 13 FOR SUPPORTING SPRINKLER PIPING. NO OTHER PIPING OR DEVICES SHALL BE ATTACHED TO THE SPRINKLER HANGER SYSTEM UNLESS THE HANGER HAS BEEN DESIGNED TO CARRY THE ADDITIONAL LOAD.

9. THIS CONTRACT DOES NOT INCLUDE ANY MATERIAL OR DEVICE TO IMPROVE THE STRUCTURAL STRENGTH OF THE BUILDING TO ENABLE IT TO CARRY

10. ALL UNDERGROUND PIPING SHALL BE DUCTILE IRON WITH FITTINGS AND JOINTS PER NFPA 13. TEFLON TAPE SHALL BE ADDED TO ALL MALE THREADS

11. ALL ABOVE GROUND WET SPRINKLER PIPE THAT IS THREADED SHALL BE SCHEDULE 40 BLACK WITH BLACK CAST/MALEABLE IRON FITTINGS WITH JOINTS PER NFPA 13. TEFLON TAPE SHALL BE ADDED TO ALL MALE THREADS OF PIPE AS A JOINING COMPOUND. CPVC PIPING IS NOT ACCEPTABLE 12. ALL ABOVE GROUND WET SYSTEM SPRINKLER PIPE THAT IS WELDED OR ROLL-GROOVED SHALL BE SCHEDULE 10 BLACK WITH BLACK CAST/MALEBLE

WATER BASED SPRINKLER SYSTEM REQUIREMENTS

- INFORMATION.
- ACCORDANCE WITH 2016 EDITION OF NFPA 14 AND LOCAL CODES.
- 3. REFER TO PLAN SHEETS AND HAZARD CLASSIFICATION LEGEND FOR HAZARD CLASSIFICATION OF EACH ROOM OR AREA.
- THE NEW SYSTEMS SHALL SHALL BE HYDRAULICALLY CALCULATED IN ACCORDANCE WITH NFPA 13. LIGHT HAZARD: 0.10 GPM/SF, MAX 225 SF PER HEAD, 15 FT MAX NOMINAL SPACING; ORDINARY TEMPERATURE RATING HEADS. ORDINARY HAZARD GROUP 1: 0.15 GPM/SF, MAX 130 SF PER HEAD, 15 FT MAX NOMINAL SPACING; INTERMEDIATE TEMPERATURE RATING HEADS.

FOR ADDITIONAL REQUIREMENTS, REFER TO DESIGN CRITERIA NOTES ON THIS SHEET.

- 5. THE POINT OF SERVICE CONNECTION IS A CIRCULATING MAIN.
- 6. REFER TO DESIGN CRITERIA NOTES ON THIS SHEET FOR FLOW TEST DATA.
- 7. REFER TO COMBINED RISER AND STANDPIPE DETAIL FOR VALVE AND SUPERVISION REQUIREMENTS
- MICROBIAL INDUCED CORROSION IS NOT ANTICIPATED IN THIS PROJECT.

- 11. NO FIRE PUMP IS REQUIRED.

1. THE POINT OF SERVICE, BACKFLOW PREVENTER, & FDC ARE SHOWN FOR REFERENCE ONLY. REFER TO THE CIVIL SITE UTILITY PLAN FOR FURTHER

2. THE BUILDING SHALL BE FULLY SPRINKLED IN ACCORDANCE WITH 2016 EDITION OF NFPA 13 AND LOCAL CODES. STANDPIPE DESIGN SHALL BE IN

ORDINARY HAZARD GROUP 2: 0.20 GPM/SF, MAX 130 SF PER HEAD, 15 FT MAX NOMINAL SPACING; INTERMEDIATE TEMPERATURE RATING HEADS.

9. REFER TO CIVIL SITE UTILITY DRAWINGS FOR BACKFLOW PREVENTER. MAXIMUM DESIGN PRESSURE DROP SHALL NOT EXCEED 3 PSI. 10. REFER TO DIVISION 21 SPECIFICATIONS FOR QUALITY AND PERFORMANCE SPECIFICATIONS OF ALL FIRE PROTECTION COMPONENTS.





SYSTEM ENGINEERING SUMMARY								
AREA SERVICED	11907 SF							
HYDRAULICALLY MOST REMOTE AREA	1500 SF							
HAZARD CLASSIFICATION OF REMOTE AREA	ORDINARY HAZARD GROUP 1							
SYSTEM DESIGN FLOW RATE (INDOOR)	292.5 GPM							
OUTSIDE HOSE STREAM DEMAND	250 GPM							
TOTAL WATER DEMAND	542.5 GPM							
WATER PRESSURE DATA	I							
END HEAD PRESSURE	7 PSI							
ELEVATION LOSS	11.26 PSI							
OUTSIDE FRICTION LOSS	.5 PSI							
BACK FLOW PREVENTOR	3 PSI							
SAFETY FACTOR	10 PSI							
AVAILABLE INSIDE FRICTION LOSS	51.76 PSI							



1. BECAUSE OF EXTREMELY TIGHT CLEARANCE IN THE CEILING SPACE, CAREFUL COORDINATION WITH ALL TRADES MUST BE

CLA	SSIFICATION
	LIGHT HAZARD
	ORDINARY HAZARD GROUP 1
	ORDINARY HAZARD GROUP 2

RF	VISIONS			
NO.	DESCRIPTION	DRAWN	CHECKED	DATE
PH	ASE	DRAWN	CHECKED	DATE
SCH	HEMATIC DESIGN			11/05/2
DE	BIGN DEVELOPMENT	KAJ	DNW	12/17/2
60	% DOCUMENTS	KAJ/KMM	DNW	@2/11/2
909	6 CONSTRUCTION DOCUMENTS	TLC	DNW	@3/31/
CO	NSTRUCTION DOCUMENTS			05/16/
BID	SET	TLC	DNW	/1/Ø1/@1/
	WATEC ENGINEE 4452 Clinton Street, Marianna, Florida 32446	DRD RING Certificate of Authoria	ration: 27825_	
PRO	WATECT:	DRD RING Certificate of Authoriz Natford, PE Florida I	ration: 27825 License 58208	
PRO	WATECT:	Certificate of Authoria Natford, PE Florida L	ation: 27825 icense 58208	
PRO D	VATEC ENGINEE 4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115 Florida N JECT: ANAMA CITY BEA	CH	ation: 27825 icense 58208	
PRO PEI	VATEC VVATEC VVATEC ENGINES 4452 Clinton Street, Marianna, Florida 32446 850.526.3447 Project Number: 2021-115 Florida (David N JECT: ANAMA CITY BEA RE STATION # 31 F	CH		1EN1
PRO PL	WATEC WATEC Mariana, Florida 32446 850.526.3447 Project Number: 2021-115 JECT:	CH		1EN1
	VATEC VVATEC VVATEC VVATEC VATECT: VANAMA CITY BEA RESTATION # 31 F VANAMA CITY BEA RESTATION # 31 F	CH EPLA		1EN1
	VATEC VVATEC VVATEC VVATEC VALCENTER VALCENTE VALC	CH		1EN1
	VATEC VVATEC VVATEC VATEC VANATA Storest, Marianna, Florida 32446 Storest, Storest VANAMA CITY BEA RE STATION # 31 F AY COUNTY, FLORIDA ET TITLE: RE PROTECTION #			1EN1
	VATEC VVATEC VVATEC VALUE	CH EPLAN		1EN1
	AT COUNTY, FLORIDA AT COUNTY, FLORIDA TITLE: CARE PROTECTION 1	CH EPLAN		1EN1
	AT COUNTY, FLORIDA AT COUNTY, FLORIDA TITLE: CARE PROTECTION 1	CH EPLAN		1EN1
	AVALUATION STREET NUMBER:	PLAN		1EN-

A−1 ('B')	A-1 ADJACENT TO ARROW INDICATES HOMERUN OF CIRCUIT NO. 1 TO PANEL A; "B" INDICATES FIXTURE TYPE; MARKS ACROSS RACEWAY RUN INDICATES THE NO. 12 CONDUCTORS; UNLESS NOTED OTHERWISE NO MARKS INDICATES TWO NO. 12 CONDUCTORS AND ONE NO. 12 GREEN GROUND CONDUCTOR IN 1/2" ₹ (2#12 & 1#12 GND-1/2"C)
0	CEILING FIXTURE
Сч	WALL BRACKET FIXTURE
₽	POLE MOUNTED FIXTURE
0	2' X 2' FIXTURE; CEILING MOUNTED; ARROW INDICATES LENS DIRECTION
	2' X 2' FIXTURE WITH INTEGRAL EMERGENCY BATTERY OR CONNECTED TO AN EMERGENCY CIRCUIT AS INDICATED; CEILING MOUNTED; ARROW INDICATES LENS
0	2' X 4' FIXTURE; CEILING MOUNTED
•	'2 X 4' FIXTURE WITH INTEGRAL EMERGENCY BATTERY OR CONNECTED TO AN EMERGENCY CIRCUIT AS INDICATED; CEILING MOUNTED
$\overline{\mathbf{Q}}$	EXIT SIGN; CEILING MOUNTED; ARROWS AS NOTED; SHADED SECTION INDICATES LIGHTED FACE OF EXIT SIGN
ର୍ଦ୍ଧି	EXIT SIGN; BACK MOUNTED; ARROWS AS NOTED; SHADED SECTION INDICATES LIGHTED FACE OF EXIT SIGN
0	JUNCTION BOX; MOUNTED ABOVE CEILING
O -	JUNCTION BOX; MOUNTED FLUSH IN WALL WITH BLANK COVER
₽	DUPLEX RECEPTACLE; 125V; 20A; 3 POLE GND; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA 5–20R; HUBBELL SERIES HBL5352
٢	CEILING MOUNTED SIMPLEX RECEPTACLE; 125V; 20A; 3 POLE GND; MT FLUSH IN CEILING UNLESS NOTED OTHERWISE; NEMA 5-20R; HUBBELL SERIES HBL53
⊕ =	QUAD RECEPTACLE; 125V; 20A; 3 POLE GND; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA 5-20R; HUBBELL SERIES HBL5352
Ø	TAMPER RESISTANT DUPLEX RECEPTACLE; 125V; 20A; 3 POLE GND; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA 5-20R; HUBBELL SERIES HBL SE
€=	QUAD RECEPTACLE; 125V; 20A; 3 POLE GND; GFI; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA GF-5-20R; HUBBELL SERIES GF5362
⊜=	DUPLEX RECEPTACLE; 125V; 20A; 3 POLE GND; GFI; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA GF-5-20R; HUBBELL SERIES GF5362
wp ©=	LETTERS "WP" ADJACENT TO SYMBOL INDICATES GFI WEATHER RESISTANT RECEPTACLE; HUBBELL HBL5362WR WITH WEATHERPROOF COVER; PASS AND SEYMOU COVER/BOX.
⊗=	DUPLEX RECEPTACLE FOR TELEVISION WITH TVSS PROTECTION, LED AND ALARM; 125V; 20A; 2 POLE; 3 WIRE; GND; SEE TELECOM PLANS FOR MOUNTING DET NEMA 5–20R; HUBBELL SERIES HBL5362SA
e	DUPLEX RECEPTACLE; 125V; 20A; 3 POLE GND; HALF-CONTROLLED RECEPTACLE; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA 5-20R; HUBBELL SI
₽	QUAD RECEPTACLE (TWO DUPLEX); 125V; 20A; 3 POLE GND; HALF-CONTROLLED RECEPTACLE; MT 18" AFF TO C/L UNLESS NOTED OTHERWISE; NEMA 5-20R SERIES BR20C1
Φ	COMBINATION POWER/TELECOM FLOOR BOX; FOUR DUPLEX RECEPTACLES; 125V; 20A; 3 POLE GND; NEMA 5-20R; HUBBELL SERIES HBL5352; REFER TO TE PLANS FOR FLOOR BOX PART NUMBERS, INSTALLATION DETAILS AND LOCATION.
¢	LETTERS +XX" ADJACENT TO SYMBOL INDICATES RECEPTACLE MOUNTING HEIGHT. +AC" = ABOVE COUNTER OR BACKSPLASH (+46" MAXIMUM TO TOP OF DEVICE) +DF" = VERIFY HEIGHT FOR DRINKING FOUNTAIN WITH MECHANICAL CONTRACTOR +TV" = VERIFY HEIGHT OF TV WITH OWNER. +SM" = VERIFY HEIGHT OF SECURITY MONITOR WITH OWNER. +DM" = VERIFY HEIGHT OF DISPATCH MONITOR WITH OWNER.
, X, 🔘	SPECIAL TYPE RECEPTACLE 'X' DENOTES NEMA TYPE; CEILING MOUNTED; VERIFY EXACT LOCATION & REQUIREMENTS WITH EQUIPMENT CONTRACTOR. A = 120V, 30A, 2P, 3W, NEMA L5–30R; HUBBELL SERIES HBL9330.
'Х' Ө -	SPECIAL TYPE RECEPTACLE 'X' DENOTES NEMA TYPE; WALL MOUNTED; VERIFY EXACT LOCATION & REQUIREMENTS WITH EQUIPMENT CONTRACTOR. A = 120V, 30A, 2P, 3W, NEMA L5-30R; HUBBELL SERIES HBL9330.
S	WALL SWITCH; 120/277V; 20A; 1 POLE; A.C. ONLY; MT 48" AFF TO C/L; HUBBELL SERIES HBL1221
S 3	WALL SWITCH; 120/277V; 20A; 3 WAY; A.C. ONLY; MT 48" AFF TO C/L; HUBBELL SERIES HBL1223
S 4	WALL SWITCH; 120/277V; 20A; 4 WAY; A.C. ONLY; MT 48" AFF TO C/L; HUBBELL SERIES HBL1224
SM	LOW VOLTAGE WALL SWITCH WITH VACANCY SENSOR; DUAL TECHNOLOGY; CONNECT TO LOCAL POWER PACK/ROOM CONTROLLER; MT 48" AFF TO C/L; REFER TO SPECS; WATTSTOPPER #LMDW—101—W.
SMD	LOW VOLTAGE DIMMING WALL SWITCH WITH VACANCY SENSOR; DUAL TECHNOLOGY; CONNECT TO LOCAL POWER PACK/ROOM CONTROLLER; MT 48" AFF TO C/L; REFER TO SPECS; WATTSTOPPER #LMDW—102—W.
S∟#	LOW VOLTAGE WALL SWITCH; CONNECT TO LOCAL POWER PACK/ROOM CONTROL; MT 48" AFF TO C/L; REFER TO SPECS; SEE LIGHTING CONTROL DETAILS LETTER "X" INDICATES BUTTON COUNT; REFER TO LOW VOLTAGE SWITCH SCHEDULE FOR SPECIFIC INFORMATION.
MS	MOTOR CONTROL SWITCH; 600V; 30A; 2 POLE; A.C. ONLY; NEAR OR ON EQUIPMENT BEING SERVED; HUBBELL SERIES HBL7832D.
WP MS	NEMA 3R MOTOR CONTROL SWITCH; 600V; 30A; 2 POLE; A.C. ONLY; NEAR OR ON EQUIPMENT BEING SERVED; HUBBELL SERIES HBL13R22D.

Sheet List Table								
Sheet	Sheet Title							
Number	mber							
E0.1	LEGEND AND NOTES							
E1.1	SITE PLAN - ELECTRICAL							
E2.1	FLOOR PLAN - POWER							
E3.1	FLOOR PLAN - HVAC POWER							
E4.1	FLOOR PLAN - MISC SYSTEMS							
E5.1	FLOOR PLAN - LIGHTING							
E6.1	ACCESSORY BLDG. FLOOR PLANS - ELECTRICAL							
E7.1	ELECTRICAL DETAILS							
E7.2	ELECTRICAL DETAILS							
E7.3	ELECTRICAL DETAILS							
E7.4	GROUNDING DETAILS							
E7.5	LIGHTING CONTROLS AND FIXTURE SCHEDULES							
E7.6	LIGHTING CONTROLS DETAILS							
E7.7	LIGHTING CONTROLS DETAILS							
E7.8	LIGHTING CONTROLS DETAILS							
E7.9	LIGHTING CONTROLS DETAILS							
E8.1	SINGLE LINE POWER RISERS							
E8.2	SCHEDULES							
E8.3	FIRE ALARM RISERS							
E8.4	ROLL-UP DOOR CONTROL RISER							

ELECTRICAL LEGEND

NUMBER OF CONDUIT

DIRECTION

361

ERIES BR20xxTR

OUR WIUFC10S

TAILS.

SERIES BR20C1

; HUBBELL

ELECOM

SPECIAL NOTE SEE TELECOM SHEETS FOR TELECOM, SECURITY AND A/V LEGENDS

ABBREVIATIONS

AHU —	AIR HANDLING UNIT
AFF —	ABOVE FINISHED FLOOR
C. –	CONDUIT
C/L -	CENTERLINE
COND -	CONDENSING UNIT
CP —	CIRCULATION PUMP
DMX —	DIGITAL MULTIPLEX
EC —	ELECTRICAL CONTRACTOR
EF —	EXHAUST FAN
EWC —	ELECTRIC WATER COOLER
EWH —	ELECTRIC WATER HEATER
FACP —	FIRE ALARM CONTROL PANEL
NNUNC –	FIRE ALARM ANNUNCIATOR
GFI —	GROUND FAULT PROTECTION
GND —	GROUND CONDUCTOR
01111	

GWH – GAS WATER HEATER HP – HEAT PUMP

LTG — LIGHTING

LTS – LIGHTS RECEPT - RECEPTACIE

UNO - UNLESS NOTED OTHERWISE WP – WEATHERPROOF

SIP WALL SWITCH; 120/277V; 20A; 1 POLE; A.C. ONLY; MT 48" AFF TO C/L; HUBBELL SERIES HBL1221; IN WEATHER PROOF ENCLOSURE IIGHTING CONTROLS SYSTEM NETWORK BRIDGE; INSTALL CONCEALED ABOVE CEILING; REFER TO LIGHTING CONTROLS DETAILS VACANCY SENSOR POWER PACK FOR RECEPTACLES; MOUNT ABOVE CEILING; REFER TO LIGHTING CONTROLS DETAIL RP RC ROOM CONTROLLER; INSTALL CONCEALED ABOVE CEILING SPACE; REFER TO LIGHTING CONTROLS DETAILS LOW VOLTAGE OCCUPANCY SENSOR; 360° DUAL-TECHNOLOGY TYPE; CEILING MOUNTED; UNLESS OTHERWISE NOTED; REFER TO LIGHTING CONTROLS DETAILS -@-LOW VOLTAGE VACANCY SENSOR; 360° DUAL-TECHNOLOGY TYPE; CEILING MOUNTED; UNLESS OTHERWISE NOTED; REFER TO LIGHTING CONTROLS DETAILS -W-D DIMMER SWITCH; 120V; SOLID STATE; SIZE AS NOTED; MT 48" AFF TO C/L OR ABOVE COUNTER/BACKSPLASH (+46" MAXIMUM TO TOP OF DEVICE) AS REQUIRED BY LOCATION. PANEL; 120/208V; MT 72" AFF TO TOP LNC LIGHTING NETWORK CONTROLLER LCP LIGHTING CONTROL PANEL MOTOR; FURNISHED BY OTHERS EXHAUST FAN; FURNISHED BY OTHERS Ð MAGNETIC STARTER; FURNISHED BY OTHERS \square □ NON-FUSED DISCONNECT SWITCH; AMP SIZE AS NOTED RACEWAY INSTALLED CONCEALED IN WALLS AND/OR ABOVE CEILING RACEWAY INSTALLED CONCEALED IN FLOOR SLAB AND/OR BELOW GRADE RACEWAY INSTALLED EXPOSED EMERGENCY RACEWAY INSTALLED CONCEALED \smile Low voltage conductor; coordinate with device connection requirements. ← FLEXIBLE CONDUIT CONNECTION CONDUIT STUB UP WITH FLEXIBLE CONDUIT CONNECTION TO EQUIPMENT FIRE ALARM SYSTEM MANUAL PULL STATION; MT 48" AFF TO C/L E 110**(C)--**FIRE ALARM SYSTEM STROBE; MT 80" AFF TO BOTTOM, '110' INDICATES CANDELA RATING, NO NUMBER INDICATES 75 CANDELA MINIMUM FIRE ALARM SYSTEM AUTOMATIC HEAT DETECTOR; 135 DEGREE/RATE OF RISE TYPE; CEILING MOUNTED Ð FIRE ALARM SYSTEM CARBON MONOXIDE DETECTOR; CEILING MOUNTED C \frown SELF-CONTAINED RESIDENTIAL SMOKE/CARBON MONOXIDE ALARM 120V. WITH BATTERY BACK-UP; PUSH-TO-TEST BUTTON & PILOT LIGHT; TANDEM TYPE (ONE ALARMS-ALL ALARM) FIRE ALARM SYSTEM AUTOMATIC SMOKE DETECTOR; CEILING MOUNTED FIRE ALARM SYSTEM AUTOMATIC AIR DUCT SMOKE DETECTOR 8 FIRE ALARM SYSTEM REMOTE INDICATOR FOR AIR DUCT SMOKE DETECTOR; MT 48" AFF TO C/L FIRE ALARM SYSTEM MAGNETIC DOOR HOLDER; MT 6'-6" AFF TO C/L Η NORMALLY CLOSED RELAY IN H.V.A.C CONTROL CIRCUIT TO OPEN UPON ACTUATION OF BUILDING FIRE ALARM SYSTEM TO SHUT DOWN A/C UNIT. CONTACTS RATED 5 AMPS, 120 VOLTS. FIRE ALARM SYSTEM SIGNAL SPEAKER/STROBE; MT 80" AFF TO BOTTOM, '110' INDICATES CANDELA RATING, NO NUMBER INDICATES 75 CANDELA MINIMUM FIRE ALARM SYSTEM EXTERIOR WEATHERPROOF SIGNAL SPEAKER/STROBE; MT 80" AFF TO BOTTOM, 75 CANDELA RATING UNLESS NOTED OTHERWISE FIRE ALARM SYSTEM EXTERIOR, WEATHERPROOF SIGNAL SPEAKER; MT 90" AFF TO BOTTOM WP**Q**X FIRE SPRINKLER SYSTEM FLOW/TAMPER SWITCH SMOKE DAMPER; SEE FIRE ALARM RISER DIAGRAM FOR DETAILS; SEE PLANS FOR LOCATIONS FSD FIRE/SMOKE DAMPER; SEE FIRE ALARM RISER DIAGRAM FOR DETAILS; SEE PLANS FOR LOCATIONS SV FIRE PROTECTION SPRINKLER SOLENOID VALVE; SEE FIRE ALARM RISER DIAGRAM FOR DETAILS; SEE PLANS FOR LOCATIONS PHOTOCELL; REFER TO LIGHTING CONTROLS DETAILS ELECTRICAL GENERAL NOTES A. CONTRACTOR SHALL COORDINATE ALL WORK WITH OTHER TRADES PRIOR TO INSTALLATION. REFER TO MECHANICAL AND PLUMBING DRAWINGS FOR EXACT SIZE AND LOCATION OF EQUIPMENT WHICH IS FURNISHED BY OTHERS AND CONNECTED BY ELECTRICAL. B. RECEPTACLES. SWITCHES AND COVERPLATES COLOR SHALL BE SELECTED BY THE ARCHITECT FROM STANDARD COLORS.

C. VERIFY ALL DOOR SWINGS WITH ARCHITECTURAL DRAWINGS PRIOR TO ROUGHING-IN WALL FOR SWITCHES. D. LOCATION OF LIGHTING FIXTURES, DISCONNECT SWITCHES, ETC. FOR MECHANICAL EQUIPMENT/ROOM SHALL BE COORDINATED WITH FINAL MECHANICAL EQUIPMENT LOCATION TO PROVIDE NATIONAL ELECTRIC CODE REQUIRED ACCESS SPACE. E. FINAL CONNECTION TO ALL MOTORS SHALL BE WITH FLEXIBLE CONDUIT CONNECTION. F. ALL EXIT AND EMERGENCY FIXTURES SHALL BE CONNECTED TO LIGHT CIRCUIT AHEAD OF LOCAL SWITCH. G. ALL PANELBOARDS, BACKBOARDS, TERMINAL CABINETS, ETC SHALL HAVE CUSTOM ENGRAVED MICARTA NAMEPLATE MECHANICALLY AFFIXED IDENTIFYING SYSTEM.

H. PROVIDE GREEN GROUND CONDUCTOR IN ALL CIRCUITS - SIZE PER N.E.C.

I. ALL EXPOSED CONDUITS, BOXES, STRAPS AND HANGERS IN THE CONTRACT AREA WHETHER NEW OR EXISTING THAT ARE PART OF THE ELECTRICAL SYSTEM SHALL BE PAINTED TO MATCH ADJACENT FINISH.

J. PROVIDE CONCRETE MARKER AT END OF ALL CONDUITS STUBBED OUT OF BUILDING FOR FUTURE USE. MARKER SHALL BE 6" DIA X 18" HIGH WITH 2" ABOVE FINISHED GRADE. INSCRIBE IN TOP OF MARKER "E" FOR ELECTRICAL,"T" FOR TELEPHONE,"V" FOR TV CABLE, "F" FOR FIRE ALARM, AND "IC" FOR INTERCOM. K. GENERAL CONTRACTOR SHALL FIELD-VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING ANY WORK, AND SHALL IMMEDIATELY NOTIFY THE ARCHITECT OF ANY DISCREPANCIES. FAILURE TO DO SO INDICATES THAT THE CONTRACTOR ACCEPTS THE CONDITIONS AS THEY EXIST, AND SHALL PERFORM THE WORK

REQUIRED AS SHOWN AND SPECIFIED.

SUBMITTALS. ANY ELECTRICAL EQUIPMENT, CONDUIT, AND WIRE SIZE CHANGES RESULTING FROM THIS REVIEW SHALL ALSO BE SUBMITTED FOR APPROVAL.

L. THE ELECTRICAL CONTRACTOR SHALL OBTAIN AND REVIEW THE MECHANICAL AND SPECIAL EQUIPMENT SUBMITTALS PRIOR TO SUBMITTING THE ELECTRICAL M. FIRE ALARM LOW VOLTAGE SOURCE AND BATTERY STANDBY SHALL ENERGIZE ALL ITEMS IN FIRE ALARM SYSTEM THAT REQUIRE POWER.

N. VERIFY EXACT LOCATION OF ALL FLOOR OUTLETS WITH THE ARCHITECT PRIOR TO ROUGHING-IN.

O. THE ELECTRICAL CONTRACTOR SHALL PROVIDE FAULT CURRENT CALCULATIONS FOR THE SERVICE EQUIPMENT AND SHALL MARK THE EQUIPMENT WITH THE AVAILABLE FAULT CURRENT AND DATE OF THE CALCULATION PER NEC 110.24. REFER TO TYPICAL SERVICE EQUIPMENT FAULT CURRENT LABEL DETAIL. P. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ARC FAULT LABELS PER NFPA 70E ARTICLE 110.16 FOR NEW EQUIPMENT. THE OWNER SHALL PROVIDE AVAILABLE CALCULATION DATA FOR THE EXISTING EQUIPMENT IN THE ELECTRICAL SYSTEM. REFER TO TYPICAL ARC FLASH HAZARD LABEL DETAIL.

Q. PROVIDE NEUTRAL AT ALL LINE VOLTAGE SWITCH LOCATIONS PER N.E.C. 404.2(C).

R. PROVIDE 'LSI' TRIP UNITS FOR ALL BREAKERS GREATER THAN OR EQUAL TO 200A.

S. PROVIDE CONDUIT BUSHINGS ON ALL ENDS OF CONDUITS.

- SP WALL SWITCH; 120/277V; 20A; 1 POLE; A.C. ONLY; PILOT LIGHT; LIGHT 'ON' WITH LOAD 'ON'; MT 48" AFF TO C/L; HUBBELL SERIES HBL1221PLC









***	OVERHEAD BAY DOORS NOTES ***
CONT	ACTOR SHALL INSTALL THE FOLLOWING FOR EACH BAY DOOR:
1. ON	E INTERIOR OVERHEAD MOUNTED PRESENCE SENSOR.
2. ON RE WI	E RADIO RECEIVER PER DOOR AND TWO DUAL BUTTON MOTES. REMOTE SHALL OPEN AND CLOSE OPPOSING DOORS 'H ONE REMOTE.









NOTES:

(1) CEILING FAN BEING PROVIDED AND INSTALLED BY OTHERS. ELECTRICAL CONNECTION TO BE MADE BY ELECTRICAL CONTRACTOR.

- ② MOUNT PHOTOCELL AS HIGH AS POSSIBLE FACING NORTH.
- ③ EXTEND CIRCUIT TO EXTERIOR LIGHTING FIXTURE FOR POWER AND CONTROL REQUIREMENTS.
- ④ INSTALL LIGHTING FIXTURE DATA/POWER SUPPLY EQUAL TO COLORKINETICS CM-150 CA gen2. MOUNT DEVICE 10'-0" AFF TO BOTTOM FOR MAINTENANCE PURPOSES.
- (5) INSTALL LIGHTING FIXTURE DATA/POWER SUPPLY EQUAL TO COLORKINETICS CM-150 CA gen2. MOUNT DEVICE ABOVE ACCESSIBLE CEILING SPACE.
- (6) INSTALL FIXTURE 'CC' USER INTERFACE SWITCH/ADJUSTMENT CONTROL AT 48" AFF FOR CONTROL OF COLOR CHANGING SOFFIT FIXTURES. REFER TO LIGHTING CONTROL DETAILS FOR MORE INFORMATION.
- ⑦ INSTALL JUNCTION BOX FOR CONNECTION TO BACKLIT NUMERICAL SIGNAGE. COORDINATE INSTALLATION MOUNTING HEIGHT AND LOCATION PRIOR TO ROUGHING IN.
- (8) LIGHTING FIXTURES TO BE INSTALLED AT TOWER SOFFIT EAVE.
- (9) INSTALL MANUAL OVERRIDE SWITCH ADJACENT TO TOUCH SCREEN INTERFACE CONTROL STATION.



*** CONSTRUCTION PHASING NOTE *** BASE BUILD = ALL CONSTRUCTION TO BE INSTALLED BEFORE THE MAIN FIRE STATION BUILD PORTION OF THIS PROJECT. <u>BUILD-OUT</u> = ALL CONSTRUCTION TO BE INSTALLED AFTER THE NEW FIRE STATION BUILDING HAS COMPLETE OCCUPANCY.



- ① INSTALL 1-3/4" EMPTY CONDUIT WITH PULLRIBBON, AND 2-1" EMPTY CONDUITS WITH PULLRIBBONS 36" PAST FOOTER AND BACK TO PANEL-T; FOR FUTURE USE. STUB-OUT, CAP AND MARK LOCATION.
- ② EXTEND CIRCUIT TO TEMPORARY HOUSING STRUCTURE. REFER TO SITE PLAN FOR APPROXIMATE LOCATION.
- ③ INSTALL DEVICE ABOVE FUTURE MEZZANINE FLOOR LEVEL. REFER TO ARCHITECTURAL PLANS FOR FINISHED FLOOR HEIGHT.
- (4) ALL LIGHTING FIXTURES TO BE RETURNED TO OWNER AFTER COMPLETION OF THE BUILD-OUT PHASE OF THIS STRUCTURE. THESE FIXTURES ARE THE SAME FIXTURES UTILIZED IN THE FIRE STATION BUILDING BAYS AND CAN BE USED AS FUTURE REPLACEMENTS AT THE OWNER'S DISCRETION.
- (5) INSTALL DISCONNECT, CONDUIT, AND CONDUCTORS AS INDICATED. DO NOT INSTALL CONNECTION WITHIN PANELBOARD UNTIL THE BUILD-OUT PHASE OF THIS PROJECT.
- (6) INSTALL CONNECTION TO BREAKER PROVIDED WITHIN PANELBOARD AS INDICATED.
- (1) INSTALL CONNECTION TO MOTORIZED DAMPER INSTALLED BY MECHANICAL CONTRACTOR AND CONNECTED BY ELECTRICAL CONTRACTOR. COORDINATE
- (1) LIGHTING FIXTURE TO BE RETURNED TO OWNER AFTER COMPLETION OF THE



E6.

SHEET NUMBER:





1. INSTALL WITH A MINIMUM CLEARANCE OF 15FT. FROM ALL BUILDINGS AND 5 FT. FROM ALL OBSTRUCTIONS.

- 2. CONCRETE SHALL HAVE A MINIMUM ULTIMATE 28 DAY COMPRESSIVE STRENGTH OF 3,000 LBS. PAD SHALL BE CURED 72 HOURS MIMNIMUM.
- 3. SECURE TRANSFORMER TO CONCRETE PAD WITH ANCHOR BOLTS PER MANUFACTURER'S SPECIFICATIONS.

STANDARD PAD FOR 300 THRU 1000KVA 3PH RADIAL OR LOOP FEED PAD MTD. TRANSFORMER NOT TO SCALE



TYPICAL POWER OUTLET INSTALLATION DETAIL NOT TO SCALE











KEY NOTES:

- Install grounded (neutral) conductor same size as the largest phase CONDUCTOR IF THE LINE-TO-NEUTRAL LOAD EXCEEDS 5% OF THE CONNECTED LOAD. IF NEUTRAL LOAD IS SMALLER, INSTALL THE NEC MINIMUM GROUNDED CONDUCTOR.
- ② NSTALL GROUNDING ELECTRODE CONDUCTOR, SIZED BASED ON NEC TABLE 250.66 USING THE SERVICE PHASE CONDUCTOR SIZE, BUT NOT SMALLER THAN NO 4.
- (3) INSTALL EQUIPMENT GROUNDING CONDUCTOR SIZED BASED ON NEC TABLE 250.122 USING THE FEEDER OVERCURRENT DEVICE SIZE.
- ④ 10 FOOT MINIMUM X 3/4" DIAMETER COPPER CLAD STEEL SECTIONAL DRIVEN GROUND ROD.
- (5) NSTALL BONDING JUMPER WIRE THAT IS SIZED BASED ON NEC TABLE 250-66 OR 250.28(D)(1) USING THE SERVICE OR SEPARATELY-DERIVED SYSTEM PHASE PHASE CONDUCTOR SIZE.
- (6) NSTALL A CONCRETE-ENCASED MAIN GROUNDING ELECTRODE IN THE BUILDING FOUNDATION PER NEC ARTICLE 250.52 (A) (3).
- ⑦ BOND EACH PERIMETER STRUCTURAL STEEL COLUMN TO THE CONCRETE-ENCASED MAIN GROUNDING ELECTRODE. USE COMPRESSION CONNECTORS THAT MEET IEEE 837 REQUIREMENTS OR USE EXOTHERMIC WELDS.
- (1) INSTALL A "MAIN GROUND ELECTRODE GROUND BAR" FOR SINGLE POINT GROUNDING. LOCATE AT AN ACCESSIBLE POINT NEAR THE SERVICE ENTRANCE EQUIPMENT. MAKE CONNECTIONS TO THE GROUND ELECTRODE CONDUCTOR USING IRREVERSIBLE CONNECTORS OR EXOTHERMIC WELDS. MAKE OTHER CONNECTIONS TO THE GROUND BAR USING TWO-HOLE COMPRESSION SPADE LUGS THAT MEET IEEE 837 REQUIREMENTS. LABEL EACH CONNECTION TO THE GROUND BAR.
- (9) FIRE ALARM CONTROL PANEL GROUND #6 COPPER CONDUCTOR.
- 1 INSTALL A COPPER GROUNDING BAR IN EACH TELECOMMUNICATIONS ROOM. CONNECT TO THE "MAIN GROUNDING ELECTRODE GROUND BAR" USING 600V INSULATED #4 COPPER CABLE AND COMPRESSION SPADE LUGS.

GENERAL NOTES

- THAN THE MINIMUM SIZES REQUIRED BY NEC.
- FOR INSPECTION, MAINTENANCE, AND TESTING.
- USING THE SERVICE PHASE CONDUCTOR SIZE.



1. BOND HOT AND COLD WATER PIPING SYSTEMS.

2. CONDUCTOR SIZES SHOWN ARE MINIMUM AND MAY BE LARGER

3. INSTALL GROUNDING CONNECTIONS TO BUILDING STRUCTURE AND WATER PIPES AT LOCATIONS THAT ARE VISIBLE AND ACCESSIBLE

4. INSTALL AN INSULATED THROAT GROUNDING BUSHING ON EACH METALLIC SERVICE ENTRANCE CONDUIT. BOND TO GROUND BUS USING CONDUCTOR THAT IS SIZED BASED ON NEC TABLE 250-66

5. INSTALL AN INSULATED THROAT GROUNDING BUSHING ON EACH METALLIC FEEDER CONDUIT. BOND TO GROUND BUS USING CONDUCTOR THAT IS SIZED BASED ON NEC TABLE 250-122 USING THE FEEDER CIRCUIT OVERCURRENT DEVICE SIZE OR THE SEPARATELY DERIVED SYSTEM OVERCURRENT DEVICE SIZE.



BASE BID LIGHTING FIX TURE SCHEDULE Project: 2181 - Panama City Beach Fire Station #31										
Note:	Per electrical specifica	tions, alternate fixtures shall be submi	tted to the en	gineer for pric	or approval	a minimum of (10) ten business	days prior to bid date. Any	alternate fixtures not submitted for prior approval will not be reviewed.	
Luminaire Designation	Manufacturer	Catalog Number	Connected Voltage	Luminaire Load (va)	Lamping Source	Color Rendering Index (CRI)	Kelvin Temperature	Mounting	Comments	
A24A	ARON LIGHTING	EDGET1-X-RTB-2'X4'-300-B1-40K8- UNV-DM-W	120V	35 VA	LED	>80	4000K	LAY-IN GRID	CONFERENCE ROOM; CORRIDOR FOR OFFICES	
A24AE	ARON LIGHTING	EDGET 1-X-RTB-2'X4'-300-B1-40K8- UNV-DM -E10W-W	120V	35 VA	LED	>80	4000K	LAY-IN GRID	INTEGRAL BATTERY BACK-UP; CORRIDOR FOR OFFICES	
A24B	ARON LIGHTING	EDGET1-X-RTB-2'X4'-300-B1-35K8- UNV-DM-W	120V	35 VA	LED	>80	3500K	LAY-IN GRID	DAYROOM	
A24BE	ARON LIGHTING	EDGET1-X-RTB-2'X4'-300-B1-35K8- UNV-DM-E10W-W	120V	35 VA	LED	>80	3500K	LAY-IN GRID	DA YROOM; INTEGRAL BATTERY BACK-UP	
С	HE WILLIAM S	75R-2-L25-840-45AMB-DRV-UNV	120V	19 VA	LED	>80	4000K	WALL MOUNT ABOVE DOOR 7'-6" AFF	CLOSET	
СР	GARDCO	SVPG-A01-840-5RD-SUR-UNV-WH	120V	21 VA	LED	>70	4000K	CEILING SURFACE	PORCH	
СРА	GARDCO	SVPG-A01-840-5RD-SUR-UNV-WH	120V	21 VA	LED	>70	4000K	CEILING PENDANT 14"-0" AFF TO BOTTOM	MAIN ENTRANCE	
DL	3G LIGHTING	3G-DL33RF-10-S80-35K-60D-UNV- DIM-WT-WI-SH-SF60	120V	11 VA	LED	>80	3500K	CEILING RECESSED		
DLA	3G LIGHT ING	3G-DL33RF-10-S80-40K-60D-UNV- DIM -WT-WI-SH-SF60	120V	11 VA	LED	>80	4000K	CEILING RECESSED		
FP	WE-EF	ETC130-GB LED ASC-VN 185-2677 + 185-0322 (BACKBOX)	120 V	18 VA	LED	>80	4000K	FLUSH IN CONCRETE	FLUSH IN CONCRETE FLAG POLE FIXTURE; PROVIDE WITH PRE-	
HB	HE WILLIAM S	GP2-L200-840-W-GP2-SMK-DRV-	120V	157 VA	LED	>80	4000K	CEILING SURFACE		
HBE	HE WILLIAM S	GP2-L200-840-W-EM/12W-GP2-SMK-	120V	157 VA	LED	>80	4000K	CEILING SURFACE		
L14	BEGHELLI	BS100LED-4-SA-LO-WT 40-120-277V- CH SS	120V	50 VA	LED	>80	4000K	CHAIN HUNG	INTEGRAL EMERGENCY BATTERY	
L14A	HE WILLIAM S	50F-S14-L45/840-F-AF12125-DIM-	120V	34 VA	LED	>80	4000K	9-0" AFF CEILING RECESSED		
L 14B	HEWILLIAMS	UNV 50F-S14-L65/840-F-AF12125-DIM-	120V	56 VA	LED	>80	4000K	CEILING RECESSED		
L 14RE	HEWILLIAMS	UNV 50F-S14-L65/840-F-AF12125-EM/10W-	120V	56 VA	LED	>80	4000K	CEILING RECESSED	INTEGRAL EMERGENCY BATTERY	
LINC		DIM-UNV 50F-S14-L65/840-F-AF12125-EM/10W-	1207	56 VA	LED	>80	4000K	LAVINGRID		
1.244	DAV PRITE	DIM-UNV	1207	27 VA	LED	>80	4000K			
L24A	DAV PRITE	2-FPZP60L-840-4-DS-UNV-DIM-	1201	37 VA	LED	>80	4000K			
L24AE	DAV DRITE	BSL10LST	1201	4/ VA	LED	>80	4000K		PLINE BOOMS (SLEEDING OUAPTERS	
L24B	DAV DRITE	2-FPZP48L-855-4-DS-UNV-DIM	1200	57 VA	LED	>80	5500K		CONTERENCE ROOM, CORRIDOR FOR OFFICES	
L24C	DAY-BRITE	2-FPZP30L-840-4-DS-UNV-DIM 2-FPZP30L-840-4-DS-UNV-DIM-	1200	23 VA	LED	>80	4000K	LA Y-IN GRID	CONFERENCE ROOM; CORRIDOR FOR OFFICES	
L24CE	DA Y-BRITE	BSL10ST	120V	23 VA	LED	>80	4000K	LAY-IN GRID	INTEGRAL BATTERY BACK-UP; CORRIDOR FOR OFFICES	
L24D	DAY-BRITE	2-FPZP30L-835-4-DS-UNV-DIM	120V	23 VA	LED	>80	3500K	LAY-IN GRID	KITCHEN; CORRIDOR FOR BUNK ROOMS	
L24DE	DAY-BRITE	BSL10ST	120V	23 VA	LED	>80	3500K	LAY-IN GRID	INTEGRAL BATTERY BACK-UP; KITCHEN; CORRIDOR FOR BUNK ROOMS	
L24F	DAY-BRITE	FMA24	120V	23 VA	LED	>80	3500K	CEILING FLANGED	DINING	
L24FE	DAY-BRITE	BSL10ST-FMA24	120V	23 VA	LED	>80	3500K	CEILING FLANGED	DINING; INTEGRAL BATTERY BACK-UP	
M 2	HE WILLIAM S	SLF-2-L13-830-HIA-DRV-UNV	120V	11 VA	LED	>80	3500K	ABOVE VAINT Y MIRROR	RESTROOMS	
PD	HE WILLIAM S	4CR-L5-855-(FINISH)-DIM I-UNV-R- W-CS	120V	7 VA	LED	>80	3500K	7'-6" AFF	ABOVE DINING TABLE	
PL2	GARDCO	GL 18-2-50LA-4835-NW-UNV- (FINISH)-	120V	50 VA	LED	>70	4000K	20'-0" AFG	TYPE II DISTRIBUTION; EQUAL SUBMISSIONS WILL NOT BE ACCEPTED.	
PL4	GARDCO	GL 18-4-105LA-4870-NW-UNV- (FINISH)	120V	105 VA	LED	>70	4000K	POLE MOUNT 20'-0" AFG	TYPE IV DISTRIBUTION; EQUAL SUBMISSIONS WILL NOT BE ACCEPTED.	
POLEFOR 'PL2', 'PL4'	VALMONT POLES	R2208-40606T4	N/A	N/A	N/A	N/A	N/A	CONCRETE ANCHOR BASE	23FT. ROUND TAPERED ALUMINUM POLE; 160M PH WITH 1.3 GUST FACTOF MINIMUM WIND RATING WITH 1.2 SQ.FT. EPA FIXTURE. EQUAL SUBM ISSIONS WILL NOT BE ACCEPTED.	
SB	HE WILLIAM S	WMAUD-4 - L40/840U/L40/840D/AF- EM10W-OCC120-DRVU/DRVD-UNV	120V	65 VA	LED	>80	4000K	BACK WALL 7'-6" AFF	INTEGRAL BATTERY BACK-UP; INTEGRAL SENSOR; LOCATE AT EACH LANDING	
SF	B-K LIGHTING	SN-24"-A-MM-LED-E72-MFL-WHW- 12-C-PC-TRE20	120V	3VA	LED	>70	4000K	WALL MOUNT 31'-4" AFG	CITY/STATION SEAL ON TOWER ILLUM INATION; ARM MOUNTED.	
SFA	B-K LIGHTING	SN-24"-A-MM-LED-E72-NSP-WHW- 12-C-PC-TRE20	120V	3VA	LED	>70	4000K	WALL MOUNT 10'-0" AFF	CITY SEAL OVER DOOR ILLUMINATION; ARM MOUNTED.	
SH	3G LIGHTING	3G-DL33RF-10-S80-35K-60D-UNV- DIM -WT-WI-SH-SF60-WL	120V	11 VA	LED	>80	3500K	CEILING RECESSED	NON CONDUCTIVE LENS	
SL	CHLORIDE	SDI-HL-C-(FINISH)-AM	120V	8 VA	LED		AMBER	RECESSED WALL 2'-0" AFF	BUNK ROOM CORRIDOR NIGHT (STEP) LIGHTING	
WP	GARDCO	121-16L-200-NW-G4-2-UNV-BK	120V	12 VA	LED	>70	4000K	WALL MOUNT 8'-0" AFG		
WPA	GARDCO	121-16L-700-NW-G4-4-UNV-BK	120V	38 VA	LED	>70	4000K	WALL MOUNT	EXTERIOR ABOVE FIRE TRUCK DOORS	
WPB	GARDCO	121-32L-700-NW-G4-4-UNV-BK	120V	70 VA	LED	>70	4000K	WALL MOUNT	EXTERIOR WALKWAY ENTRANCE ON ACCESSORY BUILDING	
X	CHLORIDE	ER55LD-3-R	120V	3.08	LED	N/A	N/A	BACK WALL		
	I	ADDITIVE A	LTERN	NATEI	LIG	ΗΤΙΝ	G FI	XTURE S	CHEDULE	
Note:	Per electrical specifica	ttions, alternate fixtures shall be submi	tted to the en	gineer for pric	or approval	a minimum of (10) ten business	days prior to bid date. Any	alternate fixtures not submitted for prior approval will not be reviewed.	
Luminaire Designation	Manufacturer	Catalog Number	Connected Voltage	Luminaire Load (va)	Lamping Source	Color Rendering Index (CRI)	Kelvin Temperature	Mounting	Comments	
CCA ADDITIVE ALTERNATE #1	COLOR KINETICS	VA YA TUBE (316-100029-01) POWER SUPPLY (309-000014-01)	24VDC	13.6	LED RGBW	N/A	N/A	SOFFIT SURFACE JUST BEHIND FASCIA	CONTROLS FOR A COMPLETE FINISHED INSTALLATION. ADDITIVE ALTERNATE #1 MUST BE ACCEPTED BEFORE ADDITIVE #2 OR #3 CAN BE INTILIZED	
CCB ADDITIVE ALTERNATE #2	COLOR KINETICS	VA YA TUBE (316-100029-01) POWER SUPPLY (309-000014-01)	24VDC	13.6	LED RGBW	N/A	N/A	SOFFIT SURFACE JUST BEHIND FASCIA	EXTERIOR SOFFITS; PROVIDE ALL NECESSARY APPURTENANCES FOR A COMPLETE FINISHED INSTALLATION. ADDITIVE ALTERNATE #1 M UST BE ACCEPTED BEFORE ADDITIVE #2 OR #3 CAN BE UTILIZED.	
CCC ADDITIVE	COLOR KINETICS	VA YA TUBE (316-100029-01) POWER SUPPLY (309-000014-01)	24VDC	13.6	LED RGBW	N/A	N/A	SOFFIT SURFACE JUST BEHIND FASCIA	EXTERIOR SOFFITS; PROVIDE ALL NECESSARY APPURTENANCES FOR A COMPLETE FINISHED INSTALLATION. ADDITIVE ALTERNATE #1 MUST BE	

SWITCH FUNCTION / CONTROL MATRIX																									
Poom #	Low Voltage Switch Button Qty. (Switch Model #)	Low Voltage Switch	Low Voltage Switch Button Oty.	Zone		Switch Button Number and Correlated Function (Button labels are recommendations and shall be designated by owner during installation)												Additional Notes							
Roomin		Control	Butto	on #1	Button	#2	Butto	on #3	Butto	Button #4		n #5	Butto	on #6	Butto	on #7	Button #8		Additional Hotes						
	(Switch Model h)	control	Function	Label	Function	Label	Function	Label	Function	Label	Function	Label	Function	Label	Function	Label	Function	Label							
101	2		ON	ON	OFF	OFF																			
101C	2		ON	ON	OFF	OFF																			
103	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
106	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
108	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
114	0	А	ON	ON	RAISE	RAISE					OFF	OFF	LOWER	LOWER											
114	8	В	ON				ON	ON	RAISE	RAISE					OFF	OFF	LOWER	LOWER							
114	0	С	ON	ON	RAISE	RAISE	1				OFF	OFF	LOWER	LOWER	()										
114	õ	D	ON				ON	ON	RAISE	RAISE					OFF	OFF	LOWER	LOWER							
118	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
119	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
120	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
122	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
124	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
126	4		ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER)										
128	4	А	ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER			4												
128	4	В	ON	ON	OFF	OFF	RAISE	RAISE	LOWER	LOWER															
134	2		ON	ON	OFF	OFF																			
135	2		ON	ON	OFF	OFF																			
136	2		ON	ON	OFF	OFF																			
00A, 100B, 100D, 102, 103A,																									
04, 105, 114A, 115-117, 121,	1 (LMDW-101)		ON/OFF	ON/OFF																					
23, 125, 127, 128A, 129-131																									
107, 110-113	2 (LMDW-102)		ON RAISE	On^	OFF/LOWER	OFFV	2																		



BUTTON ARRANGEMENTS NOT TO SCALE

LIGHTING CONTROL GENERAL NOTES

- A. THE DIAGRAMS ARE NOT INTENDED TO SHOW EXACT QUANTITIES OF DEVICES. REFER TO PLAN FOR ESTIMATED DEVICE QUANTITIES AND LOCATIONS.
- C. THE LOCAL DEVICE INTERCONNECTIONS FOR ALL LIGHTING CONTROL DEVICES SHALL BE OF THE TOPOLOGY FREE TYPE.
- D. COLORS FOR ALL DEVICES AND DEVICE COVERS SHALL BE SELECTED BY THE ARCHITECT.
- E. ALL DATA LINE SWITCHES SHALL INCLUDE CUSTOM ENGRAVED LABEL INDICATING FUNCTION OF SWITCH. COORDINATE EXACT LABEL DESCRIPTIONS WITH OWNER PRIOR TO INSTALLATION.
- F. PROVIDE ADDITIONAL POWER AND CONTROL MODULES AS RECOMMENDED BY THE SYSTEM SUPPLIER.
- G. THE DIAGRAMS REPRESENT A TYPICAL SYSTEM AND ARE NOT INTENDED FOR INSTALLATION, SYSTEM SUPPLIER SHALL PROVIDE INSTALLATION DRAWINGS AND WIRING DIAGRAMS.
- H. E.C. SHALL COORDINATE FIELD PROGRAMMING OF LIGHTING CONTROL SYSTEM WITH SYSTEM PROGRAMMER, SPECIFYING ENGINEER, AND OWNER TO ENSURE PROPER OPERATION AND TIME SCHEDULES.
- I. ALL EMERGENCY AND EXIT LIGHTING CIRCUITS SHALL BE CONNECTED TO CONTINUOUS POWER SOURCE AHEAD OF RELAY PANEL OR INDIVIDUAL RELAY COMPONENTS.
- J. INSTALL ALL CEILING SENSORS MINIMUM OF 6FT CLEAR OF DUCT REGISTERS.
- K. THE LIGHTING CONTROL AND EMERGENCY LIGHTING SYSTEMS SHALL BE CAPABLE OF BEING ACCESSED VIA THE LOCAL AREA NETWORK AND REMOTELY VIA AUTHORIZED PERSONNEL ONLY.
- L. PROGRAMMER / COMMISSIONING AGENT SHALL BE CERTIFIED BY THE EQUIPMENT MANUFACTURER ON THE SYSTEM INSTALLED.
- M. THE MANUFACTURER CERTIFIED TECHNICIAN WILL MEET ONSITE WITH THE ELECTRICAL CONTRACTORS TO COORDINATE INSTALLATION DETAILS, REVIEW BEST PRACTICES, AND DISCUSS PROJECT SPECIFIC CHALLENGES; PRIOR TO THE INSTALLATION BEING STARTED, ENABLING THE CONTRACTORS TO WORK WITH THE TECHNICIAN TO PREPARE AND MAKE CHANGES UP FRONT.
- N. THE MANUFACTURER'S LIGHTING SYSTEMS TEAM SHALL WORK ONSITE AFTER FIXTURE AND CONTROLS INSTALLATION IS COMPLETED. THE MANUFACTURER'S AGENT IS TO VERIFY THE PROJECT IS REVIEWED AND CHECKED FOR PROPER WIRING, INSTALLATION AND FUNCTIONALITY OF THE SYSTEM AS A WHOLE. ANY PROBLEMS SHALL BE ADDRESSED AND RESOLVED WITH THE ONSITE CONTRACTORS.
- 0. MANUFACTURER'S TECHNICIANS SHALL MAP OUT THE FIXTURE LOCATIONS AND ADDRESSES WITHIN THE LIGHTING CONTROL SOFTWARE. ASTRONOMIC TIMECLOCK EVENTS, SCENES, AND SCHEDULES ARE PROGRAMMED ACCORDING TO A PRE-DEFINED SCRIPT. THESE EVENTS, SCENES, AND SCHEDULES ARE TESTED AND FINALIZED FOR FINAL APPROVAL BY THE PROJECT'S OWNERSHIP.
- P. MANUFACTURER'S TECHNICIANS SHALL PROVIDE TRAINING FOR SYSTEM USERS AND THE SYSTEM MAINTENANCE TEAM. THE DETAILS OF THE TECHNOLOGY SHALL BE COVERED FROM A MAINTENANCE AND TROUBLESHOOTING POINT OF VIEW. THIS COVERS THE LIGHTING CONTROL SYSTEM AND ITS CORE FUNCTIONALITY, WITH A FOCUS ON HOW TO EDIT EXISTING SCENES AND ASTRONOMIC LIGHTING EVENTS.
- Q. THE MANUFACTURER'S REPRESENTATIVE SHALL PROVIDE IN-DEPTH TRAINING TO THE END USER ON MANAGING THE SPECIFIC CONTROL SYSTEM, GIVING THEM THE TOOLS AND KNOWLEDGE TO OPERATE THEIR SYSTEM.



DETAIL NOTES

1. SWITCH BUTTON LABELING INDICATES A DEFAULT SCHEME. OWNER TO PROVIDE ACTUAL LABELING DURING THE CONSTRUCTION PHASE OF THIS PROJECT. IF THE OWNER DOES NOT MAKE ANY DECISION, THEN THE DEFAULT LABELING MAY BE UTILIZED. VERIFY WITH OWNER PRIOR TO PROCEEDING WITH ORDERING OF ANY AND ALL BUTTON ENGRAVING.







Lo ^r (B	W V	olta abels to	be des	Swit	ch I	Mat	rix	
C	ONNECT	TO NET	WORKE ING CO	d roon Ntrol F	I CONTR PANEL	OLLER C	IR	
SL1 (1-Button)	SL2 (2-Button)	SL3 (3-Button)	SL4 (4-Button)	SL5 (5-Button)	SL8 (8-Button)	SMD (Vacancy 'Off')	SM (Vacancy 'Off')	Remarks
	-		Х					Refer to Dispatch Event Sequence of Operations.
	Х							Refer to Dispatch Event Sequence of Operations.
							Х	
	Х							Refer to Dispatch Event Sequence of Operations.
	Х							Refer to Dispatch Event Sequence of Operations.
			X X X					Refer to Dispatch Event Sequence of Operations.
						Х		
							Х	
	Х							
					x			Refer to Dispatch Event Sequence of Operations.
	Х		()	
	Х							Refer to Dispatch Event Sequence of Operations.
	X							
								Touch screen user interface; See details.

	[Dispa	tch Eve	e
			CC	NC
Event Type	Manual Activation	Automatic Activation	Raise Lighting Levels to 100% level over 30-seconds	
Dispatch Event Notification via EOC network		х	Х	Γ
Dispatch Event Notification via Push-Button	Х		X	Γ
Lighting Controls Dispatch Event Sequence	X	х	X	Γ
Door Timer Activation	Х	Х		
Traffic Light Activation (FUTURE)	Х	Х		

<u>1</u>		
LINE FEED	LOAD (VA)	RELAY
A-95	228	2
A-100	960	4
		6
		8

120V LOAD OUT MANUAL CONTROL ONLY

VIA LOCAL SWITCH

	~	S	YSTEM	208/	120V	3Ф	4W		_		0
	MDP	R	ATING	800A	M.L	.0.	22,000	AIC MINIMUM	-c a	ENG	NEERS
	IVIE I	ENCL	OSURE	NEN	MA 1	SURFA	CE MO	UNT			
		Ur	TIONS	BOLTO	N BREAD	XEKS			-		
T t	SERVING	CKT	BKR	LOAI	ECTED (VA)	CKT	BKR	SERVING	CKT #	CK1 #	
	PANEL-A	500	**3	140745	83204	3**	300	PANEL-M	2	1	FA
		-		-	-	ал. С	-		4	3	FAI
_	SPARE	- 125	-	-	- 0	-	- 60	SPARF	6	5	RO
		-	-	-	-	-	-		10	9	RO
L		-	-	-	-	-	-		12	11	
3	SPACE ONLY (60A FRAME)		3	-	0	3	30	SURGE PROTECTIVE DEVICE (TYPE-2)	14	13	RO
7		-	-	-	-	-	-		18	17	OA
										19	
	TOTAL CONNECTED LOAD =		22	23949 VA	/	360	=	622.1 A		21	
TF	S:									25	
*	PROVIDE 'LSI' TRIP UNIT MAIN BREAKER									27	AH
**	PROVIDE 'LSI' TRIP UNIT.									29	
										33	HP
										35	HP
T	S/REC PANEL (FIRE ST	ATIC	ON B	BUILE	DING)				37	
-		S	YSTEM	208/	120V	3Φ	4W		_	39	(EF
		R	ATING	500A	M.L	.0.	22,000	AIC MINIMUM		41	(EF
	A	ENCL	OSURE	NEN	MA 1	SURFA	CE MO	UNT		45	DH
		OF	TIONS	BOLT O	N BREA	KERS; 1	HREE I	EQUAL SECTIONS		47	(SF
Г		CKT	BKR	CONN	ECTED	CKT	BKR		CKT	49	HO
	SERVING	TRIP	POLE	LOAI	O (VA)	POLE	TRIP	SERVING	#	53	HO
	LTG - APPARATUS BAY - 100	20	1	1570	785	1	20	LTS - APPARATUS BAY - 100	2	55	HO
	LTS - 108-109, 114, 144A, 133	20	1	759	1255	1	20	LTS - 100A-100C, 101-107, 110-113, 131, 134	4	57	HO
-	REC - APPARATUS BAY - 100 REC - APPARATUS BAY - 100 - CORD REEL	20	1	360	360	1	20	REC - APPARATUS BAY - 100 REC - APPARATUS BAY - 100 - CORD REEL	8	61	SP
	REC - APPARATUS BAY - 100 - CORD REEL	20	1	360	360	1	20	REC - APPARATUS BAY - 100 - CORD REEL	10	63	SP
	REC - APPARATUS BAY - 100 - CORD REEL	20	1	360	360	1	20	REC - APPARATUS BAY - 100 - CORD REEL	12	65	SP.
~	REC - APPARATUS BAY - 100 REC - RECEPT - 101	20	1	1260	1080	1	20	REC - APPARATUS BAY - 100 REC - EWC	14	67	SP.
-	REC - ADMIN ASST - 103	20	1	900	1200	1	20	REC - ADMIN ASST - 103 - COMPUTER	18	71	SP.
	REC - STORAGE - 103A - COPIER	20	1	1200	960	1	20	REC - STORAGE - 103A	20	73	SP
-	REC - ADMIN ASST - 106 - COMPUTER	20	1	600	1400	1	20	REC - TOILET - 104	22	75	SPA
-	REC - ADMIN ASST - 106 REC - OFFICES - 107 & 110	20	1	1080	1200	1	20	REC - OFFICES - 107 & 110 - COMPUTER REC - OFFICES - 111 & 112 - COMPUTER	24	79	SPA
	REC - OFFICE - 113	20	1	1260	1440	1	20	REC - OFFICES - 111 & 112	28	81	SPA
	REC - OFFICE - 113 - COMPUTER	20	1	600	1260	1	20	REC - TOOLS -100A	30	83	SP
-	REC - KITCHEN - 114 - COFFEE MAKER	20	1	1500	1260	1	20	REC - KITCHEN -114 DEC KITCHEN 114 DISHWASHED	32		
2	REC - KITCHEN - 114	20	1	1200	1000	1	20	REC - KITCHEN - 114 - DISH WASHEK REC - KITCHEN - 114 - DISPOSAL	36		874 De2102
	REC - KITCHEN - 114	20	1	1200	1200	1	20	REC - KITCHEN - 114 - ICE MAKER	38	NOT	ES:
	REC - ELEC 109, LIGHTING CONTROLS	20	1	1000	1200	1	20	REC - KITCHEN - 114	40		P
	REC - KITCHEN - 114 - REFRIG	20	1	1200	1000	1	20	REC - KITCHEN - 114 - MICROWAVE REC - KITCHEN - 114 - REFRIG	42	l	
	REC - KITCHEN - 114 - REFRIG	20	1	1000	1080	1	20	REC - LIVING / DINING - 114	46		
	REC - LIVING / DINING	20	1	900	900	1	20	REC - LIVING / DINING - 114	48		
	REC - MECH - 132	20	1	1260	720	1	20	REC - RPT OFFICE - 117	50		
	REC - RPT OFFICE - 117 - COFFER REC - RPT OFFICE - 117 - CHARGER	20	1	720	1400	1	20	REC - BATH RM - 121	54		
	REC - BATH RM - 123	20	1	1400	1400	1	20	REC - BATH RM - 125	56		
-	REC - LAUNDRY - 127	20	1	1260	5000	2	30	REC - LAUNDRY - 127 - DRYER	58		
	REC - TURNOUT - 127 - WASHER (#HF-65)	20	2	1200	13520	2	70	REC - TURNOUT - 129 - DRYING CABINET (#TS-93)	62		
		-	-	-	-	-	-		64		
1	REC - FILL STATION - 100B - COMPRESSOR	80	3	22000	960	1	20	REC - UNIFORM STORAGE - 131	66		
			-		900	1	20	REC - CONFERENCE - 108 REC - CONFERENCE - 108	68 70		
	REC - IT - 108A - SERVER	30	2	2800	2800	2	30	REC - IT - 108A - SERVER	72		
		-		-	-	-	-		74		
	REC - IT - 108A	20	1	600	600	1	20	REC - IT - 108A	76		
	REC - IT - 108A REC - IT - 108A	20	1	600	600	1	20	REC - 11 - 108A REC - IT - 108A	78 80		
	FIRE ALARM CONTROL PANEL	20	*1	600	1080	1	20	REC - GEAR STORAGE - 100C	82	l	
	REC - SHOWER - 100D	20	1	1400	1400	1	20	REC - BATH RM - 128A	84	l	
	REC - OFFICER - 128 COMPLITER	20	1	900	900	1	20	REC - OFFICER - 128 REC - BUNK PM 126	86	l	
	REC - BUNK RM - 124	20	1	900	900	1	20	REC - BUNK RM - 122	90	l	
	REC - BUNK RM - 120	20	1	900	900	1	20	REC - BUNK RM - 119	92	l	
	REC - BUNK RM - 118	20	1	900	1260	1	20	REC - ICE MACHINE - TOOLS 100A	94	l	
	LTS - EATERIOR - WALL, FLAG, POLE	20	1	1200	845	1	20	LTS - TOWER INTERIOR	96	l	
	LTS - 100D, 115-128A, 130,132,135,136	20	1	1264	960	1	20	LTS - TOWER AND BAY COLOR CHANGING	100	l	
	LTS - LOWER ROOF COLOR CHANGING	20	1	960	5000	2	30	REC - LAUNDRY - 127 - DRYER	102		
	REC - LAUNDRY - 127 - WASHER	20	1	1200	-	-	-	 SDADE	104		
	REC - MED SUPPLY - 130 SPARE	20	1	- 1200	-	1	20	SPARE	106	l	
	SPARE	20	1		-	1	20	SPARE	110		
	SPARE	20	1	-	-	1	20	SPARE	112		
	SPACE ONLY SPACE ONLY	-			-	-		SPACE ONLY SURGE PROTECTIVE DEVICE (TYPE 2)	114		
	SPACE ONLY	-		-	-	-	- 50		118		
		1	-	-	-	-	-		120	I	
	SPACE ONLY	-									
	SPACE ONLY	-						•			

	S	YSTEM	208/	120V	3Ф	4W		2
NA	R	ATING	300A	M.L	.0.	22,000	AIC MINIMUM	
IM	ENCL	OSURE	NEN	1 A 1	SURFA	CE MO	UNT	-0
	OF	TIONS	BOLT O	N BREAL	KERS			-
								-
SERVING	CKT	BKR	CONN	ECTED	CKT	BKR	SERVING	CK
	TRIP	POLE	LOAL) (VA)	POLE	TRIP		#
) - APPARATUS BAY - 100	30	1	1920	1920	1	30	FAN (CF-2) - APPARATUS BAY - 100	2
) - APPARATUS BAY - 100		1	1920	214	1	20	FAN (CF-4,5) - COVERED PATIO - 133	4
DOOR - APPARATUS BAY - 100	30	2	800	800	2	30	ROLL-UP DOOR - APPARATUS BAY - 100	6
	-	-	-	-	-	-		8
DOOR (3/4HP) - APPARATUS BAY-100	20	2	800	800	2	20	ROLL-UP DOOR (3/4HP) - APPARATUS BAY-100	1
COD (2/4UD) ADDADATUC DAV 100	-	-	-	-	-	-		1
OOR(3/4HP) - APPARATUS BAY-100	20	2	800	800	2	20	ROLL-UP DOOR (3/4HP) - APPARATUS BAY-100	1
	- 70	-	-	-	-	- 15	OACU 1	
	/0	3	20125	2378	3	15	OACU-I	
	-	-	-		-	-		2
		-	- 2462	- 2462	-	- 25		2
	25	2	5402	5402	2	23	AH0-2	2
	-	-	2462	-	-	-		1 2
	25	4	3402	5774	2	25	AH0-4	2
	- 20	2	2005	- 2823	-	- 25	 HP 2	3
	20	- 2	2005	2023	- 2	23	III -2	3
	- 25	2	2823	- 3066	- 2	30	 HP_4	3
	25	2	2025	3000	2	50	111 -4	3
ALIST FAN IDH 14	- 20	-	1000	702	-	- 20	(EE 2) EVHALIST FAN ADDADATUS DAV 100	
AUST FAN - APPARATUS BAV - 100	20	1	792	1656	1	20	(FF-4) FXHAUST FAN - KITCHEN/DINING 114	4
(SE-1)- CORRIDOR 135	20	1	1584	1664	2	15	WM-11 MHP_1	4
P-1 GWH-1 IWH-1	20	1	270	- 1004	-	-		4
PLY FAN - KITCHEN/DINING 114	20	1	1656	336	1	20	(FF-7) EXHAUST FAN - APPARATUS BAY - 100	4
ING HOIST MOTOR	20	1	1200	2400	2	30	GENERATOR BLOCK HEATER	5
ING HOIST MOTOR	20	1	1200	-	-	-		5
ING HOIST MOTOR	20	1	1200	500	1	20	GENERATOR BATTERY CHARGER	5
ING HOIST MOTOR	20	1	1200	5200	2	40	WM-2.1 MHP-2	5
ING HOIST MOTOR	20	1	1200	-	-	-		5
ING HOIST MOTOR	20	1	1200	-	1	20	SPARE	6
	20	1	-	-	1	20	SPARE	6
	20	1	15	-	1	20	SPARE	6
	20	1		-	1	20	SPARE	6
LY	-	-	-	-	-	-	SPACE ONLY	6
LY	-	-	15	-	-	-	SPACE ONLY	7
LY	-	-	-	-	-	-	SPACE ONLY	7
.Y	-			-	-	-	SPACE ONLY	7
.Y	-	-	-	-	-	-	SPACE ONLY	7
Y	-	-	1.4	-	-	-	SPACE ONLY	7
LY	-		14	0	3	30	SURGE PROTECTIVE DEVICE (TYPE-2)	8
LY				-	-	-		8
								0

		S	YSTEM	208/	120V	3Φ	4W						
		R	ATING	125A	M.L	.0.	10.000 /	AIC MINIMUM					
		ENCL	OSURE	NEN	AA 1	SURFA	CE MO	UNT					
		01	PTIONS	BOLTO	NBREAL	KERS							
CKT	SERVING	CKT	BKR	CONN	ECTED	CKT	BKR	SERVING	CKT				
#		TRIP	POLE	LOAL) (VA)	POLE	TRIP		#				
1	LTG - APPARATUS BAY	20	1	400	400	1	20	LTG - EVIDENCE STORAGE	2				
3	REC - APPARATUS BAY	20	1	1080	1080	1	20	REC - APPARATUS BAY	4				
5	REC - EVIDENCE STORAGE	20	1	540	900	1	20	REC-EVIDENCE STORAGE	6				
7	REC - CITY STORAGE MEZZANINE	20	1	1080	1000	1*	20	FIRE ALARM CONTROL PANEL	8				
9	REC - EVIDENCE MEZZANINE	20	1	720	720	1	20	REC - EVIDENCE MEZZANINE	10				
11	LTG - BLDG EXTERIOR	20	1	142	720	1	20	REC - EVIDENCE INTAKE, STORAGE	12				
13	LTG - EVIDENCE STORAGE	20	1	373	400	1	20	LTG - CODE ENFORCEMENT STORAGE	14				
15	AHU-5	45	2	6342	2267	2	25	HP-5	16				
17		-	-		-	-	- 1		18				
19	REC - IT - 101 - SERVER	30	2	2800	360	1	20	REC - IT - 101 - SERVER	20				
21	Testan.		-	-	456	1	20	EF-6	22				
23	(EF-8) EXHAUST FAN - MEZZANINE 101B	20	1	156	12480	2	80	TEMPORARY HOUSING BUILDING	24				
25	SPARE	20	1	-	-	-	-		26				
27	SPARE	20	1	-	-	-	-		28				
29	SPARE	20	1			1	20	SPARE	30				
31	SPARE	20	1	12		1	20	SPARE	32				
33	SPACE ONLY	-	-	-	-	1	-	SPACE ONLY	34				
35	SPACE ONLY		-	1.4	-	1	-	SPACE ONLY	36				
37	SPACE ONLY	-	-	14	0	3	60	SURGE PROTECTIVE DEVICE (TYPE-2)	38				
39	SPACE ONLY	-	-		-	-	-		40				
41	SPACE ONLY	-	-		-	-	-		42				
	TOTAL CONNECTED LOAD - $34416 VA$ / $260 - 056 A$												
NOT	TO TAL CONNECTED LOAD -		-	HIU VA		500		75.0 A					
NOT	S:												

* PROVIDE BREAKER CAPABLE OF BEING LOCKED IN THE "ON" POSITION.

	MECHANICAL EQUIPMENT SCHEDULE																				
(VERIFY ALL EQUIPMENT CIRCUIT REQUIREMENTS WITH MANUFACTURERS SHOP DRAWINGS PRIOR TO ROUGH-IN)																					
			÷			EL	ECTR	ICAL I	OAD	1	I	PROTE	CTION	I	(ONDUC	TOR / CO	NDUIT SIZ	ΖE		
					MO	FOR(S) F	LA			Q			SPEC	IFIED		(CONDUCTO	RS	-		
						E .	SNING	MC	VA	CIE									E		
EQUIPMENT					2	GE	IOF	CIE	IER	CAL NNE	A	Ð	2	E	s		53	~	DON		
DESIGNATION	DES CRIPTION	CFM	VOLT	Φ	UП	LAR	REA	ELE HE/	OTI	TOJ COI VA	MC.	OM	TRI	POI	SET	QTJ	SIZI	GNI	col	DISC.	REMARKS
OAU-1	OUTSIDE AIR UNIT	1175	208	3	1	17		14		20125	61	70	70	3	1	4	#4	#8	1-1/4"	100/3/1	Single Point Connection
OACU-1	CONDENSING UNIT		208	3	1	6.6				2378	7.4	15	15	3	1	4	#12	#12	3/4"	30/3/3R	
AHU-1	AIR HANDLING UNIT	665	208	1	1	2.8		2.88		3462	21	25	25	2	1	3	#10	#10	3/4"	30/2/1	Single Point Connection; Integral air purification
AHU-2	AIR HANDLING UNIT	965	208	1	1	2.8		2.88		3462	21	25	25	2	1	3	#10	#10	3/4"	30/2/1	Single Point Connection; Integral air purification
AHU-3	AIR HANDLING UNIT	965	208	1	1	2.8		2.88		3462	21	25	25	2	1	3	#10	#10	3/4"	30/2/1	Single Point Connection; Integral air purification
AHU-4	AIR HANDLING UNIT	1100	208	1	1	4.3		2.88		3774	23	25	25	2	1	3	#10	#10	3/4"	30/2/1	Single Point Connection; Integral air purification
AHU-5	AIR HANDLING UNIT	795	208	1	1	2.8		5.76		6342	38	45	45	2	1	3	#8	#10	3/4"	60/2/1	Single Point Connection; Integral air purification
DH-1	DEHUMIDIFIER	155	120	1					324	324	2.8	15	15	1	1	2	#12	#12	3/4"	RECEPT	
HP-1	HEAT PUMP		208	1	1	9.64				2005	12	20	20	2	1	3	#12	#12	3/4"	30/2/3R	
HP-2	HEAT PUMP		208	1	1	13.57				2823	17	25	25	2	1	3	#10	#10	3/4"	30/2/3R	
HP-3	HEAT PUMP		208	1	1	13.57				2823	17	25	25	2	1	3	#10	#10	3/4"	30/2/3R	
HP-4	HEAT PUMP		208	1	1	14.74				3066	18	30	30	2	1	3	#10	#10	3/4"	30/2/3R	
HP-5	HEAT PUMP		208	1	1	10.9				2267	14	25	25	2	1	3	#10	#10	3/4"	30/2/3R	
EF-1	EXHAUST FAN	130	120	1	1					65	0.542	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Integral Disconnect
EF-2	EXHAUST FAN	1770	120	1	1	6.6				792	8.3	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Integral Disconnect
EF-3	EXHAUST FAN	1770	120	1	1	6.6		_		792	8.3	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Integral Disconnect
EF-4	EXHAUST FAN	1310	120	1	1	13.8				1656	17.25	30	30	1	1	2	#10	#10	3/4"	MOTORSWITCH	Interlocked with Kitchen Hood
EF-5	EXHAUST FAN	435	120	1	1	6.6				792	8.3	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Integral Disconnect, Interlocked with OAU-1
EF-6	EXHAUST FAN	420	120	1	1	3.8				456	3.8	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Integral Disconnect
EF-7	EXHAUST FAN	640	120	1	1	2.8				336	2.8	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Interlocked with IRH-1,2,3,4
EF-8	EXHAUST FAN	80	120	1	1	1.3	l l			156	1.5	20	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Interlocked with AHU-5
SF-1	SUPPLY FAN	350	120	1	1	6.6				792	8.3	15	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	Interlocked with Turn-Out Dryer
SF-2	SUPPLY FAN	1310	120	1	1	13.8				1656	17.25	30	30	1	1	2	#10	#10	3/4"	MOTORSWITCH	Interlocked with Kitchen Hood
CF-1	BIG ASS FAN		120	1	1	16				1920	16	30	30	1	1	2	#10	#10	3/4"	MOTORSWITCH	
CF-2	BIG ASS FAN		120	1	1	16				1920	16	30	30	1	1	2	#10	#10	3/4"	MOTORSWITCH	
CF-3	BIG ASS FAN		120	1	1	16				1920	16	30	30	1	1	2	#10	#10	3/4"	MOTORSWITCH	
CF-4	CEILING FAN		120	1	1	0.9				108	1	20	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	
CF-4	CEILING FAN		120	1	1	0.9				108	1	20	20	1	1	2	#12	#12	3/4"	MOTORSWITCH	
IRH-1	INFRARED GAS HEATER		120	1					48	48	0.5	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	
IRH-2	INFRARED GAS HEATER		120	1					48	48	0.5	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	
IRH-3	INFRARED GAS HEATER		120	1					48	48	0.5	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	
IRH-4	INFRARED GAS HEATER	11	120	1					48	48	0.5	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	
WM-1.1 MHP-1	MINI SPLIT SYSTEM	399	208	1	1	8				1664	12	15	15	2	1	3	#12	#12	3/4"	30/2/3R	Indoor Unit (WM) Powered from the Outdoor Unit (MHP-1)
WM-2.1 MHP-2	MINI SPLIT SYSTEM	920	208	1	1	25				5200	24	40	<u>4</u> 0	2	1	3	#8	#10	3/4"	30/2/3R	Indoor Unit (WM) Powered from the Outdoor Unit (MHP-2)
TP	TRAPPRIMER		120	1					50	50	0.4	15	15	1	1	2	#12	#12	3/4"	RECEPT	
CP-1	RECIRCULATION PUMP		120	1					120	120	1	15	15	1	1	2	#12	#12	3/4"	RECEPT	
IWH-1	GAS INSTANT WATER HEATER		120	1					50	50	0.4	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	
GWH-1	GAS WATER HEATER		120	1					50	50	0.4	15	15	1	1	2	#12	#12	3/4"	MOTORSWITCH	

FIRE ALARM RISER GENERAL NOTES

- A. THIS DIAGRAM IS NOT INTENDED TO SHOW EXACT QUANTITIES OF DEVICES. REFER TO PLAN FOR DEVICE QUANTITIES AND LOCATIONS.
- B. THE RISER REPRESENTS A TYPICAL SYSTEM AND IS NOT INTENDED FOR INSTALLATION, SYSTEM SUPPLIER SHALL PROVIDE INSTALLATION DRAWINGS AND WIRING DIAGRAMS.
- C. SEE FIRE PROTECTION INSTALLER FOR LOCATIONS AND QUANTITIES OF FLOW AND TAMPER SWITCHES.
- RECOMMENDED BY THE SYSTEM SUPPLIER.
- E. FIRE ALARM SYSTEM SHALL HAVE U/L/ APPROVED DIGITAL ALARM DIALER/COMMUNICATOR TO SEND ALARM SIGNAL TO LOCAL FIRE DEPARTMENT MONITORING SERVICE.

FLR

NOTES:

① FIRE ALARM CONTROL PANEL.

② BUILDING SPRINKLER FLOW AND TAMPER SWITCH. VERIFY EXACT LOCATION WITH SPRINKLER CONTRACTOR.

③ TELECOMMUNICATIONS BACKBOARD. CONNECT FIRE ALARM CONTROL PANEL FOR OUTSIDE COMMUNICATIONS LINE CAPABILITY.

④ INSTALL FIRE ALARM ANNUNCIATOR PANEL IN THE RECEPTION AREA TO MEET LIFE SAFETY CODE REQUIREMENT FOR "CONSTANTLY MONITORED LOCATION".

D. PROVIDE ADDITIONAL MONITOR AND CONTROL MODULES AS (5) INSTALL FIRE ALARM SYSTEM RELAY SUCH THAT THE FAN SHUTS DOWN UPON SPRINKLER SYSTEM ACTIVATION.

- A. THIS DIAGRAM IS NOT INTENDED TO SHOW EXACT QUANTITIES OF DEVICES. REFER TO PLAN FOR DEVICE QUANTITIES AND LOCATIONS.
- B. THE DIAGRAMS REPRESENT A TYPICAL SYSTEM AND ARE NOT INTENDED FOR INSTALLATION, SYSTEM SUPPLIER SHALL PROVIDE INSTALLATION DRAWINGS AND WIRING DIAGRAMS.
- C. PROVIDE ADDITIONAL POWER AND CONTROL MODULES AS RECOMMENDED BY THE SYSTEM SUPPLIER.
- D. BAY DOORS TO CLOSE WITHIN 4-MINUTES OF 'TIME-TO-CLOSE' FUNCTION INITIALIZATION UNLESS A 'STOP' FUNCTION IS ACTIVATED TO MAINTAIN AN 'OPEN-DOOR' CONDITION. 'TIME-TO-CLOSE' FUNCTION SHALL BE COORDINATED WITH THE FIRE CHIEF FOR LENGTH OF TIME TILL 'DOOR-CLOSE' OPERATION BEGINS.
- E. UPON ACTIVATION OF DISPATCH EVENT PUSH BUTTON, ALL BAY DOORS SHOULD OPEN. ALL BAY DOORS SHALL CLOSE AFTER 'TIME-TO-CLOSE' ACTIVATION HAS EXPIRED UNLESS OVERRIDDEN WITH A 'STOP' FUNCTION REQUEST TO MAINTAIN AN OPEN DOOR.
- F. LIGHTING FIXTURES CONTROLLED VIA A 'DISPATCH EVENT' OR AN DISPATCH EVENT PUSH BUTTON, SHALL BE FORCED "ON" UNTIL PROGRAMMED 'TIME-TO-CLOSE' FUNCTION HAS EXPIRED, AND THEN RESUME NORMAL OPERATION. REFER TO SEQUENCE OF OPERATION FOR LIGHTING CONTROL PROGRAM INFORMATION.
- G. VERIFY EACH DEVICE'S WIRING REQUIREMENTS WITH MANUFACTURER.

		IELECOM / SECURII	Y / AUDIO	VISUAL S	YSTEM LE			1	1
DEVICE SYMBOL	SYMBOL SUBSCRIPT - TYPE 'x'	DESCRIPTION	CAT 6 UTP (QTY)	CAT 6 STP (QTY)	RG-6 COAX (QTY)	18AWG/2COND (QTY)	JACK/MODULE TYPE	JACK/MODULE COLOR	MOUNTING HEIGHT AFF (UNO)
		BUILDING SUPPORT SYSTEM DEVICES							
4	DDC	DIRECT DIGITAL CONTROLS NETWORK OUTLET	(2)	-	-	-	RJ-45	VIOLET	COORDINATE W/CONTRACTOF
X	ELEC	ELECTRICAL OUTLET	(2)	-	-	-	RJ-45	BLUE	COORDINATE W/CONTRACTO
		WALL MOUNT PHONE DEVICES							
◀	-	WALL MOUNT PHONE OUTLET	(1)	<u>-</u>	-	-	RJ-45	GREEN	48"
		NETWORK DEVICES							
	-	DATA/VOICE OUTLET	(2)	-	-	-	RJ-45	GREEN	18"
₹	WAP	WIRELESS ACCESS POINT DATA OUTLET	(2)	-	-	-	RJ-45	GREEN	IN CEILING
	AW	DATA/VOICE OUTLET LOCATED ABOVE WORK SURFACE	(2)	-	-	-	RJ-45	GREEN	SEE DETAIL
WAP	-	CEILING MOUNTED WIRELESS ACCESS POINT DATA OUTLET, SEE DETAILS & NOTES	(2)	-	-	-	RJ-45	GREEN	SEE DETAIL
	-	FLOOR BOX - DATA/VOICE OUTLET	(2)		-	-	RJ-45	GREEN	SEE DETAIL
		BUILDING SYSTEM DEVICES							
Æ	-	TV/DISPLAY OUTLET	-	(1)	(1)		RJ-45 / F-CONN	MATCH FACEPLATE	90"
		RACEWAY & SUPPORTING INFRASTRUCTURE							
	-	CABLE TRAY - 18"X2"	-	-	-	-	-	-	SEE PLAN
		RACEWAY & SUPPORTING INFRASTRUCTURE - SITE							
	-	UNDERGROUND CONDUIT	-	-	-	-	-	-	SEE SITE; DETAILS
	-	HAND HOLE	-	-	-		-		SEE SITE; DETAILS
		INTERCOM SYSTEM							
-IC	-	INTERCOM CALL STATION - EXTERIOR	-	-	-	-	-	-	48"
-PB	-	HELP PUSH BUTTON STATION	-	-	-	-	-	-	48"; SEE DETAIL
		PAGING SYSTEM							
S	-	CEILING MOUNTED SPEAKER - INTERIOR	-	-	-	(1)	-	-	SEE DETAIL
	-	WALL MOUNTED SPEAKER - INTERIOR	-	-	-	(1)	-	-	8'-0"
S- x	BAY	WALL MOUNTED HORN TYPE SPEAKER - INTERIOR	-	-	-	(1)	-	-	15'-0"
~	EXT	WALL MOUNTED SPEAKER - EXTERIOR	-	-	-	(1)	-	-	15'-0"
		CAMERA SURVEILLANCE SYSTEM (CCTV) - ROUGH-IN ONLY							
CAM	-	WALL MOUNTED CAMERA - INTERIOR	-	-	-	-	-	-	IN CEILING
AM _{EXT}	-	WALL MOUNTED CAMERA - EXTERIOR	-	-	-	-	-	-	SEE DETAIL
		ACCESS CONTROL SYSTEM (ACS) - ROUGH-IN ONLY							
CR-	-	CARD READER	-	-		-	-	-	SEE DETAIL
DR-	-	REMOTE DOOR RELEASE	-	-	-	-	-	-	SEE DETAIL

SYSTEMS ANNOTATION LEGEND

$\langle 1 \rangle$	SHEET NOTE	TYPICAL ENLARGED PLAN REFERENCE
-	LEADER	
1	DIAGRAM NOTE	X X-XXX
0—	DIAGRAM LEADER	
c——	CONDUIT TURNING DOWN	ON WHICH DETAILED ENLARGED PLAN IS LOCATED BOUNDARY OF
o	CONDUIT TURNING UP	ENLARGED PLAN
E	CONDUIT STUB	

TELEC	COM ABBREVIATIONS:				
AW	ABOVE WORK-SURFACE				
AFF ADA	ABOVE FINISH FLOOR AMERICANS WITH DISABILITIES ACT				
ANSI AWG	AMERICAN NATIONAL STANDARDS INSTITUTE AMERICAN WIRE GAUGE				
AA	APPROVING AUTHORITY				
ARCH	AUTHORITY HAVING JURISDICTION				
BBC BAS	BONDING BACKBONE CONDUCTOR BUILDING AUTOMATION SYSTEM				
CT CAT 3	CABLE TRAY CATEGORY 3				
CAT 5E	CATEGORY 5 ENHANCED				
CAT 6A	CATEGORY 6 AUGMENTED				
CATV	COMMUNICATIONS OUTLET COMMUNITY ANTENNA TELEVISION				
COND C	CONDUCTOR CONDUIT				
CP CFCI	CONSOLIDATION POINT CONTRACTOR FURNISHED, CONTRACTOR INSTALLED				
CFOI OTR	CONTRACTOR FURNISHED, OWNER INSTALLED OWNER'S TECHNICAL REPRESENTATIVE				
		_			
ELEC	ELECTRICAL				
EMI	ELECTROMAGNETIC INTERFERENCE ENERGY MANAGEMENT CONTROL SYSTEM				
EMT FCC	ELECTRICAL METALLIC TUBING FEDERAL COMMUNICATIONS COMMISSION				
FO HH	FIBER OPTIC HANDHOLE				
IAW					
MTR	MAIN TELECOMMUNICATIONS ROOM				
MH MAX	MAINTENANCE HOLE MAXIMUM				
um MIN	MICRON / MICROMETER MINIMUM				
MUTOA MM	MULTI-USER TELECOMMUNICATIONS OUTLET ASSEMBLY MULTIMODE				
NEMA	NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION				
NESC	NATIONAL ELECTRICAL CODE NATIONAL ELECTRICAL SAFETY CODE				
NFPA N/A	NATIONAL FIRE PROTECTION ASSOCIATION NOT APPLICABLE				
NIC OFCI	NOT IN CONTRACT OWNER FURNISHED, CONTRACTOR INSTALLED				
OFOI OSP	OWNER FURNISHED, OWNER INSTALLED OUTSIDE PLANT				
PR	PAIR PATCH PANEL				
PVC	POLYVINYL CHLORIDE	-			
PBB	POLL BOX PRIMARY BONDING BUSBAR	REVISIONS			
RMU	RACK MOUNTED UNIT	NO. DESCRIPTION	DRAWN	CHECKED	DATE
RM R/I	ROOM ROUGH-IN				
ScTP SBB	SCREENED TWISTED-PAIR SECONDARY BONDING BUSBAR				
SVTC STP	SECURED VIDEO TELECONFERENCE SHIELDED TWISTED-PAIR				
SM	SINGLEMODE SUBFACE MOUNT				D4#5
STR	STRANDS	SCHEMATIC DESIGN		CHECKED	11/05/21
TEBC	TELECOMMUNICATIONS BONDING BACKBONE TELECOMMUNICATIONS EQUIPMENT BONDING CONDUCTOR				12/17/21
TBC TER	TELECOMMUNICATIONS BONDING CONDUCTOR TELECOMMUNICATIONS EQUIPMENT ROOM	90% CONSTRUCTION DOCUMENTS			Ø2/11/22 Ø3/31/22
TR TIA	TELECOMMUNICATIONS ROOM	CONSTRUCTION DOCUMENTS			Ø5/16/22
TYP UL	TYPICAL UNDERWRITERS LABORATORIES INC	BID SET			Ø7/Ø1/22
UPS	UNINTERRUPTIBLE POWER SUPPLY		MAS DE	R, STE	100 Ei
UNO	UNLESS NOTED OTHERWISE		: (85Ø);	236-98	, T L 32
VolP	VOICE OVER INTERNET PROTOCOL	ARCHITECIS commissio	n Number:	21804	
		CONSULTANTS:			
		918 HIL	OLOGY SHWAY	GROUF 98 EAS	а Т
			IN, FL 3 30.427. NTECHGRC	32541 2140 IUP-LLC.C	ом
	TYPICAL ELEVATION SYMBOL				
	ELEVATION VIEW DIRECTION	PROJECT:			
	VIEW NUMBER	PANAMA CITY BEA	,CH		ب
		FIRE STATION # 31 F		ACEM	1EN I
	NUMBER OF SHEET ON				
		BAY COUNTY, FLORIDA			
	IYPICAL SECTION SYMBOL	TELECOM LEGEND	AND '	NOTE	S
	DETAIL VIEW DIRECTION				
		SHEET NUMBER:			→ 1
	NUMBER OF SHEET ON WHICH DETAIL IS LOCATED				

- DETAIL NUMBER

NUMBER OF SHEET ON WHICH DETAIL IS LOCATED

TYPICAL VIEW TITLE

/ INDICATES PLAN NORTH - VIEW NUMBER N X-XXX SCALE: 1/8"=1'-0" ∠ VIEW SCALE NUMBER OF SHEET ON WHICH PLAN IS LOCATED TRUE NORTH ARROW

WHICH DETAIL IS LOCATED

TELECOMMUNICATIONS GENERAL NOTES - FACILITY INFRASTRUCTURE

THE TELECOMMUNICATIONS DRAWINGS PROVIDED ARE DIAGRAMMATIC AND SHOW THE GENER LOCATION OF ALL REQUIRED DEVICES; SUCH AS OUTLETS, RACEWAYS, EQUIPMENT, AND APPURTENANCES. THEY DO NOT SHOW ALL NECESSARY OFFSETS, JUNCTION BOXES, CABLE/LADDER TRAY TRANSITIONS, CONDUIT SLEEVES/PENETRATIONS, AND ADJUSTMENTS NECESSARY BY COORDINATION WITH OTHER TRADES IN THE FIELD.

TELECOMMUNICATION CONTRACTOR'S SCOPE OF WORK: TELECOMMUNICATION'S CONTRACTOR SHALL BE RESPONSIBLE FOR ENTIRE STRUCTURED CABLING SYSTEM ELEMENTS DEFINED IN THE SCOPE OF WORK. THIS INCLUDES A COMPLETE INSTALLATION OF ALL PASSIVE INFRASTRUCTURE ELEMENTS SUCH AS OUTLETS, JACKS, CABLING, CABINETS, RACKS. BACKBOARDS, LADDER TRAK (LIMITED TO TELECOM ROOMS), TELECOM EQUIPMENT ROOM/CABINET BONDING, TERMINATIONS TESTING, LABELING, WARRANTIES, AND ALL REQUIRED CLOSE-OUT DOCUMENTS. THE TELECOMMUNICATIONS CONTRACTOR SHALL UNDERSTAND THE FULL INTENT OF THE DRAWING AND SPECIFICATIONS PRIOR TO BID, AND WILL INCLUDE IN SCOPE OF WORK ALL REQUIREMENT NECESSARY TO ENSURE A FULLY FUNCTIONAL SYSTEM.

<u>COORDINATION:</u> WITH OTHER TRADES EXAMINE AND REVIEW THE DOCUMENTS OF ALL DIVISIO IN ORDER TO COORDINATE THE INSTALLATION OF WORK. USE DIMENSIONED DRAWINGS TO VER THE SPACE NECESSARY FOR LOCATING OUTLETS, RACEWAYS, AND EQUIPMENT. USE FIELD MEASUREMENTS TO VERIFY DIMENSIONS WHERE AREAS ARE CONGESTED, AND EXACT LOCATI IS CRITICAL TO ENSURE PROPER INSTALLATION. COORDINATION SHALL INCLUDE, BUT NOT BE LIMITED TO; VERIFYING THE LOCATION AND SIZE OF OPENINGS/PENETRATIONS IN FLOORS, WAI PARTITIONS, CEILINGS, AND ROOFS WITH THE INSTALLING TRADES; ALLOCATION OF SPACE WIT OTHER TRADES, INSTALLING WORK IN CHASES, SHAFTS, CEILING INTERSTITIAL SPACES, AND EQUIPMENT SPACES; AND THE PHASING OF INSTALLATION WORK WITH THAT OF OTHER TRADES

INSTALLATION SHALL CONFORM WITH NFPA 70 "NATIONAL ELECTRICAL CODE," ANSI/TIA, AND ELECTRICAL SPECIFICATIONS (UNO).

CABLING INSTALLATION: ALL CABLING ROUTED IN SLAB, BELOW VAPOR BARRIER OR BELOW GRADE, SHALL BE U.L. LISTED FOR WET LOCATIONS THAT COMPLIES WITH NFPA 70 (NEC): PART 725.3(L), 110.11, 300.5(B), 300.6, AND 310.10(G). DO NOT USE PLENUM OR RISER RATED CABLE, AN UNLISTED CABLES IN SUCH AN ENVIRONMENT. FOR IN-FLOOR CONDUIT SYSTEMS, PROVIDE HOR RUNS BACK TO THE TR SERVING THAT AREA.

USE A FILL RATIO OF 40 PERCENT FOR CONDUIT SIZING. DO NOT INSTALL MORE THAN FOUR, FOUR-PAIR CABLES IN A 1 INCH (27 MM) CONDUIT.

PROVIDE PULL STRING IN ALL EMPTY CONDUITS AND INNERDUCT. PULL STRING TO BE RATED F 200LBS IN ALL CONDUITS.

TELECOMMUNICATIONS FACEPLATES SHALL MATCH ELECTRICAL SWITCH AND RECEPTACLE PL/ FINISHES. PROVIDE COVER PLATES FOR ALL UNUSED J-BOX LOCATIONS.

LABEL ALL CABLES WITHIN 4 INCHES OF EACH TERMINATION. PROVIDE 12 INCHES SERVICE LOO THE WORK AREA END OF EACH HORIZONTAL CABLE.

INSTALL VELCRO CABLE TIES TO ALL CABLE BUNDLES IN CABLE TRAY, NON-CONTINUOUS SUPPORTS, RACK WIRE MANAGEMENT, D-RINGS AND OTHER SUPPORT MEANS. BUNDLE ALL DIFFERENTIATING NETWORK CABLING SEPARATELY.

BALANCED TWISTED-PAIR CABLING SHALL BE SEPARATED FROM FLUORESCENT LAMPS AND ASSOCIATED FIXTURES BY A MINIMUM OF 5 IN.

NON-CONTINUOUS CABLE SUPPORTS (WHEN SPECIFIED): SUPPORTS MUST NOT EXCEED 20 CABLES OR 50 PERCENT OF THE FILL CAPACITY, WHICHEVER IS LESS; INTERVALS NOT TO EXCE FT.

CABLING INSTALLATION IN CABLE TRAYS:

A MINIMUM OF 12 IN ACCESS HEADROOM SHALL BE PROVIDED AND MAINTAINED ABOVE A CABL TRAY SYSTEM OR CABLE RUNWAY.

A MINIMUM OF 3 IN CLEAR VERTICAL SPACE SHALL BE AVAILABLE ABOVE ACCESSIBLE CEILING, BELOW THE CABLE TRAY.

THE MAXIMUM FILL OF ANY CABLE TRAY SHALL NOT EXCEED 25% (UNO), ALLOWING FACILITY US AN ADDITIONAL 25% SPARE CAPACITY. THE MAXIMUM FILL DEPTH OF ANY CABLE TRAY SHALL NE EXCEED 6 IN.

MAIN TELECOM ROOM (MTR) / TELECOM ROOMS (TRs):

CONTRACTOR SHALL COORDINATE WITH GENERAL CONTRACTOR TO ENSURE TELECOM ROOMS ARE DIMENSIONALLY CONSTRUCTED AS DESIGNED. THIS INCLUDES USING FIELD MEASUREMEN TO VERIFY ROOM DIMENSIONS, CONDUIT LOCATIONS (PRIOR TO CONCRETE POUR), WALL PENETRATIONS, AND DEVICE PLACEMENT.

INSTALL BACKBOARDS IN ACCORDANCE WITH TIA-569-D. BACKBOARDS MUST BE FIRE-RETARDA TREATED WOOD, BEARING THE MANUFACTURER'S STAMP. IF PAINTED, THE MANUFACTURER'S F RATED STAMP MUST REMAIN VISIBLE.

INSTALL FLOOR MOUNTED EQUIPMENT RACKS / CABINETS LOCATED AT OR NEAR THE CENTER OF THE TELECOMMUNICATION ROOM. MAINTAIN A MINIMUM OF 36 INCHES SPACE BOTH IN FRONT A IN BACK OF THE RACK, MEASURED FROM THE EQUIPMENT, AND A MINIMUM SIDE CLEARANCE OF INCHES ON AT LEAST ONE END OF THE RACK OR ROW OF ADJACENT RACKS IS REQUIRED. PROVIDE 25% SPARE CAPACITY WITHIN EACH UTILIZED RACK.

FURNITURE/MILLWORK:

ENSURE THAT THE CABLE IS PROTECTED AT ALL TRANSITION POINTS, AND THAT METALLIC SEPARATION IS PROVIDED BETWEEN TELECOMMUNICATION AND POWER WIRING IN THE UTILIT' COLUMNS AND SYSTEMS FURNITURE TRACK IN ACCORDANCE WITH TIA-569-D AND NFPA 70.

	ELECTRICAL GENERAL NOTES - FACILITY INFRASTRUCTURE:	
<u>.</u> RAL	ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE ENTIRE INTERIOR ROUGH-IN AND SUPPORT SYSTEM NECESSARY FOR THE COMPLETE STRUCTURED CABLING SYSTEM DEFINED IN THIS SCOPE OF WORK. THIS INCLUDES A COMPLETE INSTALLATION OF ALL REQUIRED PATHWAYS INCLUDING: CABLE TRAY (EXCLUDES TRAY IN MTR/TR), CONDUIT, BACK BOXES, JUNCTION BOXES, FLOOR BOXES, BLOCKING, GROUNDING CONDUCTORS AND BUSBARS, FIRESTOPPING, POWER, AND ANY OTHER NECESSARY APPURTENANCES.	B IN C C
DR HIS RE AY IS.	THE ELECTRICAL CONTRACTOR SHALL UNDERSTAND THE FULL INTENT OF THE DRAWINGS AND SPECIFICATIONS PRIOR TO BID, AND WILL INCLUDE IN SCOPE OF WORK ALL REQUIREMENTS NECESSARY TO SUPPORT THE TELECOMMUNICATIONS SYSTEM TO COORDINATE AND ENSURE A FULLY FUNCTIONAL SYSTEM.	F T A
GS TS DNS RIFY ION	<u>COORDINATION WITH OTHER TRADES:</u> EXAMINE AND REVIEW THE DOCUMENTS OF ALL DIVISIONS IN ORDER TO COORDINATE THE INSTALLATION OF WORK. USE DIMENSIONED DRAWINGS TO VERIFY THE SPACE NECESSARY FOR LOCATING OUTLETS, RACEWAYS, AND EQUIPMENT. USE FIELD MEASUREMENTS TO VERIFY DIMENSIONS WHERE AREAS ARE CONGESTED, AND EXACT LOCATION IS CRITICAL TO ENSURE PROPER INSTALLATION. COORDINATION SHALL INCLUDE, BUT NOT BE LIMITED TO, VERIFYING THE LOCATION AND SIZE OF OPENINGS/PENETRATIONS IN FLOORS, WALLS, PARTITIONS, CEILINGS, AND ROOFS WITH THE INSTALLING TRADES; ALLOCATION OF SPACE WITH OTHER TRADES, INSTALLING WORK IN CHASES, SHAFTS, CEILING INTERSTITIAL SPACES, AND EQUIPMENT SPACES; AND THE PHASING OF INSTALLATION WORK WITH THAT OF OTHER TRADES.	В 1 2 3 С С Р С С Р С
LLS, TH	INSTALLATION SHALL CONFORM WITH NFPA 70 "NATIONAL ELECTRICAL CODE," ANSI/TIA, AND ELECTRICAL SPECIFICATIONS (UNO).	A A
	<u>CONDUIT:</u> INSTALL ELECTRICAL METALLIC TUBING (EMT) CONDUIT FROM THE CABLE BACKBONE DISTRIBUTION SYSTEM, WHETHER CABLE TRAY OR ENCLOSED DUCT, TO EACH OUTLET (UNO).	II H
ΓV,	PROVIDE A MINIMUM OF 1 INCH EMT CONDUIT FOR STANDARD OUTLETS. WHEN CABLE TRAY OR ENCLOSED DUCT IS NOT USED, INSTALL INDIVIDUAL CONDUITS FROM THE MTR/TR TO EACH OUTLET.	В <u>Р</u>
ND ME	CONDUITS HAVE BEEN SIZED BASED ON THE NFPA, AS WELL AS ANSI/TIA 569. WHERE INSTALLATIONS VARY, INCREASE CONDUITS SIZES ACCORDING TO MAXIMUM NUMBER OF CABLES BASED ON ALLOWABLE FILL RATIO OF 40%.	P P S
	FOR IN-SLAB, BELOW VAPOR BARRIER OR BELOW GRADE CONDUIT SYSTEMS, PROVIDE HOME RUNS BACK TO THE MTR/TR SERVING THAT AREA.	A • •
OR	METALLIC PATHWAYS 3 FT OR GREATER IN LENGTH SHALL COMPLY WITH THE BONDING REQUIREMENTS OF ANSI/TIA-607.	• P
ATE DP AT	FOR CONDUITS WITH AN INTERNAL DIAMETER OF 2 IN OR LESS, THE INSIDE RADIUS OF A BEND IN CONDUIT SHALL BE AT LEAST 6 TIMES THE INTERNAL DIAMETER. FOR CONDUITS WITH AN INTERNAL DIAMETER OF MORE THAN 2 IN, THE INSIDE RADIUS OF A BEND IN CONDUIT SHALL BE AT LEAST 10 TIMES THE INTERNAL DIAMETER. BENDS IN THE CONDUIT SHALL NOT CONTAIN ANY KINKS OR OTHER DISCONTINUITIES THAT MAY HAVE A DETRIMENTAL EFFECT ON THE CABLE SHEATH DURING CABLE PULLING OPERATIONS.	S S V C
	CONDUITS SHALL BE REAMED TO ELIMINATE SHARP EDGES. METALLIC CONDUIT SHALL BE TERMINATED WITH AN INSULATED BUSHING.	В
EED 5	DO NOT USE FLEXIBLE METAL CONDUIT FOR TELECOMMUNICATIONS WIRING <u>EXCEPT</u> WHEN INSTALLING ACCESS FLOOR BOXES IN AN ACCESS FLOOR, WHERE THE ACCESS FLOOR BOX MAY BE RELOCATED WITHIN A SPECIFIED SERVICE AREA. IN THIS CASE THE LENGTH OF THE FLEXIBLE METAL CONDUIT MUST NOT EXCEED A LENGTH OF 20 FEET (6 M) FOR EACH RUN PER TIA-569-D.	
E	ALL PENETRATIONS SHALL BE SEALED WITH AN APPROVED SEALANT OR U.L. LISTED PENETRATION DEVICE THAT WILL MAINTAIN THE FIRE, SMOKE AND WATERPROOF OR OTHER APPLICABLE RATINGS OF THE TYPE OF CONSTRUCTION BEING PENETRATED. SEE ARCHITECTURAL DRAWINGS FOR PENETRATION REQUIREMENTS.	
SERS NOT	UNLESS NOTED OTHERWISE, ALL CONDUITS SHALL BE INSTALLED CONCEALED UNDER FLOOR SLABS, ABOVE THE CEILING AND WITHIN THE FINISHED WALLS. ALL OUTLET BOXES SHALL BE INSTALLED FLUSH MOUNTED WITHIN FINISHED WALLS, CEILINGS OR FLOORS. SURFACE MOUNTED RACEWAY AND OUTLET BOXES SHALL NOT BE PERMITTED ON FINISHED WALLS, CEILINGS OR FLOORS EXCEPT AS INDICATED ON THE DRAWINGS.	
IS	WHEN SURFACE MOUNT RACEWAYS ARE INDICATED, PROVIDE RACEWAY TO EMT TRANSITIONAL ADAPTER AT ALL ACCESSIBLE CEILINGS. ABOVE ACCESSIBLE CEILING, ROUTE EMT TO SERVING CABLE TRAY OR SERVING MTR/TR.	
NTS	PULL ROPE SHALL BE INSTALLED IN ALL CONDUITS. PULL ROPE SHALL HAVE A MINIMUM 200LB TENSILE STRENGTH FOR ALL TELECOMMUNICATIONS CONDUITS.	
ANT FIRE	WORK AREA OUTLETS: INSTALL DOUBLE GANG ELECTRICAL BOXES, MINIMUM STANDARD SIZE 4-11/16 INCHES SQUARE AND 2-1/8 INCHES DEEP WITH APPROPRIATELY SIZED PLASTER RING FOR CONNECTION OF SINGLE GANG OR DOUBLE GANG FACEPLATE	
OF AND 0F 24	INSTALL OUTLET BOX FOR RECESS MOUNTING WITH THE FACEPLATE FLUSH WITH THE WALL	
	DO NOT PUT OUTLET BOXES IN SAME STUD CAVITY WHERE BOXES ARE ON EACH SIDE OF STC RATED WALLS.	
Y	<u>POWER:</u> INSTALL A QUADRUPLEX ELECTRICAL OUTLET WITHIN 6 INCHES OF ALL WORK AREA OUTLETS TO SERVE TELECOMMUNICATIONS LOADS ASSOCIATED WITH THAT OUTLET.	
	TELECOM GROUNDING / BONDING	

CABLE TRAYS:

THE MAXIMUM FILL OF ANY CABLE TRAY SI FILL DEPTH OF ANY CABLE TRAY SHALL NO

THE SPAN FOR CABLE SUPPORT SYSTEMS ACCORDANCE WITH THE MANUFACTURER'S CAPACITY FOR A GIVEN SPAN. THESE SYS BASIC METHODS:

CANTILEVER BRACKETS FROM A WAL
 TRAPEZE OR INDIVIDUAL ROD SUPPO

3. OR FROM BELOW.

CABLE TRAY SUPPORTS SHALL BE LOCATE CONNECTIONS BETWEEN SECTIONS OF TH POINT AND ONE-QUARTER THE DISTANCE (PLACED WITHIN 24 IN ON EACH SIDE OF AN CROSS.

A MINIMUM OF 12 IN ACCESS HEADROOM S ABOVE A CABLE TRAY SYSTEM OR CABLE

INSTALL CABLE TRAY WITH SWEEPING RAD HARD 90° TURNS.

BOND CABLE TRAY PER ANSI/TIA 607, AND

PULL BOXES:

PULL BOXES SHALL BE READILY ACCESSIB PLACED IN A FIXED FALSE CEILING SPACE SUITABLY MARKED ACCESS PANEL.

A PULL BOX SHALL BE PLACED IN A CONDU

- THE LENGTH IS OVER 100 FT;
- THERE ARE MORE THAN TWO 90° BEN
 OR THERE IS A REVERSE (U-SHAPED)

PULL BOXES SHALL BE PLACED IN A STRAI SHALL NOT BE USED IN LIEU OF A BEND. TH SHALL BE ALIGNED WITH EACH OTHER.

WHERE A PULL BOX IS REQUIRED WITH CO OUTLET BOX MAY BE USED AS A PULL BOX

IF THE PULL BOX IS COMPRISED OF METAL BONDED TO GROUND.

]
DWARE FOR TELECOM SYSTEMS; HREADED RODS, BLOCKING, SUPPORT						
HALL NOT EXCEED 50%. THE MAXIMUM OT EXCEED 6 IN.						
SHALL BE DETERMINED IN S MAXIMUM RECOMMENDED LOAD STEMS MAY BE SUPPORTED BY THREE						
_L; DRTS FROM ABOVE;						
ED WHERE PRACTICAL SO THAT HE TRAY FALL BETWEEN THE SUPPORT OF THE SPAN. A SUPPORT SHALL BE NY CONNECTION TO A BEND, TEE, OR		-				
SHALL BE PROVIDED AND MAINTAINED RUNWAY.						
DIAL TURNS. DO NOT INSTALL WITH						
GROUNDING DETAILS / NOTES.						
3LE. PULL BOXES SHALL NOT BE UNLESS IMMEDIATELY ABOVE A						
UIT RUN WHERE:						
NDS, OR EQUIVALENT;) BEND IN THE RUN.						
IGHT SECTION OF CONDUIT. THEY HE CORRESPONDING CONDUIT ENDS						
ONDUITS SMALLER THAN 1-1/4", AN K.						
LIC COMPONENTS, IT SHALL BE		P				
		NO.	DESCRIPTION	DRAWN	CHECKED	DATE
		P		DRAWN	CHECKED	DATE
		DE	SIGN DEVELOPMENT			12/17/21
		60 30	% DOCUMENTS % CONSTRUCTION DOCUMEN	ITS		Ø2/11/22 Ø3/31/22
		- 00	NSTRUCTION DOCUMENTS			Ø5/16/22
			ARCHITECTS	211 THOMAS D PANAMA CITY PHONE: (850) Commission Number:	R. , STE BEACH 236-98 21804	100 +, FL 332
				DESTIN, FL 0 850.427. W.LOGANTECHGR	GROU 98 EA 32541 .2140 oup-LLC.	
	NICATIONS DIS>		PANAMA CITY IRE STATION #	BEACH * 31 REPL	ACEI	1ENT
	ONNU RICCI PIEUT	В	AY COUNTY, FLORID	Д		
	USHUAA.LOGAN BICSI ID # 160273 BICSI ID # 160273		ELECOM NOTE	5		
	- VODA -	9HE	ET NUMBER:	=	$\dagger C$)2

NOTE

- THE MANUFACTURER'S PRINTED INSTRUCTIONS AND THESE REQUIREMENTS.
- SOURCE AND DESTINATION.

≠ 1

| | _

FIRE STATION #31 TELECOM NEW WORK FLOOR PLAN

SCALE: 1/8"=1'-0"

	G	ENERAL NOTES:			
	1.	REFER TO LEGEND AND NOTE FOR ADDITIONAL INFORMATIC	es, shee)n.	TS T0.1 A	ND T0.2
	2.	FOR SITE PLAN AND DETAILS, AND T1.1.	REFER 1	O SHEET	rs t1.0
	3.	FOR ADDITIONAL DETAILS, RE T2.3.	FER TO	SHEETS	Г2.1 -
	4.	FOR SINGLE LINE DIAGRAM, R AND T3.2.	EFER TC	SHEETS	5 T3.1
	<u>Sł</u>				
	1.	PROVIDE LOCKABLE TELECON DETAIL 2/T5.1.	M CABINE	ET, REFEI	R TO
_					
_					
	¥ 2′	DESCRIPTION	DRAWN	CHECKED	DATE
	PH	IASE	DRAWN	CHECKED	DATE
	SCł	HEMATIC DESIGN			11/Ø5/21
	DES 60	81GN DEVELOPMENT % DOCUMENTS			12/17/21 Ø2/11/22
	309	& CONSTRUCTION DOCUMENTS			Ø3/31/22
					Ø5/16/22
	<u> </u>				0 11 0 11 2 2
		IJRA RCHITECTS 2211 THO PANAM, PHONE: commission	MAS DI 4 CITY (850) n Number:	R., STE BEACH 236-98 21804	100 , FL 32
	CON	SULTANTS:			
			C		V
	-		OLOGY HWAY IN, FL O.427.	GROUF 98 EAS 32541 2140 JUP-LLC.0	сом
	PRO	UECT:			
	W- ш	PANAMA CITY BEA IRE STATI <i>O</i> N # 31 F	CH EPL,	ACEM	1ENT
DIBUT	B,	AY COUNTY, FLORIDA			
ON DESIGNER	A TI P	ET TITLE: CCESSORY BUILD ELECOM NEW WOR I LANS	ING < FLC	DOR	

ALGISTERED COM	BICSTID # 160273 EXPIRES 12-31-24
 0'	8'

SHEET NUMBER:

- PROVIDE LASER PRINTED COMMUNICATIONS OUTLET IDENTIFIER ON FACEPLATE UNDERNEATH LABEL.

TYPICAL FOR:

REVISIONS NO. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/Ø5/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS Ø2/11/22 90% CONSTRUCTION DOCUMENTS @3/31/22 - CONSTRUCTION DOCUMENTS Ø5/16/22 BID SET Ø7/Ø1/22 2211 THOMAS DR. , STE 100 **R**// PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS commission Number: 21804 CONSULTANTS: LOGAN 918 HIGHWAY 98 EAST DESTIN, FL 32541 D 850.427.2140 WWW.LOGANTECHGROUP-LLC.COM PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT BAY COUNTY, FLORIDA SHEET TITLE: TELECOM DETAILS SHEET NUMBER: Ŧ2.,

- 10. CABLE TRAY / METALLIC PATHWAYS: ALL METALLIC TELECOMMUNICATIONS PATHWAYS SHALL BE BONDED TO THE PBB. ADDITIONALLY, CABLE TRAY SECTIONS SHALL BE BONDED TOGETHER, AND TO THE PBB. BOND TRAYS TOGETHER BY CONNECTOR PLATES OF AN IDENTICAL TYPE AS THE CABLE TRAY SECTIONS. PROVIDE NO. 2 AWG BARE COPPER WIRE THROUGHOUT CABLE TRAY SYSTEM, AND SPECIFIED, THEY SHALL BE SUPPORTED BY STANDOFF INSULATORS AT INTERVALS NO GREATER BOND TO EACH SECTION, EXCEPT USE NO. 1/0 ALUMINUM WIRE IF CABLE TRAY IS ALUMINUM. THAN 2 FT OR BE CONTAINED IN ELECTRICAL NONMETALLIC TUBING (ENT). BARE BONDING TERMINATE CABLE TRAYS 10 INCHES FROM BOTH SIDES OF SMOKE AND FIRE PARTITIONS. INSTALL CONDUCTORS SHALL NOT BE IN CONTACT WITH METALLIC SURFACES OR OTHER CONDUCTORS THAT CONDUCTORS RUN THROUGH SMOKE AND FIRE PARTITIONS IN 103 MM 4 INCH RIGID STEEL CONDUITS ARE NOT PART OF THE TELECOMMUNICATIONS BONDING SYSTEM. WITH GROUNDING BUSHINGS, EXTENDING 305 MM 12 INCHES BEYOND EACH SIDE OF PARTITIONS. SEAL CONDUIT ON BOTH ENDS TO MAINTAIN SMOKE AND FIRE RATINGS OF PARTITIONS.
- 5. BOND EACH CONDUIT AND CONDUIT SUPPORT STRUTS IN MTR WITH 6 AWG BONDING CONDUCTOR.
- 6. PRIMARY BUSBAR PBB (AKA TMGB): HAVE DIMENSIONS OF 6.35 MM (0.25 IN) THICK X 100 MM (4 IN) WIDE AND SIZED IN ACCORDANCE WITH THE IMMEDIATE APPLICATION REQUIREMENTS AND WITH CONSIDERATION OF FUTURE GROWTH.
- 7 BONDS TO THE PBB: WHEN THE OUTSIDE PLANT CABLES IN THE TELECOMMUNICATIONS ENTRANCE ROOM OR SPACE INCORPORATE A CABLE SHIELD ISOLATION GAP, THE CABLE SHIELD ON THE BUILDING SIDE OF THE GAP SHALL BE BONDED TO THE PBB. ALL METALLIC PATHWAYS FOR TELECOMMUNICATIONS CABLING LOCATED WITHIN THE SAME ROOM OR SPACE AS THE PBB SHALL BE BONDED TO THE PBB. HOWEVER FOR METALLIC PATHWAYS CONTAINING BONDING CONDUCTORS WHERE THE PATHWAY IS BONDED TO THE BONDING CONDUCTOR, NO ADDITIONAL BOND TO THE PBB IS REQUIRED.
- 8. CONNECTIONS TO THE PBB: THE CONNECTIONS OF THE TBC TO THE PBB SHALL UTILIZE EXOTHERMIC WELDING, LISTED COMPRESSION TWO-HOLE LUGS, OR LISTED EXOTHERMIC TWO-HOLE LUGS. THE CONNECTION OF CONDUCTORS FOR BONDING TELECOMMUNICATIONS EQUIPMENT AND TELECOMMUNICATIONS PATHWAYS TO THE PBB SHALL UTILIZE EXOTHERMIC WELDING, LISTED COMPRESSION TWO-HOLE LUGS, OR LISTED EXOTHERMIC TWO-HOLE LUGS.

BONDING CONDUCTOR SIZING CRITERIA			
TBC LINEAR LENGTH (FEET)	TBC CONDUCTOR SIZE (AWG)		
LESS THAN 13	6		
14 - 20	4		
21 - 26	3		
27 - 33	2		
34 - 41	1		
42 - 52	1/0		
53 - 66	2/0		
67 - 84	3/0		
85 - 105	4/0		
106 - 125	250 kcmil		
126 - 150	300 kcmil		
151 - 175	350 kcmil		
176 - 250	500 kcmil		
251 - 300	600 kcmil		
GREATER THAN 301	750 kcmil		
INFO BASED ON ANSI/TIA-607-C			

- RACK BONDING BUSBAR (RBB): SHALL HAVE A MINIMUM CROSS-SECTIONAL AREA EQUAL TO A 6 AWG WIRE, AND BE LISTED. EQUIPMENT CONTAINING METALLIC PARTS AND PATCH PANELS FOR SHIELDED CABLING IN CABINETS AND RACKS SHALL BE BONDED TO THE TELECOMMUNICATIONS BONDING SYSTEM IN ACCORDANCE WITH THE MANUFACTURER INSTRUCTIONS. WHERE INSTRUCTIONS ARE NOT GIVEN, ALL BONDING CONDUCTORS THAT CONNECT THESE INSTALLED PRODUCTS SHALL BE A MINIMUM SIZED CONDUCTOR OF 12 AWG. BOND ALL RACKS WITH 4 AWG CONDUCTOR; ROUTE CONDUCTOR ALONG RACK REAR AND IN CABLE RUNWAY TO GROUNDING BUSBAR.
- 11. BUILDING STRUCTURAL METAL: WHERE STRUCTURAL METAL IS ACCESSIBLE AND IN THE SAME ROOM AS THE PBB, THE PBB SHALL BE BONDED TO STRUCTURAL METAL USING A MINIMUM SIZED CONDUCTOR OF 6 AWG.
- 12. RUN CONDUCTOR FROM BUSBAR LOCATION TO BUILDING SERVICE GROUND IN EMT CONDUIT PROVIDE INSULATED GROUNDING BUSHING - AT CONDUIT ENDS AND GROUND PER NEC. GROUNDING TO BUILDING STRUCTURE, CONDUITS, UTILITY PIPING, OR ELECTRICAL SUBPANELS IN LIEU OF BONDING TO BUILDING MAIN ELECTRICAL SERVICE GROUND IS NOT ACCEPTABLE.

TELECOM GROUNDING / BONDING DETAIL





() <u>TELECOM SINGLE LINE DIAGRAM NOTES:</u>

- REPRESENTATIVE (UNO).
- PROVIDE INDICATED STRAND QUANTITY.
- **REPRESENTATIVE (UNO).**
- STANDARDS. PROVIDE INDICATED PORT QUANTITY.
- PINOUT ARRANGEMENT.
- PLUS 10% SPARE.
- TERMINATED TO T568A PINOUT ARRANGEMENT.



DATA / VOICE SINGLE LINE DIAGRAM

1. FIBER OPTIC BACKBONE INTERCONNECT UNIT, PROVIDE INDICATED MODULE TYPE / QUANTITY; PROVIDE LABELING ON FRONT COVER TO INDICATE SERVING ROOM SOURCE, EACH ROOM'S DESTINATION, AND EACH CABLING QUANTITY / TYPE. CONFIRM TERMINATION MODULE WITH OWNER'S TECHNICAL

2. FIBER OPTIC BACKBONE CABLE, CABLING TYPE INDICATED, DIELECTRIC, INDOOR/OUTDOOR, PLENUM RATED (IF REQUIRED) PER NFPA, (UNO). RUN CONTINUOUS FROM SOURCE TO DESTINATION WITH NO SPLICES OR TERMINATIONS. ADHERE TO TIA-598 JACKET COLOR CODING SCHEME FOR BACKBONE FIBER ONLY. CONFIRM TERMINATION MODULES WITH OWNER'S TECHNICAL REPRESENTATIVE (UNO).

3. FIBER OPTIC PATCH CORD; DUAL STRAND, DIELECTRIC, PRE-MANUFACTURED, FACTORY TERMINATED AND TESTED. PROVIDE QUANTITY AS REQUIRED, PLUS 10% SPARE. PATCH CORD TYPE, MODULE, AND COLOR TO MATCH SERVING DEVICES. CONFIRM ALL PATCH CORD REQUIREMENTS WITH TECHNICAL

4. CATEGORY 6 HORIZONTAL PATCH PANEL WITH 8P8C UTP (UNSHIELDED TWISTED PAIR) MODULAR JACKS, COLOR TO MATCH FACEPLATE JACK; PROVIDE WITH REAR CABLE MANAGERS. LABEL JACKS ACCORDING TO OWNER'S TECHNICAL REPRESENTATIVE'S REQUIREMENTS OR ADHERE TO TIA 606 LABELING

5. CATEGORY 6 HORIZONTAL WIRING; UTP (UNSHIELDED TWISTED PAIR), 4-PAIR, 23 AWG, PLENUM RATED (IF REQUIRED) PER NFPA, MAXIMUM INSTALLED LENGTH 90 METERS (295'), TERMINATED TO T568A

6. DATA / VOICE OUTLET WITH CATEGORY 6 8P8C UTP (UNSHIELDED TWISTED PAIR) MODULAR JACKS FOR DATA/VOICE CONNECTIONS, TERMINATED TO T568A PINOUT ARRANGEMENT.

7. CATEGORY 6 PATCH CORDS WITH UTP (UNSHIELDED TWISTED PAIR) 8P8C MODULAR PLUG, PRE-MANUFACTURED WITH NO BOOT, FACTORY TERMINATED AND TESTED TO T568A PINOUT ARRANGEMENT. COLOR TO MATCH SYSTEM JACK. PROVIDE QUANTITY OF PATCH CORDS AS REQUIRED

8. NETWORK RJ-45 JACK; WITH CATEGORY 6 8P8C UTP (UNSHIELDED TWISTED PAIR) MODULAR JACKS,

Bicsi

SLO JO

9. DEVICE DESTINATION CABLE LABELING, PER ANSI/TIA LABELING STANDARDS.



TV SYSTEM GENERAL NOTES:

- 1. CABLE SHALL BE CONTINUOUS BETWEEN DEVICES. INTERMEDIATE SPLICES OR COUPLINGS ARE NOT ALLOWABLE.
- 2. ALL COAXIAL CONNECTORS SHALL BE 'F' COMPRESSION TYPE, FOR RG-6 AND RG-11, SPECIFICALLY SIZED FOR EACH CONNECTOR TYPE.
- 3. PROVIDE EQUALIZERS AS REQUIRED TO COMPENSATE FOR CABLE SLOPE ADJUSTMENT FOR BACKBONE CABLE FEEDS.
- 4. TERMINATE ALL UNUSED SPLITTER PORTS WITH 75 OHM TERMINATING RESISTORS.
- 5. MOUNT ALL DISTRIBUTION AMPLIFIERS WITH LONG SIDE (HEAT SINKS) IN THE DIRECTION OF VERTICAL, NOT HORIZONTAL, FOR PROPER HEAT DISPLACEMENT.
- 6. PROVIDE SPLITTERS/TAPS WITH RESISTIVE NETWORK CIRCUIT BOARDS IN LIEU OF FERRITE BEADS.
- 7. PROVIDE PROFESSIONAL GRADE FACTORY JUMPERS, RG-6 COAX WITH SCREW-ON ENDS, QUANTITY EQUAL TO NUMBERS OF TV OUTLETS SHOWN ON PLANS, PLUS 25% SPARE, LENGTH AS REQUIRED.
- 8. ALL INPUT CABLES SHALL NOT BE BUNDLED WITH OUTPUT CABLES. PHYSICAL SEPARATION BETWEEN INPUT AND OUTPUT CABLES SHALL BE MAINTAINED.
- 9. PROVIDE PLENUM RATED CABLING PER NFPA.
- 10. REFER TO FLOOR PLANS FOR ACTUAL DEVICE COUNTS.









FIRE STATION MAIN TELECOM ROOM (MTR.108A) -ENLARGED EQUIPMENT PLAN T4.1 SCALE: 1/2"=1'-0"



GENERAL CABLE RUNWAY NOTE PROVIDE ALL FACTORY COMPONENTS MATCHING CABLE RUNWAY SPECIFIED FOR THE FOLLOWING:

RADIUS BENDS FOOT-MOUNTS

INSTALL ALL CABLE RUNWAY AND RELATED FITTING AND ACCESSORIES ACCORDING TO THE MANUFACTURERS PRINTED INSRUCTIONS, UNLESS OTHERWISE NOTED.

TYPICAL RUNWAY TO RACK SUPPORT DETAIL 3 NOT TO SCALE







TYPICAL VERTICAL CABLE RUNWAY DET NOT TO SCALE

CABLE RUNWAY MOUNTING HEIGHT NOTE BOTTOM OF CABLE RUNWAY MUST BE MOUNTED AT EXACTLY 7'-0" ABOVE THE FINISHED FLOOR TO ALLOW INSTALLATION OF 7'-0" HIGH RACKS (UNLESS NOTED OTHERWISE).

BUTT-SPLICE KITS TRIANGULAR WALL SUPPORTS CABLE RUNWAY RADIUS DROPS JUNCTION SPLICE KITS ALL-THREAD SUPPORT BRACKETS WALL-ANGLE SUPPORTS

Ά	I	L	

FOR ADDITIONAL INFORMATION. 2. FOR SITE PLAN AND SITE DETAILS, REFER TO SHEETS T1.0 AND T1.1. 3. FOR ADDITIONAL DETAILS, REFER TO SHEETS T2.1 -T2.3. 4. FOR SINGLE LINE DIAGRAM, REFER TO SHEETS T3.1 AND T3.2. KEY NOTES: PLYWOOD BACKBOARD, 8'-0" WIDE X LENGTH AS SHOWN, MOUNTED ON WALLS INDICATED; MOUNT WITH BOTTOM AT 6" ABOVE FINISH FLOOR, COUNTERSINK ALL SCREWS. ROUGH ALL ELECTRICAL OUTLETS IN BACKBOARD FOR FLUSH MOUNT INSTALLATION OF FACEPLATES. BACKBOARDS SHALL BE 5/8" THICK A-C GRADE FIRE-RATED PLYWOOD, WITH "A" SIDE OUT, BEARING THE MANUFACTURER'S STAMP, WITH FIRE-RETARDANT BATTLESHIP GRAY PAINT. PRIMARY BONDING BUSBAR (PBB), REFER TO TELECOM GROUNDING / BONDING DETAILS, SHEET T2.3. 2-POST EQUIPMENT RACK, REFER TO RACK ELEVATION, SHEET T5.1. CABLE RUNWAY (WIDTH INDICATED). PROVIDE BUTT-SPLICE KIT TO BUTT-SPLICE SECTIONS, WALL ANGLE SUPPORT KITS, CEILING SUPPORT BRACKETS, AND JUNCTION SPLICE KITS OF CABLE RUNWAY. INSTALL ALL CABLE RUNWAY, FITTINGS, AND ACCESSORIES IN ACCORDANCE WITH MANUFACTURER'S PRINTED INSTRUCTIONS. COMMUNICATIONS SERVICE/BACKBONE CABLING CONDUIT. REFER TO T1.0 FOR SIZE/QUANTITY. REVISIONS NO. DESCRIPTION DRAWN CHECKED DATE PHASE DRAWN CHECKED DATE SCHEMATIC DESIGN 11/Ø5/21 DESIGN DEVELOPMENT 12/17/21 60% DOCUMENTS Ø2/11/22 90% CONSTRUCTION DOCUMENTS @3/31/22 - CONSTRUCTION DOCUMENTS Ø5/16/22 BID SET Ø7/Ø1/22 2211 THOMAS DR. , STE 100 PANAMA CITY BEACH, FL PHONE: (850) 236-9832 ARCHITECTS commission Number: 21804 CONSULTANTS: LOGAN 918 HIGHWAY 98 EAST DESTIN, FL 32541 D 850.427.2140 WWW.LOGANTECHGROUP-LLC.COM PROJECT: PANAMA CITY BEACH FIRE STATION # 31 REPLACEMENT NICATIONS DISTO BAY COUNTY, FLORIDA Bicsi SHEET TITLE: ENLARGED FLOOR PLANS JOSHUA A. LOGAN BICSI ID # 160273 MAIN TELECOM ROOM EXPIRES 12-31-24 • RCDD • SHEET NUMBER: †₄,ı

GENERAL NOTES:

REFER TO LEGEND AND NOTES, SHEETS T0.1 AND T0.2

SCALE: 1/2"=1'-0"



- KEY NOTES: 3.65" x 7'-0", COLOR BLACK. 3. IDENTIFICATION TAG AT TOP OF RACK. 5. CONCRETE FLOOR RACK MOUNTING KIT. 7. RACK ISOLATION KIT.
- ACCESS POINT (WAP).



CAUTION:

FIBER OPTIC CABLE

MTR.A/TR.B F1-F24

4. ONE RACK SPACE BLANK FILLER PLATE, COLOR BLACK.

6. RACK BASE DUST COVER, BLACK ENAMEL FINISH.

8. NYLON CABLE STANDOFF BRACKET, MOUNT ON BACK LEFT SIDE OF ALL RACKS AT 12" ON CENTER FOR ROUTING GROUNDING CONDUCTORS AND POWER EXTENSION CORDS UP AND DOWN RACKS. VELCRO STRAP EACH CONDUCTOR AND CORD INDIVIDUALLY ON STANDOFF. (NOT SHOWN ON ELEVATIONS)

9. BACKBONE FIBER DRAWER, RACK MOUNT BY SERVICE PROVIDER.

10. CATEGORY 6 HORIZONTAL WIRING PATCH PANEL.

11. RACK-MOUNTABLE 2200VA UPS W/120V, 1Ø, OUTPUT. COORDINATE REQUIRED NEMA RECEPTACLE WITH OWNER PRIOR TO INSTALLATION.

12. CATEGORY 6 HORIZONTAL WIRING PATCH PANEL FOR WIRELESS



FRONT VIEW



WALL MOUNT TELECOM DISTRIBUTION CABINET 2 NOT TO SCALE

PROVIDE SELF-LAMINATING WRITE-ON FIBER OPTIC CABLE MARKER RIGID (NON-ADHESIVE) TAG, PANDUIT PST-FO, WITH SELF-ADHESIVE LAMINATING LABLES (LASER PRINTED).



TYPICAL FIBER BACKBONE CABLE CODING FOR PATCH PANEL SERVING EACH TELECOMMUNICATIONS ROOM

FIBER OPTIC BACKBONE NOMENCLATURE

MTR.A/TR.B MMF1-F12 **TELCOM ROOM** DESIGNATOR -

BACKBONE CABLE AND STRAND ID

L TELCOM ROOM DESIGNATOR

BACKBONE CABLE LABELING

LABEL ALL BACKBONE CABLES WITHIN 12" OF CABLE BREAKOUT POINT WITH PERMANENT MYLAR WRAP WRITE-ON MARKERS.

NAME FORMULA = ROOM NUMBER/ ROOM NUMBER, CABLE TYPE (F = FIBER) AND STRAND COUNT (STRANDS 1-12). EACH PANEL WILL CONTAIN A SPREADSHEET DETAILING WHAT STRAND OF CABLE CONNECTS TO WHAT PORT NUMBER.



GENERAL NOTES: