



BOARD OF COUNTY  
COMMISSIONERS

WWW.BAYCOUNTYFL.GOV

840 WEST 11<sup>TH</sup> STREET  
PANAMA CITY, FL 32401

COMMISSIONERS:

TOMMY HAMM  
DISTRICT I

ROBERT CARROLL  
DISTRICT II

WILLIAM T. DOZIER  
DISTRICT III

DOUGLAS MOORE  
DISTRICT IV

CLAIR PEASE  
DISTRICT V

ROBERT J. MAJKA  
COUNTY MANAGER

## PURCHASING DEPARTMENT

840 West 11<sup>th</sup> Street  
Panama City, Florida 32401  
Telephone: (850) 248-8270  
Fax: (850) 248-8276

May 2, 2024

Prospective Respondents

### RE: Addendum #1 24-37 Bay County Sheriff's Office Helicopter Facility.

Please accept this as Addendum No. 1 for the above referenced solicitation.

The following question have been received. The County's answer follows in **bold**.

1. Are there hardware sets available for this project? There are remarks regarding alarms and delayed egress under door schedule remarks but there is no remark number on the door schedule.  
**Remarks shown on plans does not apply.**
2. What is the wall panels type and thickness for building? **The Project building will be design and stamped by the Metal Building designer. As long as it meets the wind requirement per ITB 24-37 and Scope of Work.**
3. What type of roof panels and thickness for building? **Designer decision as long as it meet requirement set forth in ITB 24-37 and scope of work.**
4. What frame type is requested for this building? **Designer decision as long as it meet requirement set forth in ITB 24-37 and scope of work.**
5. Any specific color for the roof or wall panels? **White.**
6. Any specific warranty to be included as part of the building? **Stand metal building warranty per the selected brand by bidder.**
7. What is the insulation R-Value of Roof and Wall? **Meet Code.**

8. Please advise as to what type of hardware is being requested and if it will be alarmed and delayed egress.

<b>DOOR SCHEDULE REMARKS:</b>
1. DOOR TO BE ALARMED WITH DELAYED EGRESS FUNCTION FULLY COMPLYING WITH FBC SECTION 1008.1.9.7 DELAYED EGRESS LOCKS.
2. DOOR HAS LIMITED OVERHEAD CLEARANCE. VERIFY CLEARANCE REQUIRED FOR PROPOSED DOOR.

REMARKS
SEE PEMB DRAWINGS
BASIS OF DESIGN: HIGHER POWER HYDRAULIC DOORS
SEE PEMB DRAWINGS

- **New (2) doors to be metal 3'-0" x 7'-0" doors, No lite package to with stand 165 mph winds.**
- **Hinges install and bid to be equal to or greater than Hager, ECBB1100**
- **Doors to have silencers and be 16 GA**
- **Front door Hager extra Heavy Duty Grade Entrance/Office Model 3450**
- **Side door Hager model 4701-32D exit Device with other proper materials/hardware to operate properly**
- **Any Notes referencing to Pre-Engineered Metal Building drawings, remember as per bid documents and Scope of Work the PEMB plans are being provided by the bidder. Drawing must be Stamped Engineering plans.**

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,

Ken Longstreet  
Grant Procurement Administrator