



BOARD OF COUNTY
COMMISSIONERS

WWW.BAYCOUNTYFL.GOV

840 WEST 11TH STREET
PANAMA CITY, FL 32401

COMMISSIONERS:

TOMMY HAMM
DISTRICT I

ROBERT CARROLL
DISTRICT II

WILLIAM T. DOZIER
DISTRICT III

DOUGLAS MOORE
DISTRICT IV

CLAIR PEASE
DISTRICT V

ROBERT J. MAJKA
COUNTY MANAGER

PURCHASING DEPARTMENT

840 West 11th Street
Panama City, Florida 32401
Telephone: (850) 248-8270
Fax: (850) 248-8276

May 3, 2024

Prospective Respondents

RE: Addendum #2 24-37 Bay County Sheriff's Office Helicopter Facility.

Please accept this as Addendum No. 2 for the above referenced solicitation.

The following question have been received. The County's answer follows in **bold**.

1. Please confirm if the zero slope jack frame for 2 ton electric winch and haul master 2 ton push beam trolley. Exhibit 2 in the invitation to bid documents says, "Do not install the winch shown on drawings." Does the pre-engineered building still need to be designed to support the winch and trolley at a future date or is the jack frame no longer needed? **The Winch is not to be included in bid. The Building structure is not to be designed for winch in the future.**
2. Please confirm the size of the louvers. On the Louver schedule on M001 there is not a size for the Louver 3. The size for the Louver 4 calls it as 36" x36" but when you measure it on the drawings the size is 2'-10" x 2'-10" . Please advise what is the correct size of the Louver 4 as well as please provide the size for the Louver 3. **Louvers on the exterior building to all be 36" x 36", Louvers to match in size.**
3. What is the floor type for the building? **Concrete Slab to have a trowel finished**
4. Is there a finish schedule? **It's a metal building as stated at bid meeting. Interior walls, restrooms and breakroom are not included in the scope of work.**
5. Can hydraulic doors be substituted for this project? **Yes, as long as substituted doors meet and/or exceed specifications. The Engineered metal building envelope is being designed as part of the bid and the envelope shall meet 165 mph wind.**

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,

Ken Longstreet
Grant Procurement Administrator