

Thomas M. McElrath, Architect
717 Merit Springs Road
Gadsden, AL 35901
PHONE: 256-490-8244
EMAIL: tom@tmm-architect.com

ADDENDUM NO. 4

April 29, 2024

PROJECT: **A NEW CITY HALL and MUNICIPAL OFFICE FACILITY**
located at 350 W. Main Street
Centre, Alabama

ARCHITECT'S PROJECT NO. 2022-06

TO: **ALL BIDDERS AND PLAN HOLDERS OF RECORD**


This Addendum forms a part of the Contract Documents and modifies the original Project Manual and Drawings, dated February 28, 2024. Bidders shall acknowledge receipt of this Addendum on the Proposal Form. This Addendum contains One (1) - 8-1/2" x 11", pages.

- A. **MODIFICATIONS TO PART I - CONTRACTURAL & LEGAL REQUIREMENTS:** NONE
- B. **MODIFICATIONS TO PART II - TECHNICAL SPECIFICATIONS:** NONE
- C. **MODIFICATIONS TO DRAWINGS:** NONE
- D. **CLARIFICATIONS TO DRAWINGS and SPECIFICATIONS:**

SHEET M0.2 of 6:

- a. At the Air Purification Schedule, change the items with an asterisk at the bottom of the schedule to read "**IHP-1 and AC-2**" in lieu of IHP-1 and IHP-2.
 - b. At Indoor Aire Handling Unit Schedule – Gas Furnace, delete Note 4 in its entirety. **AC Units 2, 3, 4, 5 and 6 are to be Natural Gas fired units.**
- E. **PRIOR APPROVALS:** NONE (Prior Approval window has expired)

END OF ADDENDUM NO. 4

By 
Thomas M. McElrath, Architect
