

Questions and Answers #6

71. Regarding the Bon Secour VS/Admin Building. I noticed that the SOW references a PPQ, but I was unable to find any attachment in Sam.Gov.

USFWS Response: Please see the PPQ attachment.

72. Attached is a copy of the finish schedule and legend. I highlighted and noted on the sheet what I am referencing. We need to know the location and height of the wainscot walls.(All walls or just wet walls etc...)

USFWS Response

Lay out tile wainscots to 38-inches or to next full tile beyond this height, all restroom walls. The showers are pre-fabricated stalls, so wainscoting is not needed in the stalls.

B-1 and B-2 are bases. B1 is 4” high. B2 is 6” high.

CWT-1 is 12” tile

CTW-2 is 4.25” tile

73. Would the Government please confirm that the CPARS and the PPQs would be excluded from the (maximum 10-page count) on Past Performance?

USFWS Response

Yes they will be excluded from the page count,