



300 CHASE PARK SOUTH • SUITE 200 • HOOVER, ALABAMA 35244
205-988-9112

ADDENDUM NO. 2
NEW PORTABLE CLASSROOMS FOR
FOREST HILLS ELEMENTARY SCHOOL
Architect Job No. 24-108
March 28, 2025
DCM # 2025169

BIDS DUE:

Tuesday, April 1, 2025, until
2:00 p.m., local time, at
Florence City Board of Education
541 Riverview Drive
Florence, AL 35630

The Plans and Specifications are here by amended. The following supersedes all contrary and/or conflicting information and is made part of the contract documents.

CLARIFICATIONS

1. Fire alarm devices and wiring shall be provided by Owner's fire alarm vendor. Conduits and junction boxes are to be furnished and installed by the general contractor. See Fire Alarm System Notes on Sheet E1.1.
2. The vertical run of the conduit at the gym wall will be 25'.
3. Fire hydrates around the gym are to be rotated with the pumper nozzle to the curb, Contractor is to contact the Florence Water Department to coordinate.
4. Rotate existing fire department connection for the gym to the curb, Contractor is to contact the fire protection vendor to coordinate.
5. Add fire alarm notification devices to restrooms.