

GLYNN WILSON CLARK
ARCHITECT
RESPONSE TO RFI

Response 1

October 29, 2025

To: General Contractors of Record

The following responses are to Pre Bid RFI #1 dated 10/27 from Hurst Construction

1. Yes the City of Wedowee will waive all fees relative to acquiring a building permit.
2. A Wedowee Building License will be required
3. The local power company is Alabama Power, they are currently reviewing the Electrical Documents. The city of Wedowee will pay any fees required by the power company.
4. Curries is approved as a manufacturer of Hollow Metal Doors
5. Forte is not approved as a manufacturer for wood doors.
6. Door 127 is located accessing RR 127 from Room 125, C-10 is the correct hardware.
7. Pavement detail has been added to Sheet C-3.
8.
 - a. 15" RCP class 3 or equivalent HDPE pipe
 - b. Storm structure at north end of lower parking lot is a single wing storm inlet.
 - c. Sheet c-2 has been revised to show location to existing main tap.
9. Yes, the site is over an acre and will require an ADEM stormwater permit.

The following responses are to Pre-Bid RFI #2 dated 10/27 from Hurst Construction

I have requested clarification to an electrical Subcontractor's questions and will share when received.

I am including Soils Report for your information.



Glynn Wilson Clark
Architect

INCLUDED WITH ADDENDUM NO 1