


February 3, 2026



ADDENDUM NO. 4

Autauga WMA Office Meeting Complex
Prattville, Alabama

This Addendum No. 4, to the plans and specifications, dated 02 December 2025, consists of One (1) Page.

Item No. 1: Refer to Specifications, Section 08 43 13, 2.01, A: Aluminum Framed Storefronts:

- A. Tubelites E14000 Series is hereby approved subject to strict conformance with the plans and specifications.

Item No. 2: Refer to Plans, Sheet A3.1, 19 of 46, Storefront and Door and Window Schedules and Details:

- A. **CLARIFICATION:** Roll up doors shall be insulated.

Item No. 3: Refer to Plans, Sheet M0.1, 38 of 46, Mechanical Legends, Notes, and Details:

- A. **CLARIFICATION:** Heat Pump No. 1 does not require hot gas reheat.

END OF ADDENDUM NO. 4